

**PUBLIC DISCLOSURE DOCUMENT**

**BEFORE THE GEORGIA PUBLIC SERVICE COMMISSION**

**STATE OF GEORGIA**

In Re: Generic Proceeding to Implement : Docket No. 43453  
House Bill 244 :

**DIRECT TESTIMONY**

**AND EXHIBITS**

**OF**

**DILBON RENE SMITH,**

**HERSCHEL ARANT,**

**TITUS DIAMOND, and**

**KEITH BROWN**

**ON BEHALF OF GEMC  
AND 38 OF ITS EMC MEMBERS**

**OCTOBER 23, 2020**

# **PUBLIC DISCLOSURE DOCUMENT**

## **TABLE OF CONTENTS**

I.	INTRODUCTION AND BACKGROUND .....	1
II.	RULES GOVERNING POLE ATTACHMENTS .....	16
III.	FAILURE TO COMPLY WITH VERTICAL CLEARANCE REQUIREMENTS.....	20
IV.	FAILURE TO COMPLY WITH SEPARATION REQUIREMENTS .....	32
V.	FAILURE TO PROPERLY SUPPORT THE POLE AND ADHERE TO LOADING AND STRENGTH REQUIREMENTS .....	46
VI.	FAILURE TO COMPLY WITH OTHER ATTACHMENT REQUIREMENTS .....	59
VII.	IMPACT TO GEORGIA EMCS .....	69
VIII.	CONCLUSION.....	73

**PUBLIC DISCLOSURE DOCUMENT**

**BEFORE THE  
GEORGIA PUBLIC SERVICE COMMISSION**

**PRE-FILED DIRECT TESTIMONY AND EXHIBITS OF  
DILBON RENE SMITH, HERSCHEL ARANT,  
TITUS DIAMOND, AND KEITH BROWN  
ON BEHALF OF  
GEORGIA ELECTRIC MEMBERSHIP CORPORATION**

**DOCKET NO. 43453**

**I. INTRODUCTION AND BACKGROUND**

**Q. Each of you please provide your name and title.**

**A. By Mr. Smith:** My name is Dilbon Rene Smith. I am the President and Chief Executive Officer of Sumter Electric Membership Corporation (“Sumter EMC”) and have served in this capacity since January 2020. Prior to becoming the Chief Executive Officer of Sumter EMC, I served as Sumter EMC’s Senior Vice President of Operations. Sumter EMC serves 14,917 member-owners in Chattahoochee, Dougherty, Lee, Marion, Quitman, Randolph, Schley, Stewart, Sumer, Terrell, and Webster counties.

**A. By Mr. Diamond:** My name is Titus Diamond. I am the Chief Operating Officer of Flint Electric Membership Corporation (“Flint EMC”) and have served in this capacity since January 2006. Flint EMC serves 74,043 members-owners in Bibb, Chattahoochee, Crawford, Dooly, Harris, Houston, Macon, Marion, Monroe, Muscogee, Peach, Schley, Sumter, Talbot, Taylor, Twiggs, and Upson counties.

**A. By Mr. Brown:** My name is Keith Brown. I am the Chief Operating Officer of Hart Electric Membership Corporation (“Hart EMC”) and have served in this capacity since 2018. Hart

## PUBLIC DISCLOSURE DOCUMENT

1 EMC serves 26,097 member-owners in Hart, Franklin, Stephens, Elbert, Madison, and  
2 Banks counties.

3 **A.** By Mr. Arant: My name is Herschel K. Arant, Jr. I am the Senior Vice President of  
4 Engineering & Energy Supply at Central Georgia Electric Membership Corporation  
5 (“Central Georgia EMC”) and have served in this capacity since February 2017. Central  
6 Georgia EMC serves 48,093 member-owners in Bibb, Butts, Clayton, Fayette, Henry,  
7 Jasper, Jones, Lamar, Monroe, Morgan, Newton, Pike, Putnam, and Spalding counties.

8 **Q. On whose behalf is this testimony being presented?**

9 **A.** By the Panel: Our testimony is offered on behalf of Georgia Electric Membership  
10 Corporation (“GEMC”) and its 38 not-for-profit cooperative members (“Georgia EMCs”) that are subject to the Georgia Broadband Opportunity Act (“GBOA”), which, in order to  
11 promote the deployment of broadband services in this state, gives the Georgia Public  
12 Service Commission the authority to set rates, fees, terms, conditions, and specifications  
13 for pole attachment agreements entered into by a communications service provider and the  
14 cooperatives on and after July 1, 2021.

15 **Q. Each of you please summarize your educational background.**

16 **A.** By Mr. Smith: I was born and raised in Dooly County, Georgia and attended Fullington  
17 Academy in Pinehurst, where I earned my high school diploma. After graduating high  
18 school, I attended Southern Polytechnic State University in Marietta, Georgia where I  
19 earned a Bachelor of Science degree in Electrical Engineering Technology, Power  
20 Generation and Distribution Option in March 1988. I subsequently studied at Auburn  
21 University where I earned a Master’s degree in Business Administration in May 2011.  
22

## PUBLIC DISCLOSURE DOCUMENT

- 1    **A.**    By Mr. Diamond: I was born in Brewton, Alabama and was raised in Quincy, Florida. After  
2            graduating high school, I attended the University of Florida in Gainesville, Florida where  
3            I earned a Bachelor of Science degree in Electrical Engineering in May 1983. I later studied  
4            at Georgia College and State University where I earned a Master’s degree in Business  
5            Administration in May 2003. I have also participated in the National Rural Electric  
6            Cooperative Association (“NRECA”) Manager Leadership Laboratory, the NRECA  
7            Management Internship Program, the Institute of Electrical and Electronics Engineers  
8            National Electric Safety Code School, and the McGraw Overvoltage School.
- 9    **A.**    By Mr. Brown: I was born and raised in Hart County, Georgia. After graduating high  
10           school, I attended Georgia Institute of Technology (“Georgia Tech”) where I studied  
11           Electrical Engineering. I studied at Georgia Tech for two years before transferring to  
12           Southern Polytechnic State University in Marietta, Georgia. I graduated from Southern  
13           Polytechnic State University with a Bachelor of Science degree in Electrical Engineering  
14           Technology in 1988.
- 15   **A.**    By Mr. Arant: I grew up in Pitts, Georgia and attended Wilcox County High School. After  
16           graduating from high school, I attended Georgia Tech where I earned a Bachelor’s degree  
17           in Electrical Engineering in 1994. After earning my Bachelor’s degree, I continued  
18           studying at Georgia Tech and, in 1995, earned a Master of Science degree in Electrical  
19           Engineering. I later studied at Georgia State University in Atlanta, Georgia and earned a  
20           Master’s degree in Business Administration in 2003.

**PUBLIC DISCLOSURE DOCUMENT**

1 **Q. Each of you please identify any professional certifications you have that are relevant**  
2 **to this proceeding.**

3 **A. By Mr. Smith:** In June 2007, I became a Registered Professional Engineer in Georgia and  
4 I continue to maintain that certification.

5 **A. By Mr. Diamond:** In July 1990, I became a Registered Professional Engineer in Georgia  
6 and I continue to maintain that certification.

7 **A. By Mr. Brown:** In 1998, I became a Registered Professional Engineer in Georgia and I  
8 continue to maintain that certification.

9 **A. By Mr. Arant:** In 1999, I became a Registered Professional Engineer in Georgia. In 1999,  
10 I became a Registered Professional Engineer in North Carolina. I continue to maintain both  
11 certifications.

12 **Q. Each of you please summarize your professional background.**

13 **A. By Mr. Smith:**

14 My post-graduate employment includes over 32 years of experience with Sumter  
15 EMC. After graduating from Southern Polytechnic State University in March 1988, I  
16 started working at Sumter EMC. Between March 1988 and January 2020, when I became  
17 Sumter EMC's President and Chief Executive Officer, I held multiple positions with ever  
18 increasing responsibility at Sumter EMC, all of them involving pole attachment and joint  
19 use agreements and the resulting engineering issues created by cable and Incumbent Local  
20 Exchange Carrier ("ILEC") attachments. As President and Chief Executive Officer I am  
21 ultimately responsible for delivering safe and reliable electricity to Sumter EMC's 14,917  
22 member-owners 24 hours a day, 365 days a year in eleven counties in South Georgia. To

## PUBLIC DISCLOSURE DOCUMENT

1 meet this objective, we need a pole plant that is soundly engineered and free of code  
2 violations created by attaching entities.

3 My first role with Sumter EMC was as a Planning Engineer. In this position, my  
4 primary responsibility was developing project-specific engineering strategies. I was also  
5 responsible for conducting engineering studies to determine whether and where  
6 improvements to Sumter EMC's power distribution system needed to be made so that the  
7 system operated reliably and within the guidelines of the American National Standards  
8 Institute, the Institute of Electrical and Electronics Engineers, and the Rural Electric  
9 Association. I also provided engineering support for the design, construction, and  
10 maintenance of the cooperative's poles, wires and other electrical facilities, and served as  
11 an on-call supervisor over the line personnel who responded to system outages. I remained  
12 a Planning Engineer at Sumter EMC until January 1994 when I was promoted to  
13 Operations Engineer. As an Operations Engineer, I continued the duties of my previous  
14 position and also directed meter reading functions, assisted in the development of standard  
15 operating procedures and financial budgets, supervised five operations employees, and  
16 conducted various engineering studies. I remained an Operations Engineer until July 1997  
17 when I was promoted to Vice President of Operations. In this position, I supervised 15  
18 engineering department personnel, developed and implemented department budgets,  
19 coordinated department activities to achieve corporate financial and operational goals, and  
20 assessed and implemented software and hardware systems to improve corporate efficiency  
21 and power system reliability. As the Vice President of Operations, I also assisted in  
22 developing proposals for the delivery of electric services to large power loads. I remained

## PUBLIC DISCLOSURE DOCUMENT

1 Vice President of Operations until January 2001 when I was promoted to Vice President  
2 of Engineering and Operations. As Sumter EMC's Vice President of Engineering and  
3 Operations, my primary responsibilities included supervising 42 engineering and  
4 construction department personnel, developing and implementing budgets, coordinating  
5 department activities, and designing and constructing Sumter EMC's utility distribution  
6 system. I also supervised the drafting, bidding, awarding, and implementation of  
7 maintenance and construction contracts for Sumter EMC's power distribution system. I  
8 remained the Vice President of Engineering and Operations until January 2004 when I was  
9 promoted to Senior Vice President of Operations. In this position, I reviewed and analyzed  
10 distribution line standards and was responsible for ensuring that these standards maximized  
11 reliability while minimizing costs. As the Senior Vice President of Operations, I was also  
12 involved in many aspects of Sumter EMC's distribution system, including engineering,  
13 planning, safety, and improvements as well as the construction and maintenance of the  
14 distribution system. I remained Sumter EMC's Senior Vice President of Operations until  
15 January 2020 when I was appointed Sumter EMC's President and Chief Executive Officer,  
16 which is the position I currently hold.

17 As Sumter EMC's President and Chief Executive Officer, I am responsible for all  
18 aspects of the cooperatives business and operations including engineering, reliability, and  
19 safe construction and maintenance of Sumter EMC's electrical transmission and  
20 distribution system. In my current position, and in my prior positions at Sumter EMC, I  
21 have seen, time and time again, communications attachments on EMC owned poles,

**PUBLIC DISCLOSURE DOCUMENT**

1 including Sumter EMC’s poles, that violate national safety standards, violate EMC  
2 standards, damage or destroy the utility poles, and impact the systems reliability.

3 **A.** By Mr. Diamond:

4 My post-graduate employment includes over 37 years of experience with  
5 cooperatives, 33 of which are with Georgia EMCs. After graduating from the University  
6 of Florida, I moved to Lake Panasoffkee, Florida and joined Sumter Electric Cooperative  
7 (“SECO”) in Florida. I worked at SECO from June 1983 until August 1987 and held two  
8 positions. My first position was as an Electrical Engineer. In this position, I designed the  
9 layout, foundations, relay schemes, and control wiring for two 69kV to 12.5/25kV  
10 substations. I was also responsible for designing overcurrent protection and coordination  
11 schemes for ten distribution substations and assisting in the development of distribution  
12 construction specifications. My second position at SECO was as the Director of  
13 Operations. In this position, I was responsible for directing SECO’s engineering and  
14 operations departments. While serving as Director of Operations, I expanded SECO’s Load  
15 Management and Supervisory Control and Data Acquisition (“SCADA”) systems, which  
16 improved reliability and performance and reduced costs for the member-owners. As the  
17 Director of Operations, I also coordinated the design and construction of substations,  
18 completed RUS Long Range and Two-Year Work Plans, and supervised 55 employees. I  
19 remained the Director of Operations at SECO until August 1987 when I joined Flint EMC.  
20 Between August 1987 and January 2006, which is when I became Flint EMC’s Chief  
21 Operating Officer, I held multiple positions with increasing responsibility at Flint EMC.

## PUBLIC DISCLOSURE DOCUMENT

1           My first position at Flint EMC was as the Section Manager of Engineering. In this  
2 position, my primary responsibility was managing Flint EMC's Staking Department,  
3 Metering and Communications Department, Equipment Maintenance Department, and  
4 Drafting Department. While acting as the Section Manager of Engineering, I completed a  
5 Two-Year Work Plan, a Long Range Plan, and Sectionalizing Studies. I also designed and  
6 built three distribution substations low-side facilities and was responsible for the system  
7 expansion capital budget for the years 1987-1990. I remained the Section Manager of  
8 Engineering until October 1990 when I was promoted to Manager of Engineering. In this  
9 role, my primary responsibilities included directing the cooperatives engineering activities,  
10 supervising the activities of 45 employees in various operations and engineering  
11 departments, performing engineering studies, and designing and constructing substation  
12 low-side facilities. While I was the Manager of Engineering, I also negotiated relocation  
13 contracts with companies regulated by the Public Service Commission, such as AT&T and  
14 Sprint, after the Federal Communications Commission auctioned 2GHz frequencies. While  
15 negotiating these relocation contracts, I had the opportunity to install a new digital  
16 microwave system needed to improve Flint EMC's communication network.

17           I remained Flint EMC's Manager of Engineering until June 1999 when I was  
18 promoted to Vice President of Engineering and Operations. In this role, my primary  
19 responsibilities included directing and managing Flint EMC's engineering and operations  
20 departments and supervising 102 employees in the Staking, Line Construction, Right-Of-  
21 Way, Equipment Maintenance, Metering and Communications, and Planning Departments.  
22 While serving as Vice President of Engineering and Operations, I improved system

## PUBLIC DISCLOSURE DOCUMENT

1 efficiency by expanding the SCADA System and the Load Management Systems,  
2 installing the Utility Analytics Institute Mapping System, the Two-Way Automatic  
3 Communication System, the Outage Management System, and the Dispersed Generation  
4 System. I remained Vice President of Engineering and Operations until January 2006 when  
5 I was appointed Chief Operating Officer of Flint EMC, which is the position I currently  
6 hold.

7 As the Chief Operating Officer of Flint EMC, I am involved, either directly or  
8 indirectly, in most aspects of Flint EMC's day-to-day business and operations, including  
9 its engineering operations. It is also my responsibility to ensure that Flint EMC's electrical  
10 transmission and distribution system is safely constructed and maintained. In carrying out  
11 this duty, employees under my direction have had to respond to many situations where a  
12 cable and/or telephone attachment has been made to a Flint EMC pole in a manner that  
13 causes damage to the pole, thereby increasing maintenance costs, and/or jeopardizes safety  
14 and reliability. I have also seen these improper attachments on poles owned by other  
15 Georgia EMCs.

16 **A. By Mr. Brown:**

17 My post-graduate employment includes over 30 years of experience with Georgia  
18 EMCs. After graduating from Southern Polytechnic State University, I joined Douglas  
19 County EMC, which is now known as Greystone Power, as a Planning Engineer. In this  
20 role, my primary responsibilities included assisting in a multi-year work plan study,  
21 assisting in the design of a distribution system, and acting as a liaison between the  
22 accounting and engineering departments. In addition, I was responsible for, among other

## PUBLIC DISCLOSURE DOCUMENT

1 things, designing the layout of installations for commercial and industrial member projects.  
2 I remained in this position until 1991 when I joined Hart EMC. Between 1991 and 2018,  
3 which is when I became Hart EMC's Chief Operating Officer, I held multiple positions  
4 with increasing responsibility at Hart EMC.

5 My first position at Hart EMC was as a Distribution Engineer. As a Distribution  
6 Engineer at Hart EMC, my primary responsibilities included: assisting the consulting  
7 engineer in work plan design, monitoring, implementing, and constructing system  
8 improvement projects, and staking and designing single and multi-phase lines for new  
9 member-owners. I also performed sectionalizing studies, reviewed equipment placement  
10 in order to minimize member-owner outages, and served as the safety coordinator until  
11 2000. I remained a Distribution Engineer until November 1998 when I was promoted to  
12 Manager of Engineering Services. As Hart EMC's Manager of Engineering Services, I was  
13 directly involved in many aspects of pole attachments. In fact, one of my primary  
14 responsibilities was anticipating, coordinating, planning, and designing pole attachments  
15 by third-party attachers. I remained the Manager of Engineering Services until 2002 when  
16 I was promoted to Vice President of Engineering and Operations. As the Vice President of  
17 Engineering and Operations, my responsibilities included supervising line crews, right of  
18 way crews, the maintenance shop, and the district office. In addition, I was involved in  
19 certain aspects of joint-use agreements. In 2007, while acting as the Vice President of  
20 Engineering and Operations, I also became responsible for many aspects of Hart EMC's  
21 human resources and accounting departments. This responsibility included, among other  
22 things, handling RUS and CFC loan issues, budgeting, and other financial matters related

## PUBLIC DISCLOSURE DOCUMENT

1 to the EMC. I remained the Vice President of Engineering and Operations until November  
2 2018 when I was appointed Chief Operating Officer of Hart EMC, which is the position I  
3 currently hold.

4 As the Chief Operating Officer of Hart EMC, I am involved, either directly or  
5 indirectly, in almost all aspects of Hart EMC's day-to-day business and operations,  
6 including its engineering operations.

7 **A. By Mr. Arant:**

8 My post-graduate employment includes over 25 years in the energy distribution  
9 industry and over 15 years working directly with Central Georgia EMC. After earning my  
10 Master of Science degree in Electrical Engineering from Georgia Tech, I started working  
11 for Kimberly Clark Corporation in Roswell, Georgia as an Engineer. In this role, I  
12 performed comprehensive project engineering for industrial power and control systems and  
13 designed controls for utility areas, air systems, and waste reclamation systems. I worked as  
14 an Engineer at Kimberly Clark Corporation until February 1996 when I joined Duke  
15 Engineering & Services in Charlotte, North Carolina. I worked at Duke Engineering &  
16 Services from February 1996 to February 1999 as an Associate Engineer and as a Power  
17 System Engineer. While working at Duke Engineering & Services, I designed over-current  
18 and over-voltage protection systems for transmission, distribution, and industrial power  
19 system networks.

20 In February 1999, I joined Georgia Transmission Corporation ("GTC") in Tucker,  
21 Georgia as a Transmission Services Engineer. GTC is a cooperative that is responsible for  
22 planning, building, and maintaining high-voltage transmission lines and substations that

## PUBLIC DISCLOSURE DOCUMENT

1 carry power from generation facilities to the 38 EMCs that are before this Commission. In  
2 this position, I served as the primary technical liaison between GTC and its member  
3 systems, which are Georgia's electric cooperatives. I was also responsible for planning,  
4 developing, and initiating power transmission construction projects. For these projects to  
5 be successful, I had to anticipate and detect system problems, identify and compare  
6 potential solutions, and provide a final justification for the selected system improvement  
7 method. I remained a Transmission Services Engineer until May 2000 when I was  
8 promoted to Project Manager at GTC. As a Project Manager at GTC, my primary  
9 responsibility was to manage all aspects of a power transmission facilities design and  
10 construction team. I remained a Project Manager at GTC until June 2003 when I joined  
11 Beckett & LaRue, Inc. ("B&L") as the Manager of Electrical Services. In this position, I  
12 conducted various engineering studies, including power system fault studies, over-current  
13 coordination studies, and over-voltage protection studies. I also designed protective relay  
14 system settings, coordinated overvoltage protection, designed substations, and managed  
15 the modeling and planning of power systems. I worked as the Manager of Electrical  
16 Services at B&L until July 2004 when I joined Central Georgia EMC. Between July 2004  
17 and February 2017, which is when I became Central Georgia EMC's Senior Vice President  
18 of Engineering & Energy Supply, I held multiple positions with increasing responsibility  
19 at Central Georgia EMC.

20 My first role with Central Georgia EMC was as the Manager of Engineering. In this  
21 position, my primary responsibilities included distribution system planning and field  
22 engineering management. I remained in this position until January 2005 when I was

## PUBLIC DISCLOSURE DOCUMENT

1 promoted to Vice President of Engineering Services. As the Vice President of Engineering  
2 Services, my primary responsibilities included those listed above with the addition of  
3 system operations and key account management. I remained the Vice President of  
4 Engineering Services until February 2017 when I was promoted to Senior Vice President  
5 of Engineering & Energy Supply, which is the position I currently hold.

6 As Central Georgia EMC's Senior Vice President of Engineering & Energy Supply,  
7 I am responsible for multiple departments and business processes, including coordinating  
8 Central Georgia EMC's business with Wholesale Power Supply Entities, managing Central  
9 Georgia EMC's engineering systems, overseeing rate design and cost of service studies,  
10 preparing capital budgets, and leading formal process mapping and improvement  
11 initiatives. In addition, I am involved in managing the contracts related to joint use and  
12 pole attachments.

13 **Q. Please describe any committees you have served on and any professional**  
14 **organizations/associations you are affiliated with that are relevant to this proceeding.**

15 **A. By Mr. Smith:** Between January 2001 and January 2004, I served on a committee that  
16 represented Georgia's electrical membership corporations in pole attachment contract  
17 negotiations with telephone companies. During this time, I was also a member of the  
18 Georgia EMC Engineer's Association and made presentations on the Association's behalf  
19 related to the economics and engineering of joint-use agreements and pole attachments and  
20 the impact such agreements and attachments have on system reliability, safety, and utility  
21 plant cost. Between January 2004 and January 2020, I served on various committees that  
22 represented the interests of Georgia's electric membership corporations in negotiating

## PUBLIC DISCLOSURE DOCUMENT

1 joint-use and pole attachment operational contracts. Currently, I am a member of the  
2 Institute of Electrical and Electronic Engineers and the Power Engineering Society.

3 **A.** By Mr. Diamond: Several years ago I was the President of the Georgia Engineering  
4 Association. I have also served on the National Rural Electric Cooperative Association  
5 Transmission and Distribution Engineering Committee (“NRECA T&D Committee”).  
6 While on the NRECA T&D Committee, I assisted the Rural Utilities Service (“RUS”) in  
7 developing, analyzing, and updating federal technical standards, guidelines and  
8 specifications. As a member of the NRECA T&D Committee, I was also responsible for  
9 monitoring and reviewing other engineering and operational standards, code changes, and  
10 design changes to ensure that EMCs remained competitive in today’s changing  
11 environment. I also served on the Overhead Lines Subcommittee. As a member of the  
12 Overhead Lines Subcommittee, I reviewed RUS construction specifications and provided  
13 guidance on clearance standards between cable facilities and power distribution lines.  
14 Currently, I am a member of the Institute of Electrical and Electronic Engineers.

15 **A.** By Mr. Brown: In 2013, I was the President of the Georgia EMC Engineering Association.  
16 Currently, I am a member of the Institute of Electrical and Electronic Engineers, the Power  
17 Engineering Society, and the Georgia Engineering Association.

18 **A.** By Mr. Arant: In 2009, I was the President of the Georgia EMC Engineering Association.  
19 Currently, I am a member of the Institute of Electrical and Electronic Engineers and the  
20 Power Engineering Society.

**PUBLIC DISCLOSURE DOCUMENT**

1 **Q. Are you sponsoring any exhibits in connection with your testimony?**

2 **A. By the Panel:** Yes. The exhibits we are sponsoring are attached hereto and labeled as  
3 follows: **GEMC Ex. 55 (Panel-1) – GEMC Ex. 130 (Panel-76).**

4 **Q. Were the attached exhibits prepared by you or under your direct supervision?**

5 **A. By the Panel:** Yes. With the exception of one exhibit, all the exhibits we are sponsoring  
6 contain photographs that one of us individually took and are a true and accurate  
7 representation of the scene depicted on the identified date. The one other exhibit that we  
8 will reference contains several photographs taken by employees of other Georgia EMCs.  
9 The photographs contained in this exhibit are accompanied by authenticating affidavits.

10 **Q. Please summarize your testimony?**

11 **A. By the Panel:** Our testimony will show how cable and telephone attachers frequently  
12 violate the National Electrical Safety Code, their pole attachment agreements (in the case  
13 of cable/non-ILEC attachers), their joint-use agreements (in the case of telephone/ILEC  
14 attachers), and other applicable design standards when attaching to poles owned by  
15 Georgia's 38 electric cooperatives subject to the Georgia Broadband Opportunity Act. We  
16 will introduce pictures taken across the state of Georgia that illustrate these violations and  
17 discuss the safety, reliability, and economic impact these violations have on the Georgia  
18 EMCs and its member-owners. It is our intent to highlight to the Commission that but for  
19 the presence of cable and telephone attachments on poles owned by the Georgia EMCs  
20 certain safety and reliability issues would not exist and the cooperative and its member-  
21 owners would not incur certain additional costs.

## PUBLIC DISCLOSURE DOCUMENT

### 1 **II. RULES GOVERNING POLE ATTACHMENTS**

#### 2 **Q. What is the National Electrical Safety Code?**

3 **A. By the Panel:** The National Electrical Safety Code (“NESC”) establishes safety standards,  
4 design standards, and work rules for electric and communications companies. These  
5 standards include rules that specifically apply to pole attachments. Specifically, the NESC  
6 has requirements for the vertical clearance over the ground, horizontal clearance from  
7 buildings, separation between electric and other communications lines, strength  
8 requirements, grounding requirements, and other requirements for the safeguarding of  
9 persons and facilities (including safe work practices). These standards are all designed to  
10 ensure that third-party pole attachments do not interfere with the safe and reliable operation  
11 of a utility’s distribution plant and to safeguard the public as well as employees and  
12 contractors of both electric and communications companies.

#### 13 **Q. How does the National Electrical Safety Code apply to pole attachments made on** 14 **poles owned by the Georgia EMCs?**

15 **A. By the Panel:** The NESC establishes safety and design standards for the electric and  
16 communications industry. This code is used in Georgia and across the country as a standard  
17 of care. The NESC is also almost always included in pole attachment agreements and the  
18 requirement to comply with the NESC is part of the CTAG agreement utilized by many of  
19 the Georgia EMCs and cable companies in Georgia. In addition, the Department of  
20 Agriculture, through the Rural Utilities Service (“RUS”) requires all EMCs that are RUS  
21 borrowers, which includes the majority of the Georgia EMCs, to build and maintain their  
22 lines in accordance with the NESC.

**PUBLIC DISCLOSURE DOCUMENT**

1 **Q. Please describe the National Electrical Safety Code rules that are most relevant to**  
2 **your testimony?**

3 **A. By the Panel:** The following rules are most relevant to our testimony today:

4 NESC Rule 232: Rule 232 establishes the minimum vertical clearance to the ground  
5 for wires, conductors, and cables. The purpose of this rule is to accommodate safe passage  
6 of people, vehicles, and/or traffic beneath the lines.

7 NESC Rules 235 and 238: Rules 235 and 238 establish minimum separations that  
8 are required between different utility functions for wires, conductors, and cables on the  
9 same supporting structure, including separation requirements between communication  
10 facilities and power facilities on the same structure. The purpose of these rules is to prevent  
11 communications cables from contacting energized electrical lines and to ensure  
12 communication workers have a safe area to work in and can maintain the work rule  
13 clearances required by Part 4 of the NESC and OSHA.

14 NESC Rule 236: Rule 236 establishes the requirements associated with providing  
15 safe climbing space on structures that workers ascend, including poles or portions of poles  
16 that are sometimes expected to be climbed.

17 NESC Rules 264 and 279: Rules 264 and 279 establish the requirements for guys,  
18 anchors, and braces, all of which are used to support the pole, which is under tension from  
19 the attached cables. The application of these rules is dictated by Sections 25 and 26 of the  
20 NESC.

21 NESC Sections 25 and 26: Sections 25 and 26 specify general loading requirements  
22 that are specific to the location of the facilities and the appropriate strength factors that

**PUBLIC DISCLOSURE DOCUMENT**

1 must be applied. These sections of the NESC provide the speed of wind, amount of ice,  
2 and other safety factors that must be applied when analyzing the strength of a new or  
3 modified pole-line and when determining whether a new or modified structure and its  
4 component parts are adequate under NESC's standards for strength and safety.

5 **Q. Are there other standards that govern pole attachments to Georgia EMC Poles?**

6 **A. By the Panel:** Yes. It is expected that third-party attachers will adhere to the good  
7 workmanlike standards that are practiced in the electric and communications industry.  
8 Moreover, third-party attachers are expected to adhere to sound engineering principles  
9 when making attachments.

10 **A. By Mr. Smith:** In addition to the standards mentioned above, under the model CTAG  
11 agreement used by most Georgia EMCs, cable and telephone attachers are required to  
12 install their attachments at least 40 inches below the EMCs bottom conductor, even if the  
13 bottom conductor is an effectively grounded neutral. This is slightly different than what  
14 the NESC requires. The NESC requires that communications attachments be at least 40  
15 inches below the power company's bottom conductor if that conductor is operating up to  
16 8,700 volts and 43 inches if the conductor is operating at 14,000 volts. If, however, the  
17 conductor is an effectively grounded neutral, the NESC allows communications  
18 attachments to be as close as 30 inches to the bottom conductor.

19 The reason most Georgia EMCs use the modified rule and have included it in the  
20 model CTAG agreement is because history has shown that communications workers are  
21 not trained in power systems. Thus, there is no guarantee that a communications worker  
22 will be able to correctly determine whether the bottom conductor is grounded. Requiring

## PUBLIC DISCLOSURE DOCUMENT

1 40 inches regardless of whether the bottom conductor is an effectively grounded neutral,  
2 reduces the potential for accidents caused by cable and telephone attachers misidentifying  
3 the bottom conductor.

4 **Q. What evidence does GEMC have showing cable and telephone attachers are violating**  
5 **the rules governing pole attachments, including the rules contained in the NESC?**

6 **A. By Panel:** This panel has a combined 114 years of experience in the field, observing and  
7 managing problem attachments for all those years. For this proceeding, each member of  
8 this Panel visited and walked the lines of their own EMC and at least three other Georgia  
9 EMCs to view the state of cable and telephone attachments on these systems. Each member  
10 took pictures and these pictures are a sampling of the cable and telephone attachment  
11 violations that currently exist. The pictures are representative of systemic practices by cable  
12 and telephone companies throughout Georgia EMCs' systems.

13 Mr. Smith, of Sumter EMC, visited Canoochee Electric Membership Corporation  
14 ("Canoochee EMC"), Colquitt Electric Membership Corporation ("Colquitt EMC"),  
15 Middle Georgia Electric Membership Corporation ("Middle Georgia EMC"), and Mitchell  
16 Electric Membership Corporation ("Mitchell EMC").

17 Mr. Diamond, of Flint EMC, visited Jackson Electric Membership Corporation  
18 ("Jackson EMC"), Tri-County Electric Membership Corporation ("Tri-County EMC"),  
19 and Walton Electric Membership Corporation ("Walton EMC").

20 Mr. Brown, of Hart EMC, visited Habersham Electric Membership Corporation  
21 ("Habersham EMC"), Jefferson Electric Membership Corporation ("Jefferson EMC"),

**PUBLIC DISCLOSURE DOCUMENT**

1 Planters Electric Membership Corporation (“Planters EMC”), and Rayle Electric  
2 Membership Corporation (“Rayle EMC”).

3 Mr. Arant, of Central Georgia EMC, visited Carroll Electric Membership  
4 Corporation (“Carroll EMC”), Coweta-Fayette Electric Membership Corporation  
5 (“Coweta-Fayette EMC”), Greystone Power Corporation (“Greystone Power”), and  
6 Snapping Shoals Electric Membership Corporation (“Snapping Shoals EMC”).

7 **III. FAILURE TO COMPLY WITH VERTICAL CLEARANCE REQUIREMENTS**

8 **Q. What is a vertical clearance violation?**

9 **A. By the Panel:** A vertical clearance violation occurs when the space between an attachment  
10 and the ground does not comply with the minimum vertical clearance requirements  
11 established in NESC Rule 232.

12 **Q. What is the purpose of NESC’s vertical clearance requirements?**

13 **A. By the Panel:** The purpose of NESC’s vertical clearance requirements is to protect the  
14 public, utility workers, and communications workers from serious injury or death as a result  
15 of making direct contact with a low-hanging cable. By adhering to NESC’s vertical  
16 clearance standards, the risk of coming into contact with a low-hanging cable is greatly  
17 reduced.

18 **Q. Please describe some of the photographs showing vertical clearance violations.**

19 **A. By Mr. Smith:** I am going to describe **GEMC Ex. 55 (Panel-1), GEMC Ex. 56 (Panel-2),**  
20 **GEMC Ex. 57 (Panel-3), GEMC Ex. 58 (Panel-4), GEMC Ex. 59 (Panel-5), GEMC**  
21 **Ex. 60 (Panel-6), GEMC Ex. 61 (Panel-7), GEMC Ex. 62 (Panel-8), and GEMC Ex. 63**  
22 **(Panel-9),** which are photographs that I personally took and are true and accurate

## PUBLIC DISCLOSURE DOCUMENT

1 representations of the scene depicted, and which all show vertical clearance violations  
2 created by cable and telephone company attachments to EMC owned poles.

3 **GEMC Ex. 55 (Panel-1)** contains four pictures of Sumter EMC's system that were  
4 taken on October 14, 2020. These pictures were taken on U.S. 19 at Eagle Pond Road. The  
5 attachments at issue, which were made without a permit request or permission from Sumter  
6 EMC, belong to AT&T. AT&T attached to multiple Sumter EMC poles that span across  
7 U.S. 19 and, as pictures "A" and "B" of **GEMC Ex. 55 (Panel-1)** show, AT&T's  
8 attachments run over not only a highway, but also over a major railroad track that has trains  
9 traveling in excess of 50 mph. Under the NESC, AT&T's attachment should have, at  
10 minimum, a vertical clearance of 23.5 feet. AT&T's attachment has a vertical clearance of  
11 18 feet 7 inches, which is almost 5 feet below the minimum railroad clearance requirement.  
12 In this state, AT&T's low-hanging cable creates a major safety hazard for railroad workers,  
13 line technicians, and motorists traveling on the U.S. 19. Moreover, the Sumter EMC poles  
14 AT&T attached to without permission were not designed or constructed for joint-use with  
15 AT&T. Put differently, these Sumter EMC poles cannot provide AT&T's attachments with  
16 the strength and support the attachments need to comply with NESC's clearance  
17 requirements. The anchors AT&T installed also are not sufficient to support the tension  
18 AT&T's attachments create. As a result, and as shown in pictures "C" and "D" of **GEMC**  
19 **Ex. 55 (Panel-1)**, two Sumter EMC poles have already bowed at AT&T's attachment  
20 points. By compromising the strength of these poles, AT&T's attachments have also  
21 created the risk that these two Sumter EMC poles will fail or have to be replaced  
22 prematurely.

**PUBLIC DISCLOSURE DOCUMENT**

1           **GEMC Ex. 56 (Panel-2)** contains four pictures of Sumter EMC’s system that were  
2 taken on October 14, 2020. These pictures were taken at 1551 Wadsworth Drive, Albany,  
3 Georgia 31721, which is located in a residential subdivision. The attachment at issue  
4 belongs to Windstream Telephone. Under the NESC, Windstream Telephone’s cable  
5 should have a vertical clearance of at least 15.5 feet. Here, however, Windstream  
6 Telephone’s cable has vertical clearance of only 3 feet and its support messenger has a  
7 vertical clearance of only 8 feet 3 inches. This is not only a violation of NESC’s standards,  
8 but is also a safety hazard. In addition, and as shown in picture “B” of **GEMC Ex. 56**  
9 **(Panel-2)**, Windstream Telephone’s lashing wire, which was used to attach the  
10 communications cable to a steel support messenger, is unraveling and hanging down from  
11 the cable. This, too, creates a safety hazard and violates NESC’s rules regarding adequate  
12 clearance of the lashing wire itself above ground. The unrestrained movement of the  
13 lashing could also result in an unintended contact between the lashing and nearby power  
14 conductors.

15           **GEMC Ex. 57 (Panel-3)** is a picture of Colquitt EMC’s system and was taken on  
16 September 28, 2020. This picture was taken on Highway 82, east of Ty Ty Omega Road.  
17 The cable attachment at issue belongs to Mediacom Communications Corporation  
18 (“Mediacom”) and is running over a peanut field. NESC Table 232-1, footnote 26, states  
19 the following: “When designing a line to accommodate oversized vehicles, [the vertical  
20 clearance values] shall be increased by the difference between the known height of the  
21 oversized vehicle and 14 ft.” Typical equipment used for the harvesting of peanuts has a  
22 height of 16 feet 8 inches. As a result, a cable attachment spanning over a peanut field

**PUBLIC DISCLOSURE DOCUMENT**

1 should have a vertical clearance of at least 18 feet 2 inches, which is 2 feet 8 inches above  
2 the standard ground clearance of 15.5 feet. The Mediacom cable attachment shown in this  
3 picture does not comply with this requirement. In fact, the Mediacom cable attachment has  
4 a vertical clearance of only 16 feet 1 inch.

5 **GEMC Ex. 58 (Panel-4)** is a picture of Colquitt EMC’s system and was taken on  
6 September 28, 2020. This picture was taken on Parrish Road, approximately 0.15 miles  
7 north of Highway 82. The cable attachment at issue belongs to Mediacom and is running  
8 over the entrance to a cotton field. NESC Table 232-1, footnote 26, states the following:  
9 “When designing a line to accommodate oversized vehicles, [the vertical clearance values]  
10 shall be increased by the difference between the known height of the oversized vehicle and  
11 14 ft.” The height of a common cotton picker is 17 feet 6 inches. As a result, a cable  
12 attachment spanning over a cotton field should have a minimum vertical clearance of at  
13 least 19 feet, which is 3 feet 6 inches above the standard ground clearance of 15.5 feet.  
14 Here, Mediacom’s attachment has a vertical clearance of only 18 feet. This is improper  
15 under the NESC. In addition, Mediacom made this attachment without first submitting an  
16 application to attach to this Colquitt EMC pole. As a result, Colquitt EMC could not review  
17 the attachment plans before construction and inform Mediacom that its attachment needed  
18 to have a vertical clearance higher than the standard ground clearance.

19 **GEMC Ex. 59 (Panel-5)** is another picture of Colquitt EMC’s system, which was  
20 taken on September 28, 2020. This picture was taken on Highway 82 at Spring Hill Drive.  
21 The cable attachment at issue, again, belongs to Mediacom. Mediacom’s attachment is  
22 running along a highway. Pursuant to NESC Rule 232, Mediacom’s attachment should

**PUBLIC DISCLOSURE DOCUMENT**

1 have a vertical clearance of at least 15.5 feet. Here, however, Mediacom’s attachment has  
2 a vertical ground clearance of less than 6 feet. Mediacom’s attachment is also almost  
3 completely covered in vegetation, which is weighing down the cable and creating excessive  
4 tension on Colquitt EMC’s pole. The presence of this vegetation also violates NESC Rule  
5 218, which states that vegetation management should be performed around  
6 communications lines. Moreover, the failure to remove vegetation may result in structural  
7 loading being applied to adjacent structures during storm loading from ice and/or wind on  
8 the trees and brush.

9 **GEMC Ex. 60 (Panel-6)** is a picture of Mitchell EMC’s system and was taken on  
10 September 29, 2020. This picture was taken on South County Line Road, approximately  
11 0.5 miles south of Hines Road. The cable attachments at issue belong to Mediacom and  
12 AT&T. The standard ground clearance required under NESC Rule 232 is 15.5 feet. Here,  
13 the Mediacom cable attachment has a ground clearance of only 10 feet 6 inches and the  
14 AT&T cable attachment has a ground clearance of only 9 feet 6 inches. Thus, both AT&T  
15 and Mediacom’s attachments violate the NESC and are creating safety hazards.

16 **GEMC Ex. 61 (Panel-7)** is another picture of Mitchell EMC’s system and was  
17 taken on September 29, 2020. This picture was taken at 2515 Tony Lynne Lane. The cable  
18 attachment at issue belongs to Mediacom. Mediacom’s attachment is hanging over a paved  
19 roadway. Pursuant to NESC 232, the Mediacom attachment should have a vertical  
20 clearance of at least 15.5 feet. However, here, the Mediacom cable has a vertical clearance  
21 of only 8 feet 10 inches. Given the location of this cable attachment, the low vertical  
22 clearance creates a hazard for vehicles traveling along this road.

**PUBLIC DISCLOSURE DOCUMENT**

1           **GEMC Ex. 62 (Panel-8)** is a picture of Sumter EMC’s system and was taken on  
2           September 28, 2020. This picture was taken on Northampton Road, just north of Forrester  
3           Parkway. The cable attachment at issue belongs to Mediacom and is hanging over a  
4           roadway. Accordingly, NESC 232 requires that this attachment have a vertical clearance  
5           of at least 15.5 feet. However, here, Mediacom’s attachment has a vertical clearance of  
6           only 12 feet 5 inches. Given the location of this cable attachment, the low vertical clearance  
7           creates a hazard for vehicles, especially large trucks, traveling along this road.

8           **GEMC Ex. 63 (Panel-9)** is another picture of Sumter EMC’s system. This picture  
9           was taken on September 28, 2020 on Leesburg Bypass, just north of Linden Road. The  
10          cable attachment at issue belongs to Mediacom. Here, Mediacom’s attachment is hanging  
11          over a body of water. Pursuant to NESC Rule 232, cable attachments over water must have  
12          a vertical clearance of at least 14 feet. Here, however, Mediacom’s attachment is less than  
13          7 feet above the water.

14    A.    By Mr. Diamond: I am going to describe **GEMC Ex. 64 (Panel-10)**, **GEMC Ex. 65**  
15          **(Panel-11)**, **GEMC Ex. 66 (Panel-12)**, and **GEMC Ex. 67 (Panel-13)**, which are  
16          photographs that I personally took and are true and accurate representations of the scene  
17          depicted, and which all show vertical clearance violations created by the attachments of  
18          telephone and cable companies.

19          **GEMC Ex. 64 (Panel-10)** is a picture of Flint EMC’s system and was taken on  
20          September 29, 2020. This picture was taken at 202 Gilchrist Drive, Warner Robins,  
21          Georgia and involves Flint EMC Pole # 027201. The cable attachment shown in this picture  
22          belongs to Cox Communications (“Cox”) and is located over a residential yard. Pursuant

## PUBLIC DISCLOSURE DOCUMENT

1 to NESC Rule 232, the cable attachment shown in this picture should have a vertical  
2 clearance of 9.5 feet. The Cox cable attachment, however, violates this rule. In fact, the  
3 Cox cable attachment has a vertical clearance of only 4 feet 5 inches. The cable being this  
4 low means there is a cable-created safety hazard.

5 **GEMC Ex. 65 (Panel-11)** is a picture of Tri-County EMC's system and was taken  
6 on September 24, 2020. This picture was taken at 101 Pinewood Drive, Eatonton, Georgia  
7 and involves Tri-County EMC Pole # 5HA-59. The cable shown in this picture belongs to  
8 Charter Communications, Inc. ("Charter") and is located over a residential driveway.  
9 Pursuant to NESC Rule 232, the cable attachment shown in this picture should have a  
10 vertical clearance of 15.5 feet. Here, the Charter cable attachment does not meet the NESC  
11 vertical clearance requirement. In fact, the Charter attachment has a vertical clearance of  
12 only 5 feet 9 inches. The cable having such a low vertical clearance means a safety hazard  
13 has been created.

14 **GEMC Ex. 66 (Panel-12)** is a picture of Tri-County EMC's system and was taken  
15 on September 24, 2020. This picture was taken at 105 Bear Creek Road West, Eatonton,  
16 Georgia. The cable shown in this picture belongs to Charter and is located near a residential  
17 driveway. Pursuant to NESC Rule 232, the cable attachment shown in this picture should  
18 have a vertical clearance of 9.5 feet. Here, however, the Charter cable attachment violates  
19 this rule. In fact, the Charter attachment has a vertical clearance of only 6 feet 6 inches,  
20 which creates a safety hazard. Moreover, the Charter attachment spans through tree  
21 branches, which is also improper and shows a lack of maintenance.

**PUBLIC DISCLOSURE DOCUMENT**

1           **GEMC Ex. 67 (Panel-13)** is a picture of Jackson EMC’s system and was taken on  
2           September 22, 2020. The picture was taken at 492 Russell Road, Lawrenceville, Georgia,  
3           30043. The cable attachment shown in this picture belongs to AT&T and is hanging over  
4           a residential yard. Pursuant to NESC Rule 232, the cable attachment shown in this picture  
5           should have a vertical clearance of 9.5 feet. The AT&T attachment violates this rule and  
6           has a vertical clearance below what is required by the NESC.

7   **A. By Mr. Brown:** I am going to describe **GEMC Ex. 68 (Panel-14)**, **GEMC Ex. 69 (Panel-**  
8           **15)**, **GEMC Ex. 70 (Panel-16)**, and **GEMC Ex. 71 (Panel-17)**, which are photographs  
9           that I personally took and are true and accurate representations of the scene depicted, and  
10           which all show vertical clearance violations created by telephone and cable company  
11           attachments on EMC owned poles.

12           **GEMC Ex. 68 (Panel-14)** is a picture of Habersham EMC’s system and was taken  
13           on September 21, 2020. This picture was taken on State Route 197. The cable attachment  
14           at issue belongs to TruVista Communications (“TruVista”). Pursuant to NESC Rule 232,  
15           TruVista’s attachment should have a vertical clearance of at least 15.5 feet. The TruVista  
16           cable attachment, however, violates this rule. In fact, the TruVista cable attachment has a  
17           vertical clearance of not more than 9 feet.

18           **GEMC Ex. 69 (Panel-15)** is a picture of Jefferson EMC’s system and was taken  
19           on September 22, 2020 at 3911 Union Grove Circle. The attachment at issue belongs to  
20           Comcast. Pursuant to NESC Rule 232, Comcast’s attachments should have a vertical  
21           clearance of at least 15.5 feet. However, as I am sure the Commission can see, the Comcast

## PUBLIC DISCLOSURE DOCUMENT

1 attachment does not have the required vertical clearance. Rather, the Comcast attachment  
2 is almost on the ground.

3 **GEMC Ex. 70 (Panel-16)** is another picture of Jefferson EMC's system and was  
4 taken on September 22, 2020 at 7480 Lakeside Drive, which is a residential driveway. The  
5 cable attachment at issue belongs to AT&T. Pursuant to NESC Rule 232, the cable  
6 attachment shown in this picture should have a vertical clearance of at least 15.5 feet. The  
7 AT&T attachment, however, violates this rule. In fact, the AT&T attachment has a vertical  
8 clearance of not more than 9 feet.

9 **GEMC Ex. 71 (Panel-17)** is a picture of Planters EMC's system and was taken on  
10 September 23, 2020 at 105 Live Oak Road, which is a residential area. The cable  
11 attachment at issue belongs to Comcast. Pursuant to NESC Rule 232, the Comcast  
12 attachment, which is hanging over a residential driveway, should have a vertical clearance  
13 of at least 15.5 feet. The Comcast attachment, however, does not comply with this  
14 requirement. In fact, the Comcast attachment has a vertical clearance of only 10 feet 9.5  
15 inches, which creates a safety hazard.

16 **A. By Mr. Arant:** I will be describing **GEMC Ex. 72 (Panel-18)**, which contains photographs  
17 that I personally took and are a true and accurate representations of the scene depicted, and  
18 which show a vertical clearance violation.

19 **GEMC Ex. 72 (Panel-18)** contains two pictures of Coweta-Fayette EMC's system  
20 that were taken on September 23, 2020. Both pictures were taken on Highway 74 at  
21 Thompson Road, Tyrone, Georgia. The attachments at issue belong to AT&T and Comcast.  
22 As the picture labeled "A" shows, the AT&T and Comcast attachments are running across

## PUBLIC DISCLOSURE DOCUMENT

1 a highway. Pursuant to NESC Rule 232, the attachments shown in these pictures should  
2 have a vertical clearance of at least 15.5 feet. The purpose of this requirement is to ensure  
3 that vehicles traveling along this highway do not make contact with the communications  
4 attachments. Here, AT&T's cable did not comply with this requirement and, as a result, a  
5 vehicle made contact with AT&T's low-hanging cable, which caused Coweta-Fayette  
6 EMC's pole to break. Coweta-Fayette EMC's broken pole is shown next to the new pole  
7 in the picture labeled "B". What I am sure the Commission has already noticed, is that the  
8 old, broken pole still has attachments on it. Those attachments belong to AT&T and  
9 Comcast and should have already been transferred. Because the old pole is broken, AT&T  
10 and Comcast's refusal to transfer to the new pole creates a safety hazard for the public. The  
11 presence of a redundant pole also hinders the ability of persons working on the new pole.

12 **Q. Are the photographs each of you just described the only vertical clearance violations**  
13 **you found on the EMC systems you visited?**

14 **A. By the Panel:** No. Additional photographs showing, among other things, cable and  
15 telephone attachments that violate NESC's vertical clearance requirements on the systems  
16 of the Georgia EMCs visited by a member of this panel are attached to this testimony.

17 Additional photographs showing vertical clearance violations on the systems of the  
18 Georgia EMCs visited by Mr. Smith are contained in **GEMC Ex. 127 (Panel-73)**. The  
19 photographs contained in **GEMC Ex. 127 (Panel-73)** are photographs that Mr. Smith  
20 personally took and are true and accurate representations of the scene depicted. Additional  
21 photographs showing vertical clearance violations on the systems of the Georgia EMCs  
22 visited by Mr. Diamond are contained in **GEMC Ex. 128 (Panel-74)**. The photographs

**PUBLIC DISCLOSURE DOCUMENT**

1 contained in **GEMC Ex. 128 (Panel-74)** are photographs that Mr. Diamond personally  
2 took and are true and accurate representations of the scene depicted. Additional  
3 photographs showing vertical clearance violations on the systems of the Georgia EMCs  
4 visited by Mr. Brown are contained in **GEMC Ex. 129 (Panel-75)**. The photographs  
5 contained in **GEMC Ex. 129 (Panel-75)** are photographs that Mr. Brown personally took  
6 and are true and accurate representations of the scene depicted. Additional photographs  
7 showing vertical clearance violations on the systems of the Georgia EMCs visited by Mr.  
8 Arant are contained in **GEMC Ex. 130 (Panel-76)**. The photographs contained in **GEMC**  
9 **Ex. 130 (Panel-76)** are photographs that Mr. Arant personally took and are true and  
10 accurate representations of the scene depicted.

11 Each panel member has also provided the following information for each  
12 photograph contained in their exhibit: the image name, the name of the photographer, the  
13 date the picture was taken, the location where the picture was taken, the name of the  
14 attaching party, and the violation type. A brief description of the specific violation  
15 occurring in each photograph is also provided. The Panel created these table of contents  
16 for **GEMC Ex. 127 (Panel-73)**, **GEMC Ex. 128 (Panel-74)**, **GEMC Ex. 129 (Panel-75)**,  
17 and **GEMC Ex. 130 (Panel-76)** to aid the Commission’s review of the photographs.

18 **Q. Do attachments that violate the vertical clearance requirements impose burdens on**  
19 **Georgia EMCs that would not otherwise exist?**

20 **A. By the Panel: Yes.**

21 **Safety Issues:** Low hanging communications conductors create numerous safety issues  
22 that would not otherwise exist. By way of example:

**PUBLIC DISCLOSURE DOCUMENT**

1 (1) When a low hanging communication cable is directly contacted by persons  
2 who are walking, running, biking, or riding on open modes of  
3 transportation, such as cycles, boats, tractors, or horses, personal injury can  
4 result.

5 (2) When a low hanging communication cable is contacted by trucks, trains, or  
6 other equipment, the contact can cause personal injury, damage or break the  
7 pole, and/or pull the power lines down. Downed power lines create a fire  
8 hazard and a risk of electrocution.

9 (3) When a communications cable does not meet the required minimum vertical  
10 clearance communications workers that are performing maintenance or  
11 other operational activities in the vicinity of these low-hanging cables are  
12 more likely to make direct contact with the communications cable. This can  
13 result in physical injury.

14 **Reliability Issues:** When communications attachments are not in compliance with  
15 NESC’s vertical clearance requirements there is an increased chance of system outages.  
16 Often times, these outages are caused by a vehicle coming in contact with one of the low-  
17 hanging communications attachments.

18 **Increased Costs:** When attachments have vertical clearances that are less than the  
19 minimums specified in the NESC, Georgia EMCs incur a multitude of costs that would not  
20 otherwise exist. By way of example:

21 (1) When a low hanging cable is observed by the public, utility operations  
22 personnel must respond to the report, identify the owner of the low-hanging

## PUBLIC DISCLOSURE DOCUMENT

1 cable, and assess any potential hazards. In most instances, the electric utility  
2 is who the public calls when a low-hanging cable is observed.

3 (2) Where a pole is broken because a truck or other vehicle makes contact with  
4 a low-hanging communications cable, the cost of replacing the pole is borne  
5 by the pole owner, not the communications company. The pole owner will  
6 also have to replace any damaged pole-top equipment, including cross-arms  
7 and braces.

8 (3) Where an outage results because a truck or other vehicle makes contact with  
9 a low-hanging communications cable, the EMC must respond. This requires  
10 more personnel and hours of effort. And the costs associated with such a  
11 response, is all borne by the EMC, not the communications company.

12 (4) When someone from the public or a worker contacts a low-hanging wire  
13 and such contact causes property damage or personal injury, this can lead  
14 to expensive and timely litigation brought against the utility.

#### 15 **IV. FAILURE TO COMPLY WITH SEPARATION REQUIREMENTS**

##### 16 **Q. What is a separation violation?**

17 **A. By the Panel:** A separation violation occurs when the space between certain facilities do  
18 not meet the separation requirements contained in NESC Rules 235 and 238.

19 By way of example, a separation violation arises when: (1) there is not at least 40  
20 inches between the point of attachment of an electric utility's neutral line and the  
21 communications attachment (30 inches under an exception subject to certain grounding  
22 and bonding requirements) or in the case of a utility conductor energized at 14,400 volts,

**PUBLIC DISCLOSURE DOCUMENT**

1 43 inches; or, (2) there is not at least 12 inches between the point of attachment of the cable  
2 of one communication utility and the point of attachment of the cable of another  
3 communication (with a minimum of 4 inches of separation throughout the span).

4 **Q. What is the purpose of NESC's separation requirements?**

5 **A. By the Panel:** The separation requirements included in the NESC have evolved over many  
6 decades of practical experience and provide the minimally acceptable distance between  
7 facilities that are attached to pole (and in the spans between poles) to reduce the risk of  
8 accidental contact by workers, who are not power-system qualified, and the typical  
9 materials with which such workers use.

10 **Q. Please describe some of the photographs showing separation violations.**

11 **A. By Mr. Smith:** I am going to describe **GEMC Ex. 73 (Panel-19)**, **GEMC Ex. 74 (Panel-**  
12 **20)**, **GEMC Ex. 75 (Panel-21)**, **GEMC Ex. 76 (Panel-22)**, **GEMC Ex. 77 (Panel-23)**,  
13 **GEMC Ex. 78 (Panel-24)**, **GEMC Ex. 79 (Panel-25)**, **GEMC Ex. 80 (Panel-26)**, and  
14 **GEMC Ex. 81 (Panel-27)**, which are photographs that I personally took and are true and  
15 accurate representations of the scene depicted, and which all show communications  
16 attachments by cable and telephone companies that violate NESC separation rules.

17 **GEMC Ex. 73 (Panel-19)** is a picture of Canoochee EMC's system and was taken  
18 on October 2, 2020. This picture was taken on U.S. 280, approximately two miles east of  
19 Pembroke. The cable attachment at issue belongs to Comcast. Pursuant to NESC Rule 235,  
20 the Comcast attachment should be separated from Canoochee EMC's neutral by at least 30  
21 inches, and pursuant to the existing CTAG model agreement between Canoochee EMC  
22 and Comcast should be separated from Canoochee EMC's neutral by at least 40 inches.

**PUBLIC DISCLOSURE DOCUMENT**

1           However, here, the Comcast attachment is less than 24 inches from the Canoochee EMC's  
2           neutral. This is improper under both the NESC and the terms of the CTAG model  
3           agreement between Canoochee EMC and Comcast. Comcast's attachment being so close  
4           to Canoochee EMC's neutral also means that Comcast's attachment is encroaching into the  
5           Communication Worker Safety Zone ("CWSZ"), which creates a hazard of electrical shock  
6           for persons working on the poles and creates a hazard for energization of the cable  
7           company's equipment into homes and businesses.

8                     **GEMC Ex. 74 (Panel-20)** is another picture of Canoochee EMC's system and was  
9           taken on October 2, 2020. This picture was taken on Elm Tree Trailer Park Road. The cable  
10          attachment at issue belongs to Comcast. While NESC requires that Comcast's cable  
11          attachments be separated from Canoochee EMC's secondary service conductor by at least  
12          40 inches, the cable attachment shown in this picture is located at the same level as  
13          Canoochee EMC's secondary service conductor. Put differently, there is no vertical  
14          separation between the Comcast cable attachment and Canoochee EMC's secondary  
15          service conductor. As a result, the Comcast cable attachment is encroaching into the  
16          CWSZ, which creates safety hazards for persons working on the pole.

17                    **GEMC Ex. 75 (Panel-21)** is another picture of Canoochee EMC's system and was  
18          taken on October 2, 2020. The Canoochee EMC pole shown in this picture is located on  
19          Barnard Road, approximately one span northwest of Elm Tree Trailer Park Road. The cable  
20          attachment at issue belongs to Comcast. Under the NESC, the Comcast attachment, which  
21          is running across a roadway, should be separated from Canoochee EMC's facilities by at  
22          least 30 inches (with an exception under the NESC that allows separation of 75% of that

## PUBLIC DISCLOSURE DOCUMENT

1 value if the communications messenger is effectively bonded to the electrical system  
2 neutral). However, here, the Comcast cable is wrapped and zip tied around Canoochee  
3 EMC's guy wire. It is likely that the Comcast attacher wrapped and zip tied its cable around  
4 Canoochee EMC's guy wire to increase the vertical clearance between the roadway and  
5 Comcast's cable. Nevertheless, Comcast's attachment violates NESC's separation  
6 requirements. Moreover, in time, the plastic zip tie may degrade in the sunlight and fail.  
7 Were that to happen, the Comcast cable would fall from Canoochee EMC's guy wire,  
8 resulting in a cable-created safety hazard.

9 **GEMC Ex. 76 (Panel-22)** is a picture of Colquitt EMC's system and was taken on  
10 September 28, 2020. This picture was taken on Parrish Road, approximately 0.15 miles  
11 north of Highway 82. The cable attachment at issue belongs to Mediacom. NESC Rule 235  
12 requires that, at the pole, cable attachments be separated from facilities owned by the utility  
13 by at least 40 inches. Here, however, the Mediacom attachment is separated from Colquitt  
14 EMC's 480 volt service cables by less than 20 inches. As I previously described, this  
15 creates a safety hazard for workers because the attachment is encroaching into the CWSZ.

16 **GEMC Ex. 77 (Panel-23)** is a picture of Middle Georgia EMC's system and was  
17 taken on September 30, 2020 at 6602 Highway 41. The cable attachment at issue belongs  
18 to Mediacom. Pursuant to NESC Rule 238B, cable attachments should be separated from  
19 the electric utility's transformer by at least 30 inches. Moreover, NESC requires that cable  
20 attachments be separated from the secondary service wire by at least 40 inches. Here,  
21 however, Mediacom's attachment is just 12 inches from both Middle Georgia EMC's

**PUBLIC DISCLOSURE DOCUMENT**

1 transformer and Middle Georgia EMC’s secondary service wire. This is improper and  
2 creates a safety hazard.

3 **GEMC Ex. 78 (Panel-24)** is a picture of Mitchell EMC’s system and was taken on  
4 September 29, 2020. This picture was taken at 2505 Morehouse Lane. The cable  
5 attachment at issue belongs to Mediacom. Pursuant to NESC Rule 238B, Mediacom’s  
6 cable attachment should be located 40 inches below Mitchell EMC’s 25kV riser cable.  
7 Here, however, Mediacom’s cable attachment is located right next to Mitchell EMC’s  
8 25kV riser cable. Mediacom’s attachment being so close to Mitchell EMC’s 25kV riser  
9 cable means that Mediacom’s attachment is encroaching into the CWSZ, the safety space  
10 designed to keep communications workers from reaching into the area where Mitchell  
11 EMC’s energized cable lies and to keep Mediacom’s equipment from being energized. This  
12 is improper under the NESC and creates a safety hazard.

13 **GEMC Ex. 79 (Panel-25)** is a picture of Sumter EMC’s system and was taken on  
14 October 4, 2020. This picture was taken at the intersection of Upper River Road and  
15 Southland Drive. The cable attachment at issue belongs to Mediacom. Pursuant to NESC  
16 Rule 238B, Mediacom’s cable attachment should be located 40 inches below Sumter  
17 EMC’s 25kV cables. Here, however, Mediacom’s cable is attached just 12 inches below  
18 Sumter EMC’s 25kV cables. This is improper and is encroaching the CWSZ, which creates  
19 safety hazards for persons working on the pole and members of the public. In addition, it  
20 increases the risk that Mediacom’s equipment, which is serving homes and businesses, will  
21 become energized.

**PUBLIC DISCLOSURE DOCUMENT**

1           **GEMC Ex. 80 (Panel-26)** is a picture of Sumter EMC’s system and was taken on  
2           October 14, 2020. The Sumter EMC pole shown in this picture is located at 177  
3           Westminster Street, Albany, Georgia 31721. The attachment at issue belongs to  
4           Windstream Telephone. Under the NESC, Windstream Telephone’s attachment should not  
5           come in contact with Sumter EMC’s facilities at the pole or anywhere in the span. The  
6           purpose of NESC’s separation rules is to protect persons working on the poles from  
7           electrical shock and prevent hazards created when communications attachments become  
8           energized. Here, Windstream Telephone has clearly violated NESC’s separation  
9           requirements. Windstream Telephone’s attachment is actually wrapped around Sumter  
10          EMC’s power line. This violates the NESC and exposes line technicians to safety hazards  
11          that do not need to exist.

12           **GEMC Ex. 81 (Panel-27)** consists of two pictures of Sumter EMC’s system that  
13          were taken on October 14, 2020. The Sumter EMC poles shown in these pictures are  
14          located at 776 Highway 19 South, Leesburg, Georgia 31763. The attachments at issue  
15          belong to AT&T and Mediacom. As shown in picture “A” of **GEMC Ex. 81 (Panel-27)**,  
16          AT&T and Mediacom’s attachments span across a highway. NESC Rule 235H requires  
17          that there be at least 4 inches between the cable of one communication utility and the cable  
18          of another communication utility, anywhere in the span. AT&T and Mediacom’s  
19          attachments do not comply with this rule. In fact, AT&T’s attachment crosses Mediacom’s  
20          attachment at the mid-span. And, as shown in picture “B” of **GEMC Ex. 81 (Panel-27)**,  
21          AT&T’s cable is actually rubbing against Mediacom’s cable where they crossover. This

## PUBLIC DISCLOSURE DOCUMENT

1 could ultimately lead to lash failure and AT&T and Mediacom's cables having a vertical  
2 clearance that does not meet NESC standards.

3 **A.** By Mr. Diamond: I am going to describe **GEMC Ex. 82 (Panel-28)**, **GEMC Ex. 83**  
4 **(Panel-29)**, **GEMC Ex. 84 (Panel-30)**, and **GEMC Ex. 85 (Panel-31)**, which are  
5 photographs that I personally took and are true and accurate representations of the scene  
6 depicted, and which all show cable and telephone attachments that do not comply with  
7 NESC's separation requirements.

8 **GEMC Ex. 82 (Panel-28)** is a picture of Flint EMC's system and was taken on  
9 September 29, 2020. The cable attachment depicted in this exhibit is on Flint EMC pole #  
10 049195, which is located at the intersection of Northside Drive and Ravenwood Way,  
11 Warner Robins, Georgia. The cable attachment in this picture belongs to Cox. Pursuant to  
12 NESC Rule 235, the Cox cable attachment shown in this picture should be separated from  
13 Flint EMC's neutral by at least 30 inches. Moreover, NESC Rule 238D requires that a  
14 communications attachment be separated from a drip loop serving a street light by at least  
15 12 inches. The Cox cable attachment violates both these requirements. There is only 22  
16 inches between the Cox cable attachment and Flint EMC's neutral and only 7 inches  
17 between the Cox cable attachment and the drip loop serving the street light. Cox's  
18 attachment being so close to Flint EMC's neutral means that Cox's attachment is  
19 encroaching into the CWSZ, which creates a hazard of electrical shock for persons working  
20 on the pole and creates a hazard for energization of the cable company's equipment into  
21 homes and businesses.

## PUBLIC DISCLOSURE DOCUMENT

1           **GEMC Ex. 83 (Panel-29)** is a picture of Walton EMC's system and was taken on  
2           September 21, 2020. The cable attachment shown in this picture is on Walton EMC pole #  
3           111099p003, which is located at 2015 Pleasant Hill Road. The cable attachment belongs  
4           to Comcast. Pursuant to NESC Rule 235, the cable attachment should be separated from  
5           Walton EMC's service wire by at least 40 inches. The Comcast cable attachment shown in  
6           this picture violates this requirement. In fact, the Comcast cable attachment is located only  
7           20 inches from Walton EMC's service wire. As I previously described, Comcast's  
8           attachment being so close to Walton EMC's service wire means that Comcast's attachment  
9           is encroaching on the CWSZ, which creates a safety hazard for workers.

10           **GEMC Ex. 84 (Panel-30)** is another picture of Walton EMC's system and was  
11           taken on September 21, 2020. The cable attachment shown in this picture is attached to  
12           Walton EMC pole # 087224p005, which is located at Karlee Boulevard and Highway 81.  
13           The cable attachment belongs to Comcast. Pursuant to NESC Rule 238B, the cable  
14           attachment should be separated from Walton EMC's transformer by at least 30 inches.  
15           Here, however, Comcast's attachment is separated from the transformer by only 8 inches.  
16           This is inadequate and means that Comcast's attachment is creating unnecessary hazards  
17           by encroaching into the CWSZ.

18           **GEMC Ex. 85 (Panel-31)** is a picture of Tri-County EMC's system and was taken  
19           on September 24, 2020. The cable in this picture is attached to Tri-County EMC pole #33-  
20           50, which is located at 242 Highway 212, Eatonton, Georgia. The cable attachment belongs  
21           to AT&T and spans across Highway 212. Pursuant to NESC Rule 235, AT&T's attachment  
22           should be separated from Tri-County EMC's facilities by at least 30 inches in the span.

## PUBLIC DISCLOSURE DOCUMENT

1 AT&T's cable, however, does not comply with this requirement. In fact, AT&T's cable is  
2 zip-tied to Tri-County EMC's service wire. Put differently, there is no separation between  
3 AT&T's attachment and Tri-County EMC's facilities. Under the NESC, this is improper.  
4 Moreover, should the zip tie eventually fail, AT&T's cable would likely separate from Tri-  
5 County EMC's facilities, at which point, AT&T's cable will likely not meet NESC's  
6 vertical clearance requirements. When communications cables create issues like this with  
7 vertical clearances, risks to traveling vehicles and the public follow.

8 **A.** By Mr. Brown: I am going to describe **GEMC Ex. 86 (Panel-32)**, **GEMC Ex. 87 (Panel-**  
9 **33)**, **GEMC Ex. 88 (Panel-34)**, and **GEMC Ex. 89 (Panel-35)**, which are photographs  
10 that I personally took and are true and accurate representations of the scene depicted, and  
11 which all show instances where communications attachments are violating the separation  
12 requirements.

13 **GEMC Ex. 86 (Panel-32)** is a picture of Hart EMC's system and was taken on  
14 September 16, 2020. The Hart EMC pole in this picture is located in Harbor Heights Circle.  
15 The cable attachments at issue belong to TruVista and Windstream. Pursuant to NESC  
16 Rule 238B, communications attachments should be separated from the transformer by at  
17 least 30 inches. Here, however, Windstream and TruVista's attachments are located just  
18 under Hart EMC's transformer, which means that the attachment is encroaching on the  
19 CWSZ and creating a safety hazard for persons working on the pole.

20 **GEMC Ex. 87 (Panel-33)** is a picture of Habersham EMC's system and was taken  
21 on September 21, 2020. The Habersham EMC pole in this picture is located on Parkwood  
22 Drive. The cable attachment at issue belongs to Windstream. Pursuant to NESC Rule 235,

**PUBLIC DISCLOSURE DOCUMENT**

1 Windstream’s attachment should be separated from Habersham EMC’s neutral by at least  
2 40 inches. Windstream’s attachment, however, does not comply with this requirement. In  
3 fact, Windstream’s attachment is sitting above Habersham EMC’s neutral. This is improper  
4 under NESC because Windstream has created a risk of electrical shock to those who have  
5 to come after them on the pole.

6 **GEMC Ex. 88 (Panel-34)** is a picture of Jefferson EMC’s system and was taken  
7 on September 22, 2020 at 7383 Lakeside Drive. The cable attachments at issue belong to  
8 Comcast and AT&T. Pursuant to NESC Rule 235H, there should be at least 4 inches  
9 between the cable of one communication utility and the cable of another communication  
10 utility. Despite this requirement, here, there is almost no separation between the AT&T  
11 and Comcast attachments. In fact, the AT&T and Comcast attachments have been zip-tied  
12 together.

13 **GEMC Ex. 89 (Panel-35)** is a picture of Rayle EMC’s system and was taken on  
14 September 22, 2020. This picture shows Rayle EMC pole # 15222048, which is located at  
15 228 Forest Lane. The attachment at issue is a cable company attachment. Pursuant to NESC  
16 Rule 238B, the attachment should be separated from Rayle EMC’s transformer by at least  
17 30 inches. Despite this requirement, the cable attachment shown in this picture is located  
18 just below the transformer and, thus, does not comply with the 30 inch separation  
19 requirement. Moreover, the cable attachment is encroaching into the CWSZ and creating  
20 a safety hazard for persons working on the pole.

21 **A. By Mr. Arant:** I will describe **GEMC Ex. 90 (Panel-36)**, **GEMC Ex. 91 (Panel-37)**,  
22 **GEMC Ex. 92 (Panel-38)**, and **GEMC Ex. 93 (Panel-39)**, which are photographs that I

## PUBLIC DISCLOSURE DOCUMENT

1 personally took and are true and accurate representations of the scene depicted, and which  
2 all show instances where cable attachments are violating the separation requirements.

3 **GEMC Ex. 90 (Panel-36)** is a picture of Central Georgia EMC's system and was  
4 taken on October 13, 2020. This picture was taken at 1938 Peeksville Road, Locust Grove,  
5 Georgia. The attachment at issue belongs to Charter. NESC Rule 235 requires that there be  
6 40 inches between the lowest energized electric line and any communications attachment.  
7 The purpose of this rule is to protect communications workers, who often have limited  
8 training. At mid-span, NESC requires that there be 30 inches between any communications  
9 attachment and the lowest energized electric line. Here, Charter's attachment does not  
10 comply with this requirement. In fact, as I am sure the Commission has noticed, Charter's  
11 attachment is draped over Central Georgia EMC's service line. The attacher likely did this  
12 so that Charter's attachment would have a greater vertical clearance. Nevertheless, this is  
13 improper and creates a safety hazard for persons working on the pole as well as reliability  
14 issues.

15 **GEMC Ex. 91 (Panel-37)** is a picture of Coweta-Fayette EMC's system and was  
16 taken on September 23, 2020. The Coweta-Fayette EMC pole shown in this picture is  
17 located on State Route 34 at Fischer Road, Sharpsburg, Georgia. The many attachments at  
18 issue in this picture belong to Comcast and AT&T. The NESC requires that there be 40  
19 inches between the facilities of an electric utility and a communications attachment and  
20 that there be at least 4 inches between the cable of one communication utility and the cable  
21 of another communication utility. The purpose of these rules is to prevent safety hazards  
22 for persons working on the pole and prevent the communications attachment from

## PUBLIC DISCLOSURE DOCUMENT

1 becoming energized. NESC Rule 239A requires that cable attachments be secure and be  
2 made on the surface of the structure. The purpose of this rule is to prevent safety hazards  
3 that are created by unsecured wiring. Comcast and AT&T's attachments do not comply  
4 with these rules. Comcast and AT&T have their attachments coiled excessively around  
5 Coweta-Fayette EMC's pole and are not maintaining the required separation. This is not  
6 only improper under numerous NESC rules, including NESC Rule 236, which requires that  
7 a full quadrant of the pole be available for climbing, but also creates a safety hazard for  
8 persons working on the pole, as the loose wires could get caught in their climbing gear.

9 **GEMC Ex. 92 (Panel-38)** is a picture of Greystone Power's system and was taken  
10 on September 24, 2020. This picture was taken at 4382 Daniell Mill Road, Winston,  
11 Georgia, which is a residential area. The attachment at issue belongs to Comcast. NESC  
12 Rule 235H requires that there be at least 4 inches between the cable of one communication  
13 utility and the cable of another communication utility, anywhere in the span. Despite this  
14 requirement, Comcast's attachment is actually resting on another communications  
15 attachment. Put differently, there is no separation between these two attachments. This is  
16 improper and a violation of both the NESC and the good workmanlike standard practiced  
17 in the electric and communications industry.

18 **GEMC Ex. 93 (Panel-39)** is another picture of Greystone Power's system and was  
19 taken on September 24, 2020. The picture was taken at 4162 Post Road. The attachment at  
20 issue belongs to Comcast and is running in front of a single-family residence. Under the  
21 NESC, Comcast's cable should remain separated from the telephone cable by  
22 approximately 4 inches throughout the span. Here, Comcast's cable has not maintained the

## PUBLIC DISCLOSURE DOCUMENT

1 required 4 inches of separation from the telephone cable. In fact, Comcast's cable is  
2 sagging below the telephone cable. Because Comcast's cable is not maintaining the  
3 minimum 4 inches of separation, the Comcast cable is likely to rub against the telephone  
4 facilities as the cables move during inclement weather or a breezy day. The friction created  
5 by the cables rubbing together could reasonably wear down the lashing material so much  
6 so that the co-axial cable will break away from the support strands it was lashed to.

7 **Q. Are the photographs each of you just described the only separation violations you**  
8 **found on the EMC systems you visited?**

9 **A. By the Panel:** No. Additional photographs showing, among other things, cable and  
10 telephone attachments that violate NESC's separation requirements on the systems of the  
11 Georgia EMCs visited by a member of this panel are attached to this testimony.

12 Additional photographs showing separation violations on the systems of the  
13 Georgia EMCs visited by Mr. Smith are contained in **GEMC Ex. 127 (Panel-73)**. The  
14 photographs contained in **GEMC Ex. 127 (Panel-73)** are photographs that Mr. Smith  
15 personally took and are true and accurate representations of the scene depicted. Additional  
16 photographs showing separation violations on the systems of the Georgia EMCs visited by  
17 Mr. Diamond are contained in **GEMC Ex. 128 (Panel-74)**. The photographs contained in  
18 **GEMC Ex. 128 (Panel-74)** are photographs that Mr. Diamond personally took and are  
19 true and accurate representations of the scene depicted. Additional photographs showing  
20 separation violations on the systems of the Georgia EMCs visited by Mr. Brown are  
21 contained in **GEMC Ex. 129 (Panel-75)**. The photographs contained in **GEMC Ex. 129**  
22 **(Panel-75)** are photographs that Mr. Brown personally took and are true and accurate

**PUBLIC DISCLOSURE DOCUMENT**

1 representations of the scene depicted. Additional photographs showing separation  
2 violations on the systems of the Georgia EMCs visited by Mr. Arant are contained in  
3 **GEMC Ex. 130 (Panel-76)**. The photographs contained in **GEMC Ex. 130 (Panel-76)** are  
4 photographs that Mr. Arant personally took and are true and accurate representations of the  
5 scene depicted.

6 In an effort to aid the Commission, each panel member has provided the following  
7 information for each picture contained in their exhibit: the image name, the name of the  
8 photographer, the date the picture was taken, the location where the picture was taken, the  
9 name of the attaching party, and the violation type. A brief description of the specific  
10 violation occurring in each picture is also provided. This information is located in the first  
11 pages of each of the exhibits listed above.

12 **Q. Do attachments that violate the separation requirements impose burdens on Georgia**  
13 **EMCs that would not otherwise exist?**

14 **A. By the Panel: Yes.**

15 **Safety Issues:** When communications companies do not adhere to NESC's  
16 separation requirements, it effectively makes the Georgia EMC owned poles unsafe to  
17 work on through no fault of the Georgia EMCs. More specifically, failure to adhere to the  
18 minimum separation requirements can increase the likelihood that persons working on the  
19 pole will suffer injury from electrocution. Injuries from electrocution can be severe. This  
20 is especially true for communications employees and contractors installing and maintaining  
21 communications attachments because these individuals are rarely qualified to work in close  
22 proximity to power system conductors, cables and equipment, and do not receive the kind

**PUBLIC DISCLOSURE DOCUMENT**

1 of training that Georgia EMCs provide their employees in an effort to avoid these kinds of  
2 safety hazards. Moreover, these individuals do not have the training, tools, personal  
3 protective equipment, and/or aerial lifts to meet the OSHA requirements for working on  
4 electrical power systems. In addition, a lack of adequate separation creates a safety hazard  
5 for the public through the increased likelihood of a high voltage being imposed on  
6 communications facilities serving nearby homes and businesses.

7 **Reliability Issues:** When there is contact between two different communications  
8 cables, between communications cables and power facilities, between communications  
9 facilities and guy wires, and/or between a communications worker and the power facilities,  
10 the power facilities can become damaged and a power outage can occur.

11 **Increased Costs:** Georgia EMCs incur increased costs as they identify, report, and  
12 follow up to ensure communications companies correct separation violations that their  
13 attachments have created. In addition, where a separation violation leads to personal injury,  
14 Georgia EMCs incur significant administrative and legal expenses defending any  
15 subsequent legal action.

16 **V. FAILURE TO PROPERLY SUPPORT THE POLE AND ADHERE TO LOADING**  
17 **AND STRENGTH REQUIREMENTS**

18 **Q. What is a pole compromise issue and how do pole compromise issues arise?**

19 **A. By the Panel:** A pole compromise issue is when the pole bends, leans, cracks, or is  
20 otherwise damaged because it is not being supported properly.

21 Pole compromise issues arise when: (1) attachers do not comply with Rules 264  
22 and 279, which require third-party communications attachers to install and maintain guys,

## PUBLIC DISCLOSURE DOCUMENT

1 anchors, and/or other braces to support the additional tension created by the  
2 communications attachment; and/or, (2) communications attachments are made that  
3 increase the loading on the poles beyond the strength requirements, as described in NESC  
4 Sections 25 and 26.

5 **Q. Please describe some of the photographs showing pole compromise issues.**

6 **A. By Mr. Smith:** I am going to describe **GEMC Ex. 94 (Panel-40)**, **GEMC Ex. 95 (Panel-**  
7 **41)**, **GEMC Ex. 96 (Panel-42)**, **GEMC Ex. 97 (Panel-43)**, **GEMC Ex. 98 (Panel-44)**,  
8 **GEMC Ex. 99 (Panel-45)**, and **GEMC Ex. 100 (Panel-46)**, which are photographs that I  
9 personally took and are true and accurate representations of the scene depicted, and which  
10 show pole compromise issues.

11 **GEMC Ex. 94 (Panel-40)** contains two pictures of Canoochee EMC's system that  
12 were taken on October 2, 2020. Both pictures show the same Canoochee EMC pole and  
13 were taken on Georgia Highway 196 at Marcus Nobles Road. The cable attachment at issue  
14 belongs to Comcast. NESC Rule 214 requires cable companies to inspect their facilities at  
15 installation and at intervals that experience has shown to be necessary. NESC Rules 264  
16 and 379 require cable companies to install and maintain guys, anchors and other braces  
17 that support the pole. As shown in picture "A" of **GEMC Ex. 94 (Panel-40)**, Comcast's  
18 guy-wire is broken and laying across a fence. Moreover, Comcast has not installed a new  
19 guy-wire to support its attachment. This is improper under NESC, compromises the  
20 strength of Canoochee EMC's pole, and does not meet the good workmanlike standards  
21 that are practiced in the electric and communications industry.

**PUBLIC DISCLOSURE DOCUMENT**

1           **GEMC Ex. 95 (Panel-41)** is another picture of Canoochee EMC’s system and was  
2 taken on October 2, 2020. This picture was taken at 845 Live Oak Church Road. The cable  
3 attachment at issue belongs to Comcast. To maintain the strength of utility poles, NESC  
4 requires cable attachers to install and maintain guys, anchors, and other braces. Here,  
5 Comcast’s initial installation was not done in accordance with the NESC or sound  
6 engineering principles. Moreover, Comcast has not maintained its guy-wire. Specifically,  
7 Comcast installed the guy attachment hardware with insufficient surface area. And, as a  
8 result, the guy attachment hardware is digging into the wood where it is installed and is  
9 compromising the strength of the pole. And, as the photograph shows, the pole is starting  
10 to bend and deflect where Comcast installed the guy attachment. This means that the guy  
11 attachment has created a potential point of failure for this pole. Had Comcast used the  
12 appropriate attachment hardware and installed its guy attachment correctly the pole’s wood  
13 fibers would not be crushing under the pressures and forces imposed on the hardware by  
14 the long span of communications cables. Ultimately, Canoochee EMC may have to replace  
15 this pole prematurely because Comcast’s attachment is damaging the pole.

16           **GEMC Ex. 96 (Panel-42)** is a picture of Colquitt EMC’s system and was taken on  
17 September 28, 2020. This picture was taken at the intersection of Springhill Church Road  
18 and Sandhammock Lake Road. The attachment at issue belongs to Mediacom. Here,  
19 despite having an obligation to install and maintain its guy-wire, the Mediacom guy-wire,  
20 which should be supporting several spans of communications cables, is loose. Thus,  
21 Colquitt EMC’s guy-wire and anchor are supporting both the power lines and the additional

## PUBLIC DISCLOSURE DOCUMENT

1 communications attachments. This is improper and, because Mediacom's guy-wire is  
2 inadequate, could result in pole failure.

3 **GEMC Ex. 97 (Panel-43)** is a picture of Middle Georgia EMC's system and was  
4 taken on September 30, 2020. This picture was taken at 7000 Highway 41. The attachment  
5 at issue belongs to Mediacom. NESC requires cable companies to install and maintain guy-  
6 wires, anchors, and other braces that are needed to support the pole. Here, while Mediacom  
7 did install a guy-wire, it did not install its own anchor. Instead, Mediacom attached its guy-  
8 wire to Middle Georgia EMC's anchor, which was not designed to support both the power  
9 lines and the communications attachments. Ultimately, this could cause the pole to bend or  
10 completely fail. In addition, one of Mediacom's cables is hanging down from the pole. This  
11 violates NESC Rule 239A, which requires cable attachments to be securely attached to the  
12 surface of the utility pole, and creates a safety hazard.

13 **GEMC Ex. 98 (Panel-44)** is a picture of Mitchell EMC's system and was taken on  
14 September 29, 2020 at 811 Notre Dame Avenue. The attachments at issue belong to  
15 Mediacom and AT&T. Pursuant to NESC Rule 264, both Mediacom and AT&T should  
16 have installed guy-wires and anchors to support the additional load created by their  
17 attachments. Despite this, Mediacom and AT&T are sharing a common anchor, which is  
18 putting excessive tension on Mitchell EMC's pole and causing it to become bowed. This  
19 could force Mitchell EMC to replace this pole sooner than would normally be necessary.

20 **GEMC Ex. 99 (Panel-45)** is a picture of Sumter EMC's system and was taken on  
21 September 29, 2020 at 107 Ashwood Court, which is in the Canterbury Subdivision. The  
22 attachment at issue belongs to Mediacom. Here, Mediacom has violated NESC Rule 264

**PUBLIC DISCLOSURE DOCUMENT**

1 by failing to maintain its guy-wire. In fact, Mediacom’s guy-wire is broken and taped  
2 around the base of the pole. As a result, Mediacom’s guy-wire is providing no support for  
3 the increased tension created by Mediacom’s attachments. A pole burdened by an  
4 improperly guy-wired attachment could fail under storm conditions because of that  
5 attachment.

6 **GEMC Ex. 100 (Panel-46)** is another picture of Sumter EMC’s system and was  
7 taken on October 4, 2020. This picture was taken on Murphy Mill Road, just west of Lake  
8 Jennifer Drive. The attachments at issue belong to Mediacom and AT&T. Here, while  
9 Mediacom and AT&T did install guy-wires to support the tension added by their  
10 attachments, neither Mediacom nor AT&T have maintained their guy-wires. In fact, both  
11 guy-wires are loose, which is not only improper under the NESC but is also causing Sumter  
12 EMC’s double-circuit pole to lean left. Because the pole is leaning left, there is less than  
13 13 feet of vertical clearance between the lowest communications cable and the surface of  
14 the adjacent public road. If additional strain is put on the cable steel messenger, as might  
15 occur from a tree limb falling across the communications cables or from contact by a large  
16 truck traveling on the roadway, the Sumter EMC pole may fail, leaving over 1,000 Sumter  
17 EMC member-owners without power and creating a risk of public contact with uninsulated  
18 power conductors energized at 25,000 volts.

19 **A. By Mr. Diamond:** I will describe **GEMC Ex. 101 (Panel-47)**, **GEMC Ex. 102 (Panel-48)**,  
20 **GEMC Ex. 103 (Panel-49)**, and **GEMC Ex. 104 (Panel-50)**, which are photographs that  
21 I personally took and are true and accurate representations of the scene depicted, and which  
22 show pole compromise issues.

## PUBLIC DISCLOSURE DOCUMENT

1           **GEMC Ex. 101 (Panel-47)** is a picture of Flint EMC’s system and was taken on  
2           September 29, 2020. The cable attachments at issue are on Flint EMC pole # 085338, which  
3           is located at the intersection of Highway 96 and Highway 247 in Kathleen, Georgia. The  
4           attachments belong to Cox, Hargray Communications (“Hargray”), and AT&T. While I  
5           believe the picture speaks for itself, the attachments by Cox, Hargray, and AT&T are  
6           putting undue strain on the Flint EMC pole, causing it to bend. This is likely a result of  
7           Cox, Hargray, and AT&T failing to adhere to NESC Rules 264 and 279, which require the  
8           proper installation and maintenance of guy-wires and anchors that provide additional  
9           strength and support to the pole.

10           **GEMC Ex. 102 (Panel-48)** is a picture of Flint EMC’s system and was taken on  
11           September 29, 2020. The pole shown in this picture is Flint EMC pole #033355, which is  
12           located at the intersection Parkwood Drive and Anne Drive in Warner Robins, Georgia.  
13           The cable attachment at issue belongs to Cox. NESC Rules 264 and 279 require cable  
14           companies to install and maintain adequate guys, anchors, and other braces needed to  
15           support the additional tension created by the attachment. Here, while Cox has installed a  
16           guy-wire, Cox did not install its own anchor. Instead, Cox attached its guy-wire to Flint  
17           EMC’s anchor, which was not designed to support both the power lines and the cable  
18           attachments. Because Cox has attached to Flint EMC’s pole without properly installing its  
19           own guy-wire and anchor, the Flint EMC pole is bowed and being pulled at Cox’s  
20           attachment point.

21           **GEMC Ex. 103 (Panel-49)** is a picture of Walton EMC’s system and was taken on  
22           September 21, 2020. The communications attachment at issue belongs to AT&T and is

**PUBLIC DISCLOSURE DOCUMENT**

1 attached to Walton EMC pole # 066113p002, which is located at the intersection of Athens  
2 Highway and Hill Street SW. AT&T's cable spans across Athens Highway. As I am sure  
3 the Commission can see, the Walton EMC pole is leaning right. This is the result of AT&T  
4 not complying with the guying and anchoring requirements contained in NESC Rules 264  
5 and 279. Specifically, here, AT&T has not properly guyed its attachment, which has  
6 compromised the strength of the Walton EMC pole and caused the pole to lean to the right.  
7 The excess tension created by AT&T's attachment could ultimately damage the pole in a  
8 way that forces Walton EMC to replace the pole prematurely.

9 **GEMC Ex. 104 (Panel-50)** is a picture of Jackson EMC's system and was taken  
10 on September 22, 2020. The communications attachment at issue belongs to Comcast and  
11 is attached to Jackson EMC pole # 611161402, which is located at 793 Mountain Church  
12 Road, Pendergrass, Georgia. NESC Rules 264 and 279 require that communications  
13 attachers install and maintain guys, anchors, and braces in order to support the pole. Here,  
14 while Comcast has attached to the Jackson EMC pole, Comcast completely failed to install  
15 a guy-wire, anchor, and/or other brace. Such conduct creates safety and reliability issues,  
16 damages the pole, and is improper under the NESC.

17 **A. By Mr. Brown:** I am going to describe **GEMC Ex. 105 (Panel-51)**, **GEMC Ex. 106**  
18 **(Panel-52)**, **GEMC Ex. 107 (Panel-53)**, **GEMC Ex. 108 (Panel-54)**, and **GEMC Ex. 109**  
19 **(Panel-55)**, which are photographs that I personally took and are true and accurate  
20 representations of the scene depicted and which show pole compromise issues.

21 **GEMC Ex. 105 (Panel-51)** is a picture of Hart EMC's system and was taken on  
22 September 16, 2020. The Hart EMC pole in this picture is located on Old Beacon Light

**PUBLIC DISCLOSURE DOCUMENT**

1 Road. The cable attachment at issue belongs to Comcast. NESC Rule 264 requires the use  
2 of guys, braces, and anchors to provide additional strength to the pole when attachments  
3 are made. Here, Comcast’s guy-wire is not properly installed. Specifically, Comcast’s guy-  
4 wire is hanging loosely next to the pole instead of being pulled tight. When a guy-wire is  
5 not pulled tight, as is the case in this picture, the pole is not receiving the additional strength  
6 that is needed to support the communications attachment. Because Comcast did not  
7 properly install a guy-wire, Hart EMC’s guy wire and anchor is supporting both the power  
8 lines and the communications attachments, which they were not designed to do.

9 **GEMC Ex. 106 (Panel-52)** is a picture of Habersham EMC’s system and was taken  
10 on September 21, 2020. The Habersham EMC pole in this picture is located at 2210 Dicks  
11 Hill Parkway. The attachment at issue belongs to Windstream. Here, despite having an  
12 obligation under NESC to install and maintain guy-wires, anchors, and braces,  
13 Windstream’s attachment was not accompanied by the installation of a proper guy-wire.  
14 As a result, the Windstream attachment is putting undue strain on Habersham EMC’s pole,  
15 causing it to bend and become deformed. In the long run, this could cause pole failure or  
16 force Habersham EMC to replace its pole sooner than would normally be required.

17 **GEMC Ex. 107 (Panel-53)** is a picture of Jefferson EMC’s system and was taken  
18 on September 22, 2020. The Jefferson EMC anchor shown in this picture is attached to the  
19 Jefferson EMC pole located at 4803 Forest Hills Drive. The cable attachment at issue  
20 belongs to Comcast. The NESC requires cable companies to install and maintain guy-  
21 wires, anchors, and other braces that are needed to support the additional tension created  
22 by communications attachments. Here, while Comcast installed a guy-wire, it did not

## PUBLIC DISCLOSURE DOCUMENT

1 install its own anchor. Instead, Comcast attached its guy-wire to Jefferson EMC's anchor,  
2 which was not designed to support both the power lines and the communications  
3 attachments. Because Comcast did not install its own anchor, Comcast's attachment  
4 compromises the overall strength of the pole, which can cause the pole to lean, bend, and/or  
5 fail.

6 **GEMC Ex. 108 (Panel-54)** is a picture of Planters EMC's system and was taken  
7 on September 23, 2020 at 286 Twin Oak Drive. The cable attachment at issue belongs to  
8 Comcast. Pursuant to NESC Rule 264, when Comcast attached to Planters EMC's pole it  
9 should have also installed guy-wires and anchors to support the additional tension created  
10 by its attachment. Despite this obligation, Comcast has attached to the Planters EMC pole  
11 but has completely failed to install a guy-wire. As a result, this Planters EMC pole is only  
12 supported by the guy-wires and anchors installed and maintained by Planters EMC, which  
13 were not designed to support the additional tension created by Comcast's attachment.

14 **GEMC Ex. 109 (Panel-55)** is a picture of Rayle EMC's system and was taken on  
15 September 22, 2020. The pole shown in this picture is Rayle EMC Pole # 15222038, which  
16 is located at 308 Forest Lane. The attachment at issue was made by a cable company. The  
17 NESC requires cable companies to install and maintain guy-wires, anchors, and other  
18 braces that are needed to support the additional tension created by the attachment. Here,  
19 while the cable company did install a guy-wire, it did not install its own anchor. Rather,  
20 the cable company attached its guy-wire to Rayle EMC's anchor. This is improper under  
21 the NESC and has caused Rayle EMC's pole to bend and become deformed. A bent and  
22 deformed pole may fail or have to be prematurely replaced.

**PUBLIC DISCLOSURE DOCUMENT**

1    **A.**    By Mr. Arant: I will be describing **GEMC Ex. 110 (Panel-56)**, **GEMC Ex. 111 (Panel-**  
2           **57)**, and **GEMC Ex. 112 (Panel-58)**, which are photographs that I personally took and are  
3           true and accurate representations of the scene depicted, and which show pole compromise  
4           issues.

5                   **GEMC Ex. 110 (Panel-56)** is a picture of Carroll EMC’s system and was taken on  
6           September 24, 2020. The Carroll EMC pole shown in this picture is located on Madison  
7           Sanders Road at US 27. The attachments at issue belong to Comcast and AT&T. Pursuant  
8           to NESC Rules 264 and 379, third-party attachers, including Comcast and AT&T, are  
9           required to install and maintain guys, anchors, and other braces to support the added tension  
10          created by communications attachments. Without the appropriate guy, anchor, and/or other  
11          brace, the third-party attachment compromises the strength of the pole, which can lead to  
12          the pole bending, leaning, and, in some cases, failing. Here, Comcast and AT&T both  
13          attached to Carroll EMC’s pole without, contemporaneously, installing adequate guy-  
14          wires. As a result, Carroll EMC’s pole has become bowed.

15                   **GEMC Ex. 111 (Panel-57)** contains two pictures of Greystone Power’s system  
16          that were taken on September 24, 2020. The Greystone Power pole shown in both pictures  
17          is located at 4337 Maroney Mill Road, Douglasville, Georgia 30134. The attachment at  
18          issue belongs to Comcast. As I previously mentioned, the NESC requires that third-party  
19          attachers, including Comcast, install and maintain guys, anchors, and other braces that  
20          support the additional tension created by communications attachments. Here, while  
21          Comcast did install a guy-wire, Comcast did not attach its guy-wire to Greystone Power’s  
22          double eye anchor, which is designed to have a cable guy-wire attachment. Instead, and as

## PUBLIC DISCLOSURE DOCUMENT

1 shown in the picture A of **GEMC Ex. 111 (Panel-57)**, Comcast left its guy-wire hanging  
2 at the base of Greystone Power's pole. As a result, and as shown in the picture B of **GEMC**  
3 **Ex. 111 (Panel-57)**, Greystone Power's pole is leaning right. If additional strain is put on  
4 this Greystone Power pole, then the pole may fail. Poles that fail create reliability issues  
5 and pose risks to people and property.

6 **GEMC Ex. 112 (Panel-58)** contains two pictures of Snapping Shoals EMC's  
7 system that were taken on September 29, 2020. The Snapping Shoals EMC poles shown in  
8 these pictures are located at 103 Temple Lane, Covington, Georgia. The communications  
9 attachment at issue belongs to Comcast. These pictures are an example of what can result  
10 when third-party attachers do not make timely transfers and maintain the proper guys,  
11 anchors, and/or braces, as required by the NESC. Here, the entire top of the old Snapping  
12 Shoals EMC pole failed because Comcast did not timely transfer to the new Snapping  
13 Shoals EMC pole and Comcast did not properly support its attachments that remained on  
14 the old pole. Comcast's failure to both properly support its attachments and timely transfer  
15 its attachments is improper under the NESC and violates the good workmanlike standards  
16 that are practiced in the electric and communications industry.

17 **Q. Are the photographs each of you just described the only pole compromise issues you**  
18 **found on the EMC systems you visited?**

19 **A. By the Panel:** No. Additional pictures showing, among other things, cable and telephone  
20 attachments that violate NESC's strength and loading requirements on the systems of the  
21 Georgia EMCs visited by a member of this panel are attached to this testimony.

## PUBLIC DISCLOSURE DOCUMENT

1 Additional photographs showing strength and loading violations on the systems of  
2 the Georgia EMCs visited by Mr. Smith are contained in **GEMC Ex. 127 (Panel-73)**. The  
3 photographs contained in **GEMC Ex. 127 (Panel-73)** are photographs that Mr. Smith  
4 personally took and are true and accurate representations of the scene depicted. Additional  
5 photographs showing strength and loading violations on the systems of the Georgia EMCs  
6 visited by Mr. Diamond are contained in **GEMC Ex. 128 (Panel-74)**. The photographs in  
7 **GEMC Ex. 128 (Panel-74)** are photographs that Mr. Diamond personally took and are  
8 true and accurate representations of the scene depicted. Additional photographs showing  
9 strength and loading violations on the systems of the Georgia EMCs visited by Mr. Brown  
10 are contained in **GEMC Ex. 129 (Panel-75)**. The photographs contained in **GEMC Ex.**  
11 **129 (Panel-75)** are photographs that Mr. Brown personally took and are true and accurate  
12 representations of the scene depicted. Additional photographs showing strength and  
13 loading violations on the systems of the Georgia EMCs visited by Mr. Arant are contained  
14 in **GEMC Ex. 130 (Panel-76)**. The photographs contained in **GEMC Ex. 130 (Panel-76)**  
15 are photographs that Mr. Arant personally took and are true and accurate representations  
16 of the scene depicted.

17 In an effort to aid the Commission, each panel member has provided the following  
18 information for each photograph contained in their exhibit: the image name, the name of  
19 the photographer, the date the picture was taken, the location where the picture was taken,  
20 the name of the attaching party, and the violation type. A brief description of the specific  
21 violation occurring in each photograph is also provided. This information is located in the  
22 first pages of each of the exhibits listed above.

## PUBLIC DISCLOSURE DOCUMENT

1 **Q. Do communications attachments that cause pole compromise issues impose burdens**  
2 **on Georgia EMCs that would not otherwise exist?**

3 **A. By the Panel: Yes.**

4 **Safety Issues:** The failure to properly guy and support communications  
5 attachments creates pole loading issues that can cause premature and unexpected pole  
6 failure. This creates a safety hazard for the public and EMC workers that may be climbing  
7 the poles.

8 **Reliability Issues:** When EMC owned poles are broken or damaged it will often  
9 lead to power interruptions. These interruptions occur more frequently when the system is  
10 under storm loading conditions. And, while it is true that EMC pole and equipment failures  
11 occur during storms even without communications attachments present, an EMC pole that  
12 has communications attachments that do not meet the strength provisions of the NESC is  
13 much more likely to catastrophically fail, which results in a power outage that takes far  
14 more time to restore.

15 **Increased Costs:** Pole compromise issues increase costs for Georgia EMCs  
16 through increased outage times, increased repair time, premature replacement of existing  
17 facilities, and the costs of labor and materials associated with these activities. In addition,  
18 Georgia EMCs invest a significant amount of time and money communicating loading and  
19 strength issues to communications attachers, evaluating potential solutions, and  
20 implementing corrective actions.

PUBLIC DISCLOSURE DOCUMENT

1 VI. FAILURE TO COMPLY WITH OTHER ATTACHMENT REQUIREMENTS

2 Q. Are there other rules and standards that communications attachers frequently  
3 violate?

4 A. By the Panel: Yes. In addition to the violations described above, cable and telephone  
5 companies frequently violate the following rules when attaching to poles owned by  
6 Georgia EMCs:

7 Abandon Attachments: NESC Rule 214-B, which governs inspections and testing  
8 of overhead supply and communications lines, requires that lines that have been  
9 permanently abandoned be removed or maintained in a safe condition. Despite this,  
10 communications attachers abandon their lines and fail to remove and/or maintain them after  
11 such abandonment.

12 Failure to Transfer Attachments: Under most pole attachment agreements,  
13 communications attachers have an obligation to transfer their attachments within a  
14 specified amount of time. Despite this and the good workmanlike standard practiced in the  
15 electric and communications industry, communications attachers often fail or refuse to  
16 timely transfer their attachments when a new pole is set. This can create a safety hazard for  
17 the public and persons trying to work on the new pole.

18 Skipping Poles: NESC Rule 234-B, requires that there be at least 3 feet of  
19 horizontal clearance (when displaced by wind) between a communications cable and any  
20 pole that the cable is not attached. In some instances, however, communications attachers  
21 do not attach to every pole. Instead, the communications cable runs right in front of the

**PUBLIC DISCLOSURE DOCUMENT**

1 pole. In addition to violating NESC Rule 234-B, this practice puts additional stress on the  
2 other poles that the communications cable is attached to.

3 Dangling Wires Not Securely Attached to the Pole: NESC Rule 239A requires that  
4 attachments be secure and be made on the surface of the utility pole. The purpose of this  
5 rule is prevent the safety hazards that are created by unsecured wiring. Despite this rule,  
6 third-party attachers often leave cables hanging, creating a safety hazard for both the  
7 general public and persons working on the pole.

8 Unpermitted and Excessive Overlashing: Most pole attachment agreements  
9 prohibit overlashing without prior permitting and review by the pole owner. Despite this,  
10 third-party communications attachers use overlashing to attach to EMC owned poles  
11 without seeking a permit or having a qualified engineer perform a pole loading analysis to  
12 determine if the increased diameter and weight of the attachments will create unbalanced  
13 tensions and/or other pole loading not in compliance with NESC Sections 24 and 25.

14 Creating Boxed-In-Poles: Good work practice requires that all communications  
15 cables be installed on the same side of the pole as the power system neutral conductor.  
16 Having cables on both sides of the pole encroaches on the climbing space and violates  
17 NESC Rule 236, which requires an open climbing space past any conductors or cables. In  
18 addition, when replacing a boxed-in pole, the new replacement pole cannot be placed  
19 directly in line but instead must be set on one side of the communications cables.  
20 Ultimately, this results in a slight angle on the new structure. Despite all of this,  
21 communications attachers create boxed-in poles by attaching to both the street side and the  
22 opposite side of the pole.

## PUBLIC DISCLOSURE DOCUMENT

1            Failure to Participate in Vegetation Management: Under NESC Rule 218, third-  
2 party communications attachers are required to participate in vegetation management.  
3 Despite this, many communications attachers do not participate in vegetation management,  
4 even where the vegetation is solely affecting the communications attachments. Such  
5 conduct can result in vegetation weighing down cables and putting additional tension on  
6 the EMC pole.

7 **Q. Please describe some of the photographs showing these other violations.**

8 **A. By Mr. Smith: I will describe **GEMC Ex. 113 (Panel-59)**, **GEMC Ex. 114 (Panel-60)**,  
9 **GEMC Ex. 115 (Panel-61)**, and **GEMC Ex. 116 (Panel-62)**, which are photographs that  
10 I personally took and are true and accurate representations of the scene depicted.**

11            **GEMC Ex. 113 (Panel-59)** is a picture of Canoochee EMC's system and was taken  
12 on October 2, 2020 where Fort Argyle Road and Savannah-Ogeechee Canal Park intersect.  
13 The attachment at issue belongs to Comcast. Here, Comcast has attached additional cables  
14 to an original bundle of cables by overlashing. As a result, there are three communications  
15 cables that are bundled together on the left span and six communications cables that are  
16 bundled together on the right span. This is causing unbalanced tension across Canoochee  
17 EMC's pole, and Comcast has not installed proper guying to support the unbalanced  
18 tensions. In addition, the increased diameter of the overlashed cables will result in a  
19 significant increase in horizontal forces resulting from wind loading against the cables. In  
20 sum, these Comcast attachments violate the good workmanlike standards related to proper  
21 sag and tension practices and may be violating NESC Rule 250, which contains specific  
22 loading requirements.

## PUBLIC DISCLOSURE DOCUMENT

1           **GEMC Ex. 114 (Panel-60)** is a picture of Colquitt EMC's system and was taken  
2 on September 28, 2020. The Colquitt EMC pole shown in this picture is located on  
3 Springhill Church Road. The attachment at issue belongs to Mediacom. NESC Rule 239A  
4 requires that attachments be secure and be made on the surface of the pole. The purpose of  
5 this rule is prevent the safety hazards that are created by unsecured wiring. As shown in  
6 the picture, Mediacom's riser cables are not securely attached to the surface of Colquitt  
7 EMC's pole. Thus, Mediacom's attachment does not comply with NESC Rule 239A and  
8 creates a safety hazard.

9           **GEMC Ex. 115 (Panel-61)** is a picture of Middle Georgia EMC's system and was  
10 taken on September 30, 2020 at 521 Folds Road. The attachment at issue belongs to a now-  
11 defunct cable system operator. Here, the cable operator has actually abandoned its  
12 attachment but has left the cable attached to Middle Georgia EMC's pole and laying on the  
13 ground. This conduct violates the NESC and good workmanlike standards.

14           **GEMC Ex. 116 (Panel-62)** is a picture of Sumter EMC's system and was taken on  
15 September 21, 2020. The Sumter EMC pole shown in this picture is located on Wadsworth  
16 Avenue, west of Winifred Road. The attachments at issue belong to Mediacom and  
17 Windstream. Good work practices require that communication attachments be installed on  
18 the same side of the pole as the power system neutral conductor. Here, however, Mediacom  
19 and Windstream have attached on both the street side of the pole and the opposite side of  
20 the pole. As a result, Mediacom and Windstream have created a boxed-in pole. Boxed-in  
21 poles obstruct safe pole access by climbing workers, which violates NESC Rule 236, and  
22 hinder Sumter EMC's ability to replace its pole either routinely or due to an emergency.

**PUBLIC DISCLOSURE DOCUMENT**

1           Moreover, if Sumter EMC needed to install a replacement pole, the boxed-in pole forces  
2           Sumter EMC to install the replacement pole out of line with the adjacent poles, thereby  
3           imposing a side force on the pole resulting from the angle of the transferred conductors and  
4           cables.

5    **A.**    By Mr. Diamond: I am going to describe **GEMC Ex. 117 (Panel-63)**, **GEMC Ex. 118**  
6           **(Panel-64)**, and **GEMC Ex. 119 (Panel-65)**, which are photographs that I personally took  
7           and are true and accurate representations of the scene depicted.

8                   **GEMC Ex. 117 (Panel-63)** is a picture of Flint EMC’s system and was taken on  
9           September 29, 2020. The cables shown in this picture belong to Hargray and Windstream  
10          and should be attached to Flint EMC pole # 050004, which is located at the intersection of  
11          Highway 247 and Highway 127 in Kathleen, Georgia. However, the Hargray and  
12          Windstream cables are not attached to the Flint EMC pole. Rather, they are running right  
13          beside the pole. This violates NESC Rule 234-B, does not adhere to the good workmanlike  
14          standard practiced in the electric and communications industry, and creates a safety hazard  
15          for persons working on the pole.

16                   **GEMC Ex. 118 (Panel-64)** is a picture of Walton EMC’s system and was taken on  
17          September 21, 2020. The cable attachment in this photograph is attached to Walton EMC  
18          pole # 111174p010, which is located at 1068 Pleasant Valley Road. The communications  
19          attachment at issue belongs to Windstream. Despite the fact that Walton EMC replaced its  
20          pole at this location, Windstream still has not transferred its attachment. As a result, there  
21          are redundant poles at this location.

## PUBLIC DISCLOSURE DOCUMENT

1           **GEMC Ex. 119 (Panel-65)** is a picture of Tri-County EMC's system and was taken  
2 on September 24, 2020. The cable attachment in this photograph is attached to Tri-County  
3 EMC pole # 5L-6-2, which is located at 157 Crooked Creek Road, Eatonton Georgia. The  
4 communications attachment at issue belongs to Charter. Here, when Charter attached to  
5 Tri-County EMC's pole it drilled through the secondary riser shield. This is improper under  
6 the good workmanlike standards practiced in this industry. Moreover, it creates a risk of  
7 electrical shock to the communications worker, who could not have known where exactly  
8 Tri-County EMC's secondary conductors were under the riser shield.

9 **A. By Mr. Brown:** I will describe **GEMC Ex. 120 (Panel-66)**, **GEMC Ex. 121 (Panel-67)**,  
10 **GEMC Ex. 122 (Panel-68)**, and **GEMC Ex. 123 (Panel-69)**, which are photographs that  
11 I personally took and are true and accurate representations of the scene depicted.

12           **GEMC Ex. 120 (Panel-66)** is a picture of Hart EMC's system and was taken on  
13 September 16, 2020. The Hart EMC pole captured in this picture is located on Ernest Oliver  
14 Road. The cable attachment at issue belongs to Hart CATV. Here, Hart EMC has replaced  
15 one of its poles; however, Hart CATV has not transferred its attachments. As a result, there  
16 are redundant poles at this location.

17           **GEMC Ex. 121 (Panel-67)** is another picture of Hart EMC's system and was taken  
18 on September 16, 2020. The Hart EMC pole shown in this picture is located on Capri Drive.  
19 The cables at issue belong to Hart CATV, Hart Telephone, and Comcast and should be  
20 attached to the Hart EMC pole shown in the picture. However, the cables owned by Hart  
21 CATV, Hart Telephone, and Comcast are not attached to the Hart EMC pole; instead, they

**PUBLIC DISCLOSURE DOCUMENT**

1 are running right in front of the pole. This violates NESC Rule 234-B and creates a safety  
2 hazard for persons doing work on the pole.

3 **GEMC Ex. 122 (Panel-68)** is a picture of Habersham EMC’s system and was taken  
4 on September 21, 2020. The Habersham EMC pole shown in this picture is located on  
5 Duncan Bridge Road. The attachment at issue belongs to Windstream. Here, Windstream  
6 attached by overlashing. However, Windstream’s attachment was done poorly and, thus,  
7 has resulted in parts of the cable hanging down into the grounds of a church cemetery. This  
8 violates both the good workmanlike standards practiced in this industry and NESC Rule  
9 239A, which requires cable attachments to be securely attached to the surface of the utility  
10 pole. This also creates numerous safety hazards that NESC Rule 239A is designed to  
11 prevent, including climbing hazards, entanglement hazards, and tripping hazards.

12 **GEMC Ex. 123 (Panel-69)** is a picture of Jefferson EMC’s system and was taken  
13 on September 22, 2020 at 7421 Lakeside Drive. The communications attachment at issue  
14 belongs to Comcast. Comcast’s cable, which is spanning between two Jefferson EMC  
15 poles, has been tacked to a tree. This violates the good workmanlike standards practiced in  
16 the electric and communications industry.

17 **A. By Mr. Arant:** I will be describing **GEMC Ex. 124 (Panel-70)** and **GEMC Ex. 125**  
18 **(Panel-71)**, which are photographs that I personally took and are true and accurate  
19 representations of the scene depicted.

20 **GEMC Ex. 124 (Panel-70)** is a picture of Carroll EMC’s system and was taken on  
21 September 24, 2020. The Carroll EMC pole shown in this picture is located on Jonesville  
22 Road, Bowdon, Georgia. The attachment at issue belongs to Comcast. Here, Comcast

## PUBLIC DISCLOSURE DOCUMENT

1 attached to Carroll EMC's pole through unpermitted overlashing. Comcast's attachment  
2 continues for 35-40 spans. Comcast's conduct is improper and violates the good  
3 workmanlike standards practiced in this industry. Moreover, Comcast's unpermitted  
4 overlashing could overload the pole, resulting in complete pole failure or damage to the  
5 pole.

6 **GEMC Ex. 125 (Panel-71)** contains two pictures of Greystone Power's system  
7 that were taken on September 24, 2020. The Greystone Power poles shown in these pictures  
8 are located at the intersection of Post Road and the 1-20 West on ramp in Winston, Georgia.  
9 The attachment at issue belongs to Comcast. Here, Comcast has abandoned an inactive  
10 coax cable and left it hanging. Even though the cable is inactive, Comcast's conduct  
11 violates NESC 214-B and has created an entanglement hazard.

12 **Q. Are the photographs each of you just described the only other violations you found**  
13 **on the EMC systems you visited?**

14 **A. By the Panel:** No. Additional pictures showing, among other things, cable and telephone  
15 attachments that violate other attachment requirements on the systems of the Georgia  
16 EMCs visited by a member of this panel are attached to this testimony.

17 Additional photographs showing other communications attachment violations on  
18 the systems of the Georgia EMCs visited by Mr. Smith are contained in **GEMC Ex. 127**  
19 **(Panel-73)**. The photographs contained in **GEMC Ex. 127 (Panel-73)** are photographs  
20 that Mr. Smith personally took and are true and accurate representations of the scene  
21 depicted. Additional photographs showing other communications attachment violations on  
22 the systems of the Georgia EMCs visited by Mr. Diamond are contained in **GEMC Ex.**

**PUBLIC DISCLOSURE DOCUMENT**

1       **128 (Panel-74)**. The photographs contained in **GEMC Ex. 128 (Panel-74)** are photographs  
2       that Mr. Diamond personally took and are true and accurate representations of the scene  
3       depicted. Additional photographs showing other communications attachment violations on  
4       the systems of the Georgia EMCs visited by Mr. Brown are contained in **GEMC Ex. 129**  
5       **(Panel-75)**. The photographs contained in **GEMC Ex. 129 (Panel-75)** are photographs  
6       that Mr. Brown personally took and are true and accurate representations of the scene  
7       depicted. Additional photographs showing other communications attachment violations on  
8       the systems of the Georgia EMCs visited by Mr. Arant are contained in **GEMC Ex. 130**  
9       **(Panel-76)**. The photographs contained in **GEMC Ex. 130 (Panel-76)** are photographs  
10      that Mr. Arant personally took and are true and accurate representations of the scene  
11      depicted.

12               In an effort to aid the Commission, each panel member has provided the following  
13      information for each photograph contained in their exhibit: the image name, the name of  
14      the photographer, the date the picture was taken, the location where the picture was taken,  
15      the name of the attaching party, and the violation type. A brief description of the specific  
16      violation occurring in each photograph is also provided. This information is located in the  
17      first pages of each of the exhibits identified above.

18      **Q. Do attachments that violate these other rules and standards impose burdens and costs**  
19      **on Georgia EMCs that would not otherwise exist?**

20      **A. By the Panel: Yes.**

21               **Safety Issues:** Safety issues are created when communications attachers abandon  
22      their attachments, leave their wires dangling, create boxed-in poles, and fail to participate

## PUBLIC DISCLOSURE DOCUMENT

1 in vegetation management. Specifically, abandoned communications attachments and  
2 dangling communications wires represent an ongoing hazard to EMC personnel, especially  
3 if the cables become energized. EMC workers, including lineman and EMC right-of-way  
4 crews, can also trip, fall, become entangled, or make unexpected contact with an abandoned  
5 or dangling communications wire. In addition, an EMC lineman cannot safely climb a pole  
6 that is boxed-in by communications attachments or has communications wires dangling  
7 from various places on the pole. These practices also create a safety hazard for the general  
8 public, who may slip, trip, fall, become entangled in, or make unintentional contact with a  
9 communications cable that is abandoned, dangling, or hidden under overgrown vegetation.

10 **Reliability Issues:** The frequency and duration of power outages increases when  
11 communications attachers abandon their attachments, fail to participate in vegetation  
12 management, fail to maintain their cables, create boxed-in poles, and leave their cables  
13 dangling from EMC poles. Abandoned attachments and dangling cables can also lead to  
14 outages through unintentional contact between the communications facilities and the power  
15 conductors. Boxed-in poles and dangling cables also hinder the ability of EMC line  
16 workers to safely climb EMC poles when an outage occurs.

17 **Increased Costs:** Reports from the public or law enforcement regarding downed  
18 lines and hanging cables must be investigated. When violations have gone uncorrected for  
19 a significant period of time, the electric utility may have to make multiple visits to the site  
20 to verify that the problem is not a power conductor. All the costs associated with such  
21 activities are borne by the EMC. Where communications attachments create a boxed-in  
22 pole, Georgia EMCs incur increased costs replacing the pole because it takes longer to set

## PUBLIC DISCLOSURE DOCUMENT

1 and transfer power system attachments and, in addition, may require the EMC to straighten  
2 the replacement pole, which had to be installed leaning to one side to clear the boxed  
3 communications cables, after the transfers are complete.

### 4 VII. IMPACT TO GEORGIA EMCS

5 Q. As a panel you have presented evidence showing that cable and telephone attachers  
6 are violating various pole attachment rules, including rules established by the NESC,  
7 at the nineteen (19) Georgia EMCs visited by a member of this panel. Have you also  
8 reviewed photographs showing similar pole attachment violations at other Georgia  
9 EMCs?

10 A. By the Panel: Yes. The pictures described in this testimony are representative of systemic  
11 practices by cable and telephone companies throughout Georgia EMCs' systems. Put  
12 differently, telephone and cable attachers are violating these same pole attachment rules on  
13 the systems of the other Georgia EMCs that were not visited by any member of this panel.

14 GEMC Ex. 126 (Panel-73) contains pictures and authenticating affidavits that  
15 were submitted by other Georgia EMCs not visited by any member of this panel. Like the  
16 pictures described throughout this testimony, the pictures in GEMC Ex. 126 (Panel-73)  
17 show cable and telephone attachments that violate various pole attachment rules, including  
18 the rules established by the NESC.

19 Q. Please describe the effect that any of these bad pole attachment practices by cable and  
20 telephone attachers have had on your EMC.

21 A. By Mr. Smith: By way of example, in October 2007, Sumter EMC discovered that an  
22 existing cable system in Cusseta, Georgia had been sold by Charter to Georgia Broadband.

## PUBLIC DISCLOSURE DOCUMENT

1 The cable system was found to be violating many NESC rules and presented potential  
2 hazards to electrical line workers, communications line workers, and the public. After  
3 purchasing the system, Georgia Broadband turned off service on the system. For several  
4 months Sumter EMC tried to contact Georgia Broadband to negotiate a new license  
5 agreement. However, after Sumter EMC's many attempts failed, Sumter EMC removed  
6 the facilities to protect the public safety and to protect the safety, integrity and reliability  
7 of Sumter EMC's electrical distribution system. It cost Sumter EMC \$58,176.82 to have a  
8 qualified electrical contractor remove the abandoned attachments, including associated  
9 guy-wires and anchors, on approximately 855 Sumter EMC poles. In addition, Sumter  
10 EMC was owed \$16,741.01 in unpaid pole attachment rentals for 2007 and \$13,184.10 in  
11 unpaid pole attachment rentals for part of 2008. In total, Sumter EMC incurred costs  
12 totaling \$88,124.93 for the period 2007-2009. Charter eventually paid Sumter EMC  
13 \$45,000 as reimbursement for a portion of the costs Sumter EMC incurred. However,  
14 Sumter EMC never recovered the remaining \$43,124.92 and this amount does not include  
15 additional legal and administrative expenses also incurred by Sumter EMC as a result of  
16 this incident.

17 In addition to the costs associated with the above-described abandoned cable  
18 system, Sumter EMC has experienced significant power outages during the more than three  
19 decades I have been employed by Sumter EMC. As an example, Sumter EMC has had  
20 extended power outages affecting the City of Cusseta because telephone company cables  
21 did not have sufficient height over a U.S. highway. In two instances, a pole carrying our  
22 three-phase 25kV power line was broken after a truck caught the telephone cable. The root

## PUBLIC DISCLOSURE DOCUMENT

1 cause of these two failures was inadequate guying and anchoring by the telephone  
2 company.

3 From my early years as a beginning engineer working nights with lineman making  
4 repairs, through the next 30 years of my career as a manager and lead engineer, I have  
5 observed on Sumter EMC's system as well as the systems of other Georgia EMCs the  
6 increased maintenance and repair costs, the safety hazards and the reliability issues created  
7 by telephone and cable attachments on EMC owned poles.

8 **A.** By Mr. Diamond: Bad pole attachment practices by cable and telephone companies have  
9 had significant effects on Flint EMC's system. Flint EMC has experienced power outages  
10 that last several hours at a time. Flint EMC line workers have been in situations where they  
11 cannot safely climb a Flint EMC pole because communications attachments have not been  
12 placed properly. In addition, Flint EMC has incurred many costs associated with improper  
13 attachments made by cable and telephone companies on Flint EMC poles. The bottom line  
14 is that throughout my 37 years working with electric cooperatives, I continuously see cable  
15 and telephone companies violating the rules we described above. And these practices have  
16 and will continue to disrupt the reliability and integrity of Flint EMC's system.

17 **A.** By Mr. Brown: Several years ago, Hart EMC began placing new poles along an interstate  
18 in order to provide better reliability for its member-owners. However, the communications  
19 attachers, who had attachments on the old Hart EMC poles, refused to transfer their  
20 attachments. The communications attachers refused to transfer for so long that Hart EMC  
21 ended up having to cede ownership of its old poles to the communications attachers. After  
22 ceding ownership, a fire occurred under the communications cables of one of Hart EMC's

## PUBLIC DISCLOSURE DOCUMENT

1 old poles. Despite this, the communications attachers still would not remove their  
2 attachments. In fact, following the fire, the communications attachers began attaching to  
3 Hart EMC's new poles without first removing their old attachments. This is just one of the  
4 many examples where cable and telephone company attachments have disrupted the  
5 reliability and integrity of Hart EMC's system and caused Hart EMC to incur additional  
6 costs.

7 **A.** By Mr. Arant: In 2016, a deactivated Charter cable that was attached to a Central Georgia  
8 EMC pole located along the side of Bill Gardner Parkway in Locust Grove, Georgia fell to  
9 the ground. Charter did not subsequently remove its attachment from the Central Georgia  
10 EMC pole. Rather, Charter knowingly left the deactivated line attached and laying on the  
11 side of Bill Gardner Parkway. Charter's cable facilities remained on the side of Bill  
12 Gardner Parkway for so long that the cables became completely covered by grass. When  
13 a right-of-way mowing crew later passed through the area, the Charter cable, which was  
14 still attached to the Central Georgia EMC pole, got entangled in the mower. The mower  
15 flung the cable into Central Georgia EMC's distribution conductor. This caused a large  
16 power outage that effected 546 of Central Georgia EMC's member-owners. It also put the  
17 individual that was operating the mowing equipment at risk of sustaining a serious injury.  
18 What is by far most concerning, however, is that when Charter was notified about what  
19 happened they admitted to knowing and not having removed the downed cable. It goes  
20 without saying, that such conduct is unacceptable and violates the many standards that  
21 govern the electric and communications industry.

## PUBLIC DISCLOSURE DOCUMENT

1 **Q. Why do you believe cable and telephone attachers commit so many violations when**  
2 **they install pole attachments on Georgia EMC poles?**

3 **A. By the Panel:** It is our opinion that cable and telephone company employees and contractors  
4 are not trained on how to properly attach to electrical utility poles. In fact, in most instances  
5 telephone and cable attachers do not know the NESC requirements and thus do not know  
6 how to install attachments that comply with NESC's requirements. Telephone and cable  
7 companies are also not investing the time or the money to train their attachers. As a result,  
8 these companies are compromising the safety, reliability, and integrity of the electrical  
9 distribution systems owned by the Georgia EMCs.

10 **VIII. CONCLUSION**

11 **Q. Does this conclude your testimony?**

12 **A. By the Panel:** Yes.