COMMISSIONERS

TRICIA PRIDEMORE , Chairman
TIM G. ECHOLS , Vice-Chairman
FITZ JOHNSON
LAUREN "BUBBA" McDONALD
JASON SHAW

FILED
DEC 02 2022
EXECUTIVE SECRETARY
G.P.S.C.

REECE McALISTER
EXECUTIVE DIRECTOR

MICHELLE THEBERT
FACILITIES PROTECTION UNIT DIRECTOR

Georgia Public Service Commission

(404) 463-6526
(800) 282-5813

244 Washington Street, SW
Atlanta, GA 30334-5701

FAX: (404) 463-6532
psc.ga.gov

Docket No. 37029

DOCKET# 37029
DOCUMENT# 192281

City of Buford Gas System
2300 Buford Highway
Buford, GA 30518

REF: Methane Emission Plan Inspection # JH22-004

☐ Certified Mail ☐ Regular Mail ☒ Email

Attention: Mr. Bryan Kerlin

On September 14, 2022, a representative of the Georgia Public Service Commission Pipeline/Facilities Safety Office conducted an inspection of your gas system. The enclosed inspection report numbered JH22-004 is provided for your information and file.

In conjunction with this inspection report, Staff has recommended the following enforcement(s):

Enforcement Action:

- ☐ Notice of Probable Violation
- ☐ Notice of Probable Violation with Proposed Civil Penalty
- ☐ Notice of Amendment

Enforcement Letter:

- ☐ Warning Letter
- ☐ Letter of Concern

Enforcement Notification:

- ☐ Observed Issue
- ☒ No Violation

Please review and respond to this report in accordance with the attached Instructions for Responding to Enforcement Actions, Enforcement Letters, and Notifications Issued by the Georgia Public Service Commission. Please refer to Docket No. 37029 in your response.

Please let me know if there are any questions concerning this report at (404) 463-6526 or michellet@psc.state.ga.us. Thank you for your continuing contribution toward increased pipeline safety.

Sincerely,

Michelle Thebert

Michelle L. Thebert
Director, Office of Pipeline Safety/Facilities Protection

COMMISSIONERS

TRICIA PRIDEMORE , Chairman
TIM G. ECHOLS , Vice-Chairman
FITZ JOHNSON
LAUREN "BUBBA" McDONALD
JASON SHAW

REECE McALISTER
EXECUTIVE DIRECTOR

MICHELLE THEBERT
FACILITIES PROTECTION UNIT DIRECTOR

Georgia Public Service Commission

(404) 463-6526
(800) 282-5813

244 Washington Street, SW
Atlanta, GA 30334-5701

FAX: (404) 463-6532
psc.ga.gov

REPORT OF NATURAL GAS SAFETY

INSPECTION NO: JH22-004

OPERATOR: City of Buford Gas System

INVESTIGATOR: Jack Hewitt

INSPECTION DATE: September 14, 2022 REPORT MAILED DATE: November 30, 2022

Any questions concerning this report may be directed to the above address or by telephoning (404) 463-6526.

1. PURPOSE OF INSPECTION

To perform an inspection of the Operator's methane emission reduction plan for compliance with the Congressional mandate of Section 114 of the Protecting Our Infrastructure of Pipelines and Enhancing Safety (PIPES) Act of 2020.

2. CONTINUING VIOLATIONS

3. CLEARED VIOLATIONS

4. NEW VIOLATIONS

5. OTHER RECOMMENDATIONS/COMMENTS

On 9/15/2022 Staff reported to the City of Buford to perform an inspection of The City of Buford's Methane Emissions Plan for compliance with The Protecting Our Infrastructure of Pipelines and Enhancing Safety (PIPES) Act of 2020.

During this inspection, the Operator was represented by:
Jason Higgins – Natural Gas Compliance Director
Bruce Bagnasco- Consultant- MGAG/SRCS
Tim Franklin- Consultant- MGAG/SRCS

Commission Staff was represented by Jack Hewitt, Lead Inspector.

NO VIOLATIONS FOUND

49CFR §192.603 General
(c) The Associate Administrator or the State Agency that has submitted a current certification under the pipeline safety laws, (49 U.S.C. 60101 et seq.) with respect to the pipeline facility governed by an operator's plans and procedures may, after notice and opportunity for hearing as provided in 49 CFR 190.206 or the relevant State procedures, require the operator to amend its plans and procedures as necessary to provide a reasonable level of safety.

STAFFS COMMENTS: The Protecting Our Infrastructure of Pipelines and Enhancing Safety (PIPES) Act of 2020 was signed on December 27, 2020. This statute contains a self-executing mandate requiring operators to update their inspection and maintenance plans to address eliminating hazardous leaks and minimizing releases of natural gas (including intentional venting during normal operations) from their pipeline facilities. Operators must also revise their plans to address the replacement or remediation of pipeline facilities that are known to leak based on their material, design, or past operating and maintenance history.

Section 114 of the Protecting our Infrastructure of Pipelines and Enhancing Safety Act of 2020, Public Law No. 116-260 (Act) requires operators, by December 27, 2021, to update the inspection and maintenance plan required under section 60108(a) to address the elements described in the amendments to that section outlined below:

- Section 60108(a)(2)(D) - the extent to which the plan will contribute to — (i) public safety; (ii) eliminating hazardous leaks and minimizing releases of natural gas from pipeline facilities; and (iii) the protection of the environment; and

- Section 60108(a)(2)(E) - the extent to which the plan addresses the replacement or remediation of pipelines that are known to leak based on the material (including cast iron, unprotected steel, wrought iron, and historic plastics with known issues), design, or past operating and maintenance history of the pipeline.

During this inspection (JH22-014), Staff examined the City of Buford's Methane Emissions Mitigation Plan and documented the findings on the Form 27- section 114 inspection form, ten years of leak history by cause (if chart is not included in data base then there were no leaks by cause), five years of PHMSA 7100. Reports, mitigation action plan, lost and unaccounted for gas, list of regulator stations, procedures for purging, regulator inspection, gas leak surveys, right-of-way patrolling.

As a result of this inspection Staff noted no probable violations of the minimum federal safety standards.

Please review and respond to this report in accordance with the attached Instructions for Responding to Enforcement Letters Issued by the Georgia Public Service Commission.

OPERATOR RESPONSE FORM

Operator Name: CITY OF BUFORD GAS SYSTEM

Informal Conference Requested: Yes ☐ No ☐

Docket Number: 37029

Responses required within **30 days of electronic mail.** Provide the following information for this report:

Response to Inspection Number:_____

Type of Enforcement Action(s) cited in report:			Informal Conference Requested	
☐ Notice of Probable Violation (NOPV)	☐ New	☐Continuing	☐ Yes	☐ No
☐ Notice of Amendment (NOA)	☐ New	☐Continuing	☐ Yes	☐ No
☐ Warning Letter	☐ New	☐Continuing	☐ Yes	☐ No
☐ Letter of Concern	☐ New	☐Continuing	☐ Yes	☐ No
☐ Observed Issue	☐ New	☐Continuing	☐ Yes	☐ No
☐ Proposed Civil Penalty	$_____ PCP $ Amount (Total for report)			

Indicate below (A-E) based on the type of Enforcement Actions in this report: (Check all that apply)
Complete a separate copy of Page 2, Operator Response to Enforcement Action, for each cited item.

A. Response for **Notice of Probable Violation** (with and without proposed civil penalty):
   1. ☐ Written statement indicating that corrective measures have achieved Compliance or
   2. ☐ Written plan of action outlining the corrective measures that will be taken to achieve compliance and when compliance is anticipated.

B. Response for **NOA**:
   1. ☐ Contested: Attach written explanation, information, or other material in answer to the allegations in the Notice of Amendment stating your reasons for objecting to the NOA, in whole or in part; or
   2. ☐ Not Contested: Explanation, information, or other material believed to warrant modification of the NOA in whole or in part; or
   3. ☐ Written request for clarification. (Attached)

C. Response for **Continuing** and/or **Existing** violations:
   Current status, updates, expected completion dates, proposed modifications, etc., of the continuing and/or existing violations, even if this information was previously provided. Referencing a previously filed response letter, as status, updates, etc. alone is not sufficient for this response. Failure to provide this information may result in formal interrogatories from the Director through data requests.

D. Response for ☐ **Letter of Concern** / ☐ **Warning Letter**
   I acknowledge receipt of the Letter of Concern/Warning Letter:_____
   SIGNATURE / TITLE

   Additional Comments: (Optional)_____

E. Response for **Observed Issue** and **No Violation**: (Optional Response)
   Staff requests that the Operator acknowledge receipt of the Observed Issue/No Violation in writing, or by submitting an email to the FPU Director

Operator Response to Enforcement Action

Enforcement Action for:_____ ☐ New Violation ☐ Continuing Violation
Enter Code / Commission Rule (Complete a separate attachment for each enforcement action)

Enforcement Action(s) cited in report:	Conference Requested:	
☐ Notice of Probable Violation (NOPV)	☐ Yes ☐ No	$_____ Proposed Penalty for this violation
☐ Notice of Amendment (NOA)	☐ Yes ☐ No	
☐ Warning Letter	☐ Yes ☐ No	
☐ Letter of Concern	☐ Yes ☐ No	
☐ Observed Issue	☐ Yes ☐ No	
☐ Proposed Civil Penalty	☐ Yes ☐ No	

OPERATORS RESPONSE: _____

_____

_____

_____

_____

_____

_____

_____

Response Provided by: _____ Date:_____
Name / Title

Internal use only:

Lead Inspector: _____ Date Response Reviewed:_____

Actions Acceptable: ☐ Yes ☐No Re-inspection Needed:☐ Yes ☐ No Clear Violation:☐ Yes ☐ No

_____

Supervisor Review by:_____ Date Reviewed:_____

Additional Enforcement Recommended: ☐ Yes ☐ No

_____

Director Review

Approved: ☐ Yes ☐No Schedule Special Follow-up Inspection: ☐ Yes ☐ No

Cleared Violation: ☐ Yes ☐ No

Comments:_____

_____

Filings:
For all written responses or any other official correspondence, the Operator shall file the response at the following address:

Ms. Sallie Tanner, Executive Secretary
Georgia Public Service Commission
244 Washington Street, SW
Atlanta, Georgia 30334

The Operator must file **five (5)** copies of any response and/or official correspondence, as well as a CD with an electronic version of the response in Microsoft Word and/or a PDF, if applicable.

Informal Conference:
Any Operator who chooses to request an informal conference shall request such a conference through emailing the Director (michellet@psc.state.ga.us), calling the Director (404-463-2765), or selecting the "Request Conference" choice.

Civil Penalty Payments:
Certified check for the full amount of the recommended civil penalty or consent agreement amount made payable to the Georgia Public Service Commission. The Operator's name, applicable Docket No., and Inspection Report No. must be included on the certified check. Mail payment to:

Ms. Michelle Thebert, Director, Facilities Protection Unit
Georgia Public Service Commission
244 Washington Street
Atlanta, Georgia 30334

Hearing Requests:
The Operator has the right to request a hearing before the full Commission to contest the alleged probable violations, recommended civil penalties, and all other proposed actions of enforcement. A request for a hearing must be submitted in writing and in accordance with Commission Rule 515-2-1-.04. The Operator must include a statement of the issues that you intend to raise at the hearing. The issues may relate to the allegations, new information, proposed compliance order, proposed civil penalty, or any other recommendation for enforcement action. Please refer to Commission Rule 515-9-3-.11 and O.C.G.A. § 46-2-91 for assessment considerations upon which civil penalties are based. An operator's failure to specify an issue may result in a waiver of the right to raise that issue at hearing. The request must also indicate whether or not the Operator will be represented by counsel at the hearing.

Open Records and Trade Secret Filings:
The Operator is advised that any material provided to the Commission, and all materials prepared by the Commission, including the Notice of Probable Violations and any Orders issued in this case, may be considered public information and subject to disclosure under the Georgia Open Records Act (O.C.G.A. § 50-18-70 et seq.). If you believe that any portion of your response material is security sensitive, privileged, confidential or may cause your company competitive disadvantages and would qualify for protection under the Commission's "Trade Secret Rule" (Commission Rule 515-3-1-.11), you must, along with the complete original document clearly marked "TRADE SECRET" on each page, provide a second copy of the document with the portions you believe qualify for trade secret treatment redacted, and an explanation of why you believe the redacted information qualifies for such trade secret treatment. Should the Commission receive a request for disclosure of any "TRADE SECRET" material, you will be notified, if after review, the materials and your provided justification are deemed not to meet any exemptions provided in the Georgia Open Records Act. You may appeal the Commission's decision to release material at that time. Your appeal will stay the release of those materials until a final decision is made.

BEFORE THE GEORGIA PUBLIC SERVICE COMMISSION
STATE OF GEORGIA

IN THE MATTER OF:	)	
	)	
No Violation Report	)	**DOCKET NO. 37029**
City of Buford Gas System	)	
Inspection JH22-004 on September 14, 2022	)	
	)	

CERTIFICATE OF SERVICE

I, the undersigned, do hereby certify that I have caused to be served a copy of the foregoing, and a copy of same was served upon all parties and persons listed below via electronic mail as indicated by an asterisk I further certify that the *City of Buford Gas System* was served a hard copy of the above-stated document by U.S. Mail, certified/return receipt requested.

*Sallie Tanner, Executive Secretary
Georgia Public Service Commission
244 Washington Street, SW
Atlanta, GA 30334

*Bryan Kerlin, City Manager
City of Buford Gas System
2300 Buford Highway
Buford, GA 30518
bkerlin@cityofbuford.com

*Michelle Thebert, Facilities Protection Unit Director
Georgia Public Service Commission
244 Washington Street, SW
Atlanta, GA 30334

Respectfully Submitted this 7th day of December 2022:

Cathy Nesbitt

Cathy Nesbitt, Administrative Assistant
Georgia Public Service Commission
Facilities Protection Unit
244 Washington Street, SW
Atlanta, GA 30334