

COMMISSIONERS

TRICIA PRIDEMORE , Chairman
TIM G. ECHOLS , Vice-Chairman
FITZ JOHNSON
LAUREN "BUBBA" McDONALD
JASON SHAW

FILED

FEB 01 2023

EXECUTIVE SECRETARY
G.P.S.C.



REECE McALISTER
EXECUTIVE DIRECTOR

MICHELLE THEBERT
FACILITIES PROTECTION UNIT DIRECTOR


Georgia Public Service Commission

(404) 463-6526
(800) 282-5813

244 Washington Street, SW
Atlanta, GA 30334-5701

FAX: (404) 463-6532
psc.ga.gov

Docket No. 37066



City of Lumpkin Gas Department
P. O. Box 278
522 MLK Jr. Drive
Lumpkin, GA 31815
DELIVERED VIA E-MAIL

RE: Inspection Report JJ22-021

Dear Ms. Anne Holloway -

Based on review of City of Lumpkin Gas Department's response, discussions with Pipeline Safety Staff and/or Operator, and/or any additional information provided for Inspection Report JJ21-050, I have cleared the following Enforcement Actions:

Violation	Description	Inspection#
192.181(b)	Each regulator station controlling the flow or pressure of gas in a distribution system must have...	JJ21-050

Any new or continuing Enforcement Action(s) not listed above will be addressed during the Operator's future inspection. No action is required by City of Lumpkin Gas Department at this time.

Please let me know if there are any questions or concerns regarding this correspondence at (404) 985-4271 or mthebert@psc.ga.gov. Thank you for your continuing contribution toward increased pipeline safety.

Sincerely,

Michelle Thebert
Director, Office of Pipeline/Facilities Safety

COMMISSIONERS

TRICIA PRIDEMORE , Chairman
TIM G. ECHOLS , Vice-Chairman
FITZ JOHNSON
LAUREN "BUBBA" McDONALD
JASON SHAW



REECE McALISTER
EXECUTIVE DIRECTOR

MICHELLE THEBERT
FACILITIES PROTECTION UNIT DIRECTOR

Georgia Public Service Commission

(404) 463-6526
(800) 282-5813

244 Washington Street, SW
Atlanta, GA 30334-5701

FAX: (404) 463-6532
psc.ga.gov

REPORT OF NATURAL GAS SAFETY

INSPECTION NO: JJ22-021

OPERATOR: City of Lumpkin Gas Department

INVESTIGATOR: Joe Jones

INSPECTION DATE: April 11, 2022

REPORT MAILED DATE: January 31, 2023

Any questions concerning this report may be directed to the above address or by telephoning (404) 463-6526.

1. PURPOSE OF INSPECTION

To conduct a review of the Operators previously existing probable violations.

2. CONTINUING VIOLATIONS

Violation	Description	Inspection#	Date
192.455	External corrosion control: Buried or submerged pipelines installed after July 31	LB10-047	5/4/2010
Consent Agreement Pending	Operator is negotiating Consent Agreement with the FPU Director	JS18-001	1/23/2018
192.453	General.	JJ21-050	10/19/2021
192.605(a)	Each operator shall prepare and follow for each pipeline, a manual of written procedures for...	JJ21-050	10/19/2021
192.615(c)	Each operator shall establish and maintain liaison with appropriate fire, police, and other...	JJ21-050	10/19/2021
192.603(b)	Each operator shall keep records necessary to administer the procedures established under §192.605.	JJ21-050	10/19/2021
192.805(b)	Ensure through evaluation that individuals performing covered tasks are qualified.	JJ21-050	10/19/2021
192.467(c)	Except for unprotected copper inserted in a ferrous pipe, each pipeline must be electrically...	JJ21-050	10/19/2021
192.481(c)	If atmospheric corrosion is found during an inspection, the operator must provide protection...	JJ21-050	10/19/2021

3. CLEARED VIOLATIONS

Cleared on 4/11/2022

Violation	Description	Inspection#	Date
192.181(b)	Each regulator station controlling the flow or pressure of gas in a distribution system must have...	JJ21-050	10/19/2021

4. NEW VIOLATIONS

5. OTHER RECOMMENDATIONS/COMMENTS

SEE ATTACHED REVIEW OF OPERATOR RESPONSE

BEFORE THE GEORGIA PUBLIC SERVICE COMMISSION
STATE OF GEORGIA

IN THE MATTER OF:)
)
Cleared Violation Report) DOCKET NO. 37066
City of Lumpkin Gas Department)
Inspection JJ22-021 on April 11, 2022)
)

CERTIFICATE OF SERVICE

I, the undersigned, do hereby certify that I have caused to be served a copy of the foregoing, and a copy of same was served upon all parties and persons listed below via electronic mail as indicated by an asterisk I further certify that the *City of Lumpkin Gas Department* was served a hard copy of the above-stated document by U.S. Mail, certified/return receipt requested.

*Sallie Tanner, Executive Secretary
Georgia Public Service Commission
244 Washington Street, SW
Atlanta, GA 30334

*Anne Holloway, City Manager
City of Lumpkin Gas Department
P.O. Box 278
522 MLK Jr. Drive
Lumpkin, GA 31815
lumpkincity@bellsouth.net

*Michelle Thebert, Facilities Protection Unit Director
Georgia Public Service Commission
244 Washington Street, SW
Atlanta, GA 30334

Respectfully Submitted this 7th day of February 2023:



Cathy Nesbitt, Administrative Assistant
Georgia Public Service Commission
Facilities Protection Unit
244 Washington Street, SW
Atlanta, GA 30334