COMMISSIONERS

TRICIA PRIDEMORE , Chairman
TIM G. ECHOLS , Vice-Chairman
FITZ JOHNSON
LAUREN "BUBBA" McDONALD
JASON SHAW

FILED
MAY 01 2023
EXECUTIVE SECRETARY
G.P.S.C.

REECE McALISTER
EXECUTIVE DIRECTOR

MICHELLE THEBERT
FACILITIES PROTECTION UNIT DIRECTOR

Georgia Public Service Commission

(404) 463-6526
(800) 282-5813

244 Washington Street, SW
Atlanta, GA 30334-5701

FAX: (404) 463-6532
psc.ga.gov

Docket No. 37061

DOCKET# 37061
DOCUMENT# 194278

City of LaFayette Utilities
PO Box 89
LaFayette, GA 30728
DELIVERED VIA E-MAIL

RE: Inspection Report JS23-002

Dear Mr. David Hamilton -

Based on review of City of LaFayette Utilities's response, discussions with Pipeline Safety Staff and/or Operator, and/or any additional information provided for Inspection Report JS20-012, I have cleared the following Enforcement Actions:

Violation	Description	Inspection#
192.1007(f)	Periodic Evaluation and Improvement.	JS20-012

Any new or continuing Enforcement Action(s) not listed above will be addressed during the Operator's future inspection. No action is required by City of LaFayette Utilities at this time.

Please let me know if there are any questions or concerns regarding this correspondence at (404) 985-4271 or mthebert@psc.ga.gov. Thank you for your continuing contribution toward increased pipeline safety.

Sincerely,

Michelle Thebert
Director, Office of Pipeline/Facilities Safety

COMMISSIONERS

TRICIA PRIDEMORE , Chairman
TIM G. ECHOLS , Vice-Chairman
FITZ JOHNSON
LAUREN "BUBBA" McDONALD
JASON SHAW

REECE McALISTER
EXECUTIVE DIRECTOR

MICHELLE THEBERT
FACILITIES PROTECTION UNIT DIRECTOR

Georgia Public Service Commission

(404) 463-6526
(800) 282-5813

244 Washington Street, SW
Atlanta, GA 30334-5701

FAX: (404) 463-6532
psc.ga.gov

REPORT OF NATURAL GAS SAFETY

INSPECTION NO: JS23-002

OPERATOR: City of LaFayette Utilities

INVESTIGATOR: Jason Smith

INSPECTION DATE: January 18, 2023 REPORT MAILED DATE: April 27, 2023

Any questions concerning this report may be directed to the above address or by telephoning (404) 463-6526.

1. PURPOSE OF INSPECTION

To review the Operator's submitted response to inspection #DJ22-042.

2. CONTINUING VIOLATIONS

Violation	Description	Inspection#	Date
192.465(d)	Each operator shall take prompt remedial action to correct any deficiencies indicated by the...	JS19-013	3/25/2019
192.619(a)	No person may operate a segment of steel or plastic pipeline at a pressure that exceeds a maximum...	JS19-013	3/25/2019
192.553(a)(1)	At the end of each incremental increase, the pressure must be held constant while the entire...	JS19-013	3/25/2019
192.557(b)(1)	Before increasing operating pressure above the previously established maximum allowable operating...	JS19-013	3/25/2019
192.467(c)	Except for unprotected copper inserted in a ferrous pipe, each pipeline must be electrically...	JS19-013	3/25/2019
192.553(b)	Records. Each operator who uprates a segment of pipeline shall retain for the life of the segment...	JS19-013	3/25/2019
192.553(d)	Limitation on increase in maximum allowable operating pressure. Except as provided in §192.555(c)...	JS19-013	3/25/2019
199.241	Training for supervisors.	AT19-039	10/17/2019
199.105(c)(6)	The operator shall randomly select a sufficient number of covered employees for testing during...	AT19-039	10/17/2019
199.113(c)	Supervisory Personnel Training (Drug)	AT19-039	10/17/2019
192.605(a)	Each operator shall prepare and follow for each pipeline, a manual of written procedures for...	AT22-016	5/9/2022

3. CLEARED VIOLATIONS

Cleared on 1/18/2023

Violation	Description	Inspection#	Date
192.1007(f)	Periodic Evaluation and Improvement.	JS20-012	3/11/2020

4. NEW VIOLATIONS

5. OTHER RECOMMENDATIONS/COMMENTS

Report to File Only after sending Existing Violations Cleared Continuing letter by email.

192.1007(f) cleared / all other continuing

BEFORE THE GEORGIA PUBLIC SERVICE COMMISSION
STATE OF GEORGIA

IN THE MATTER OF:	)	
	)	
Cleared Violation Letter	)	**DOCKET NO. 37061**
City of LaFayette Utilities	)	
Inspection JS23-002 on January 18, 2023	)	
	)	

CERTIFICATE OF SERVICE

I, the undersigned, do hereby certify that I have caused to be served a copy of the foregoing, and a copy of same was served upon all parties and persons listed below via electronic mail as indicated by an asterisk. I further certify that the *City of LaFayette Utilities* was served a hard copy of the above-stated document by U.S. Mail, certified/return receipt requested.

*Sallie Tanner, Executive Secretary
Georgia Public Service Commission
244 Washington Street, SW
Atlanta, GA 30334

*David Hamilton, City Manager
City of LaFayette Utilities
P.O. Box 89
LaFayette, GA 30728
dhamilton@cityoflafayettega.org

*Michelle Thebert, Facilities Protection Unit Director
Georgia Public Service Commission
244 Washington Street, SW
Atlanta, GA 30334

Respectfully Submitted this 2nd day of May 2023:

Cathy Nesbitt

Cathy Nesbitt, Administrative Assistant
Georgia Public Service Commission
Facilities Protection Unit
244 Washington Street, SW
Atlanta, GA 30334