COMMISSIONERS

JASON SHAW , Chairman
TIM G. ECHOLS , Vice-Chairman
FITZ JOHNSON
LAUREN "BUBBA" McDONALD
TRICIA PRIDEMORE

FILED
JAN 24 2024
EXECUTIVE SECRETARY
G.P.S.C.

REECE McALISTER
EXECUTIVE DIRECTOR

MICHELLE THEBERT
FACILITIES PROTECTION UNIT DIRECTOR

Georgia Public Service Commission

(404) 463-6526
(800) 282-5813

244 Washington Street, SW
Atlanta, GA 30334-5701

FAX: (404) 463-6532
psc.ga.gov

Docket No. 37092

DOCKET# 37092
DOCUMENT# 217165

City of Toccoa Natural Gas Department
(Distribution)
92 N. Alexander St
PO Box 579
Toccoa, GA 30577
DELIVERED VIA E-MAIL

RE: Inspection Report DJ23-017

Dear Mr. William Morse -

Based on review of City of Toccoa Natural Gas Department (Distribution)'s response, discussions with Pipeline Safety Staff and/or Operator, and/or any additional information provided for Inspection Report DJ22-028, I have cleared the following Enforcement Actions:

Violation	Description	Inspection#
192.603(c)	General - The Associate Administrator or the State Agency that has submitted a current...	DJ22-028

Any new or continuing Enforcement Action(s) not listed above will be addressed during the Operator's future inspection. No action is required by City of Toccoa Natural Gas Department (Distribution) at this time.

Please let me know if there are any questions or concerns regarding this correspondence at (404) 985-4271 or mthebert@psc.ga.gov. Thank you for your continuing contribution toward increased pipeline safety.

Sincerely,

Michelle Thebert
Director, Office of Pipeline/Facilities Safety

COMMISSIONERS

JASON SHAW , Chairman
TIM G. ECHOLS , Vice-Chairman
FITZ JOHNSON
LAUREN "BUBBA" McDONALD
TRICIA PRIDEMORE

REECE McALISTER
EXECUTIVE DIRECTOR

MICHELLE THEBERT
FACILITIES PROTECTION UNIT DIRECTOR

Georgia Public Service Commission

(404) 463-6526
(800) 282-5813

244 Washington Street, SW
Atlanta, GA 30334-5701

FAX: (404) 463-6532
psc.ga.gov

REPORT OF NATURAL GAS SAFETY

INSPECTION NO: DJ23-017

OPERATOR: City of Toccoa Natural Gas Department (Distribution)

INVESTIGATOR: Daphne Jones

INSPECTION DATE: April 11, 2023 REPORT MAILED DATE: January 10, 2024

Any questions concerning this report may be directed to the above address or by telephoning (404) 463-6526.

1. PURPOSE OF INSPECTION

To conduct a review of the Operator's response of the Operators previously existing probable violations.

2. CONTINUING VIOLATIONS

Violation	Description	Inspection#	Date
192.619(a)	No person may operate a segment of steel or plastic pipeline at a pressure that exceeds a maximum...	AT18-022	6/11/2018
192.181(b)	Each regulator station controlling the flow or pressure of gas in a distribution system must have...	AT18-022	6/11/2018
Consent Agreement Pending	Operator is negotiating Consent Agreement with the FPU Director	JJ19-032	6/17/2019
Consent Agreement Pending	Operator is negotiating Consent Agreement with the FPU Director	DJ20-039	12/7/2020
192.605(a)	Each operator shall prepare and follow for each pipeline, a manual of written procedures for...	DJ21-038	10/4/2021
192.465(d)	Each operator shall take prompt remedial action to correct any deficiencies indicated by the...	DJ21-038	10/4/2021
192.467(a)	Each buried or submerged pipeline must be electrically isolated from other underground metallic...	DJ21-038	10/4/2021

3. CLEARED VIOLATIONS

Cleared on 4/11/2023

Violation	Description	Inspection#	Date
192.603(c)	General - The Associate Administrator or the State Agency that has submitted a current...	DJ22-028	6/21/2022

4. NEW VIOLATIONS

5. OTHER RECOMMENDATIONS/COMMENTS

FOR FILE ONLY AFTER CLEARING ENFORCEMENTS ACTION LETTER

BEFORE THE GEORGIA PUBLIC SERVICE COMMISSION
STATE OF GEORGIA

IN THE MATTER OF:	)	
	)	
Cleared Violation Report	)	**DOCKET NO. 37092**
City of Toccoa Natural Gas Department	)	
(Distribution)	)	
Inspection DJ23-017 on April 11, 2023	)	

CERTIFICATE OF SERVICE

I, the undersigned, do hereby certify that I have caused to be served a copy of the foregoing, and a copy of same was served upon all parties and persons listed below via electronic mail as indicated by an asterisk. I further certify that the *City of Toccoa Natural Gas Department* was served a hard copy of the above-stated document by U.S. Mail, certified/return receipt requested.

*Sallie Tanner, Executive Secretary
Georgia Public Service Commission
244 Washington Street, SW
Atlanta, GA 30334

*William Morse, City Manager
City of Toccoa Natural Gas
92 N. Alexander Street
P.O. Box 579
Toccoa, GA 30577
bmorse@cityoftoccoa.com

*Michelle Thebert, Facilities Protection Unit Director
Georgia Public Service Commission
244 Washington Street, SW
Atlanta, GA 30334

Respectfully Submitted this 31ST day of January 2024:

Cathy Nesbitt

Cathy Nesbitt, Administrative Assistant
Georgia Public Service Commission
Facilities Protection Unit
244 Washington Street, SW
Atlanta, GA 30334