COMMISSIONERS

JASON SHAW , Chairman
TIM G. ECHOLS , Vice-Chairman
FITZ JOHNSON
LAUREN "BUBBA" McDONALD
TRICIA PRIDEMORE

FILED
JAN 24 2024
EXECUTIVE SECRETARY
G.P.S.C.

REECE McALISTER
EXECUTIVE DIRECTOR

MICHELLE THEBERT
FACILITIES PROTECTION UNIT DIRECTOR

# Georgia Public Service Commission

(404) 463-6526
(800) 282-5813

244 Washington Street, SW
Atlanta, GA 30334-5701

FAX: (404) 463-6532
psc.ga.gov

Docket No. 37055

DOCKET# 37055
DOCUMENT# 217172

City of Grantville Gas System
123 LaGrange Street P. O. Box 160
Grantville, GA 30220
DELIVERED VIA E-MAIL

RE: Inspection Report AT23-021

Dear Mr. Al Grieshaber -

Based on review of City of Grantville Gas System's response, discussions with Pipeline Safety Staff and/or Operator, and/or any additional information provided for Inspection Report AT22-006, I have cleared the following Enforcement Actions:

| Violation | Description | Inspection# |
|---|---|---|
| 192.617 | Investigation of failures. | AT22-006 |

Any new or continuing Enforcement Action(s) not listed above will be addressed during the Operator's future inspection. No action is required by City of Grantville Gas System at this time.

Please let me know if there are any questions or concerns regarding this correspondence at (404) 985-4271 or mthebert@psc.ga.gov. Thank you for your continuing contribution toward increased pipeline safety.

Sincerely,

Michelle Thebert
Director, Office of Pipeline/Facilities Safety

COMMISSIONERS

JASON SHAW , Chairman
TIM G. ECHOLS , Vice-Chairman
FITZ JOHNSON
LAUREN "BUBBA" McDONALD
TRICIA PRIDEMORE

REECE McALISTER
EXECUTIVE DIRECTOR

MICHELLE THEBERT
FACILITIES PROTECTION UNIT DIRECTOR

# Georgia Public Service Commission

(404) 463-6526
(800) 282-5813

244 Washington Street, SW
Atlanta, GA 30334-5701

FAX: (404) 463-6532
psc.ga.gov

## REPORT OF NATURAL GAS SAFETY

INSPECTION NO: AT23-021

OPERATOR: City of Grantville Gas System

INVESTIGATOR: Alan Towe

INSPECTION DATE: March 9, 2023 REPORT MAILED DATE: January 10, 2024

Any questions concerning this report may be directed to the above address or by telephoning (404) 463-6526.

1. PURPOSE OF INSPECTION

To perform a review of the Operators response letter to the probable violations cited in inspection number AT22-006 for compliance with Part 192. of the pipeline safety regulations.

2. CONTINUING VIOLATIONS

| Violation | Description | Inspection# | Date |
|---|---|---|---|
| Consent Agreement Pending | Operator is negotiating Consent Agreement with the FPU Director | JL18-002 | 1/30/2018 |
| 192.605(a) | Each operator shall prepare and follow for each pipeline, a manual of written procedures for... | AT22-006 | 2/3/2022 |
| 192.615(b)(3) | Review employee activities to determine whether the procedures were effectively followed in each... | AT22-006 | 2/3/2022 |
| 192.605(b)(3) | Maintenance and normal operations. The manual required by paragraph (a) of this section must... | AT22-006 | 2/3/2022 |
| 192.615(a)(6) | Emergency shutdown and pressure reduction in any section of the operator's pipeline system neces... | AT22-006 | 2/3/2022 |
| 192.615(a)(4) | The availability of personnel, equipment, tools, and materials, as needed at the scene of an... | AT22-006 | 2/3/2022 |
| 192.807(b) | Records supporting an individual's current qualification shall be maintained while the individual... | AT22-006 | 2/3/2022 |

3. CLEARED VIOLATIONS

Cleared on 3/9/2023

| Violation | Description | Inspection# | Date |
|---|---|---|---|
| 192.617 | Investigation of failures. | AT22-006 | 2/3/2022 |

4. NEW VIOLATIONS

5. OTHER RECOMMENDATIONS/COMMENTS

FOR FILE ONLY AFTER CLEARING ENFORCEMENTS ACTIONS LETTER FOR 192.617

**BEFORE THE GEORGIA PUBLIC SERVICE COMMISSION**
**STATE OF GEORGIA**

| | | |
|---|---|---|
| **IN THE MATTER OF:** | ) | |
| | ) | |
| **Cleared Violation Report** | ) | **DOCKET NO. 37055** |
| **City of Grantville Gas System** | ) | |
| **Inspection AT23-021 on March 9, 2023** | ) | |
| | ) | |

## CERTIFICATE OF SERVICE

I, the undersigned, do hereby certify that I have caused to be served a copy of the foregoing, and a copy of same was served upon all parties and persons listed below via electronic mail as indicated by an asterisk I further certify that the *City of Grantville Gas System* was served a hard copy of the above-stated document by U.S. Mail, certified/return receipt requested.

*Sallie Tanner, Executive Secretary
Georgia Public Service Commission
244 Washington Street, SW
Atlanta, GA 30334

*Al Grieshaber, City Manager
City of Grantville Gas System
123 LaGrange Street
P.O. Box 160
Grantville, GA 30220
agrieshaber@grantvillega.org

*Michelle Thebert, Facilities Protection Unit Director
Georgia Public Service Commission
244 Washington Street, SW
Atlanta, GA 30334

Respectfully Submitted this 31st day of January 2023:

Cathy Nesbitt

Cathy Nesbitt, Administrative Assistant
Georgia Public Service Commission
Facilities Protection Unit
244 Washington Street, SW
Atlanta, GA 30334