

Amended MFR 1

**Atlanta Gas Light - Docket 43510
2024 Universal Service Fund
Facilities Expansion Plan
Minimum Filing Requirements**

Per Commission Rule 515-7-5-.07, the EDC shall include the following minimum filing requirements in its Annual USF Facilities Expansion Plan filing:

	<p>(a) A detailed written technical description of the project(s). The technical description will include, but not be limited to, a discussion of the type, size, and length of the proposed facilities and the proposed route and the community and/or company that will be served. The technical description will affirmatively state if a proposed approach main line-extension is new main or an extension or expansion of existing main as defined in 515-7-5-.01(j)(k). There will be a discussion of the type and size of main proposed to be replaced. The technical description will affirmatively state if the EDC is or is not certificated to serve in the counties where the facilities will be constructed.</p>
--	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

White County

This project proposes to serve a church building and other potential retail businesses in this area of Cleveland, Georgia.

AGL proposes to tie-into existing 4" plastic at the intersection of W Kytle Street and Bell Street and install approximately 1,175 feet of 4" plastic (MAOP 60 psi) to serve the church building. There is potential for further commercial infill along the proposed route.

Please see Attachment *MFR-4, Maps of Proposed Corridors White*. AGL is currently certificated to serve this area.

Cherokee County

This project proposes to serve the new Cherokee High School. There will be two meters at this location, one for the main school building and one for the athletic fieldhouse.

This project requires a pressure improvement to serve the new school. AGL proposes to upsize approximately 600 feet of 4" plastic on Riverstone Parkway between Milton Drive and Transit Avenue to 6" plastic (MAOP 60 psi), which requires installation of approximately 700 feet of 6" plastic to re-establish the feed to the existing MHP main along Riverstone Parkway. The pressure improvement also involves installation of approximately 50 feet of 2" plastic (MAOP 60 psi) to re-establish the feed to the MHP main on Milton Drive. AGL also proposes to tie-into existing 4" plastic on Bluff's Parkway and install approximately 495 feet of 4" plastic (MAOP 60 psi) along the new road approaching the school, and approximately 2,275 feet of 2" plastic (MAOP 60 psi) along MLK Drive to serve the school and fieldhouse.

Amended MFR 1

**Atlanta Gas Light - Docket 43510
2024 Universal Service Fund
Facilities Expansion Plan
Minimum Filing Requirements**

Please see Attachment *MFR-4, Maps of Proposed Corridors Cherokee*. AGL is currently certificated to serve this area.

Chatham County

This project proposes to serve the new Richmond Hill High School.

AGL proposes to tie-into what will be existing 6" plastic on Belfast Keller Road and extend that main by installing approximately 1,500 feet of 6" plastic (MAOP 60 psi) along Belfast Keller Road to serve the school. The main to be tied-into is currently proposed as part of a New Business line extension scheduled to be installed in 2024.

Please see Attachment *MFR-4, Maps of Proposed Corridors Chatham*. AGL is currently certificated to serve this area.