

MFR-7: Project Technical Analysis - Cherokee

Project Information						Proposed Load	Proposed Main Section 1					Proposed Main Section 2					
Project Name	Address	Location Code	Project Summary	Requested By	Date Requested	Load (MCFH)	Category	Size	Type	Wall Thickness	Length (ft)	Category	Size	Type	Wall Thickness	Length (ft)	Category
Cherokee High School 23COMM-3740-1500 DR MARTIN LUTHER KING JR BLVD CANTON GA 30114		3740	4" & 2" MHP PLS main extension with 6" MHP PLS main PRIM			46.818		6"	PLS		700		4"	PLS		495	

Note: Steel MAOP 300 psi, plastic MAOP 60 psi unless otherwise noted

Disclaimer

The attached estimate is for planning purposes only and cannot be used as a firm quotation from Atlanta Gas Light or our contractors. We will not be able to provide a firm quote until the project undergoes additional engineering and cost inform.

MFR-7: Project Technical Analysis - Cherokee

Proposed Main Section 3				Proposed Service 1				Proposed Service 2				Cost Estimate		Approvals			
Size	Type	Wall Thickness	Length (ft)	Size	Type	Wall Thickness	Length (ft)	Size	Type	Wall Thickness	Length (ft)	Grand Total	Accuracy	Mgr	Director	VP	EVP
2"	PLS		2275	1.25"	PLS		315'	4"	PLS		235	\$500,000	plus or minus 50%				

ation is solicited from our vendors thru our formal bid process. The costs provided are based on rule of thumb estimates, local knowledge, and/or past history as well as mapping technologies. Keep in

MFR 7: Project Technical Analysis - Athens/Clarke

Project Information						Proposed Load	Proposed Main Section 1					Proposed Service 1				Cost Estimate		Approvals			
Project Name	Address	Location Code	Project Summary	Requested By	Date Requested	Load (MCFH)	Category	Size	Type	Wall Thickness	Length (ft)	Size	Type	Wall Thickness	Length (ft)	Grand Total	Accuracy	Mgr	Director	VP	EVP
2780375-22NCV-3380-156 WILFORD ASH SR PKY CLEVELAND GA 30528		3380	4" MHP PLS main extension with 1.25" PLS service			1.36		4"	PLS		1,175	1.25"	PLS		205'	\$120,000	plus or minus 50%				

Note: Steel MAOP 300 psi, plastic MAOP 60 psi unless otherwise noted

Disclaimer

The attached estimate is for planning purposes only and cannot be used as a firm quotation from Atlanta Gas Light or our contractors. We will not be able to provide a firm quote until the project undergoes additional engineering and cost information is solicited from our vendors thru

Project Information				
Project Name	Address	Location Code	Project Summary	Requested By
Richmond Hill High School - USF		4970	Install 1,500' x 6" MHP PLS Main and 2,000' x 2" MHP PLS Service	
TOTAL				

**Note: Steel MAOP 300 psi, plastic MAOP 60 psi unless otherwise noted**

**Disclaimer**

The attached estimate is for planning purposes only and cannot be used as a firm quotation from Atlanta past history as well as mapping technologies. Keep in mind the estimated installation period can be dela

	Proposed Load	Proposed Main Section 1					Proposed Main S		
Date Requested	Load (MCFH)	Category	Size (inches)	Type	Wall Thickness	Length (ft)	Category	Size	Type
	14.2		6	PLS		1,500			

Gas Light or our contractors. We will not be able to provide a firm quote until the project undergoes additional permitting delays and undetected terrain features (boring through rock formations, water crossings,

Section 2		Proposed Main Section 3					Proposed Service			
Wall Thickness	Length (ft)	Category	Size	Type	Wall Thickness	Length (ft)	Size	Type	Wall Thickness	Length (ft)
							2	PLS		2,000

il engineering and cost information is solicited from our vendors thru our formal bid process. The costs p  
, etc.).

Cost Estimate		Approvals			
Grand Total	Accuracy	Mgr	Director	VP	SVP
\$335,268	Plus 20%/Minus 20%				

provided are based on rule of thumb estimates, local knowledge, and/or