Odorization Test Point Locations

192.625(f)

Test Station #	Location:	Date	Flow-Rator Reading	% Gas In Instrument - Effluent	Odor Intensity Code	Inspector
1	NE Reg Station	5/29/24	.82	.91	light, heavy	JB
2	518 3rd St. N.W.	5/29/24	.85	.94		JB
3	WOW Reg Station	5/29/24	.82	.93		JB
4	26 St. S.E. & 5th Ave. S.E.	5/29/24	.83	.95		JB
1	NE Reg Station	10/13/24	.86	.97		JB
2	518 3rd St. N.W.	10/13/24	.85	.98		JB
3	WOW Reg Station	10/13/24	.81	.93		JB
4	26 St. S.E. & 5th Ave. S.E.	10/13/24	.83	.95		JB
1	NE Reg Station	12/10/24	.85	.98		JB
2	518 3rd St. N.W.	12/10/24	.82	.93		JB
3	WOW Reg Station	12/10/24	.81	.98		JB
4	26 St. S.E. & 5th Ave. S.E.	12/10/24	.84	.93		JB
1	NE Reg Station	2/18/25	.85	.98		JB
2	518 3rd St. N.W.	2/18/25	.85	.96		JB
3	WOW Reg Station	2/18/25	.83	.99		JB
4	26 St. S.E. & 5th Ave. S.E.	2/18/25	.84	.93		JB
1	NE Reg Station					
2	518 3rd St. N.W.					
3	WOW Reg Station					
4	26 St. S.E. & 5th Ave. S.E.					

Odorization Test Point Locations
192.625(f)

Test Station #	Location:	Date	Flow-Rator Reading	% Gas In Instrument - Effluent	Odor Intensity Code	Inspector
1	NE Reg Station	12/15/23	.85	.97	Light Musty	JB
2	518 3rd St. N.W.	12/15/23	.85	.98		JB
3	WOW Reg Station	12/15/23	.83	.93		JB
4	26 St. S.E. & 5th Ave. S.E.	12/15/23	.84	.95		JB
1	NE Reg Station	2/23/24	.82	.91		JB
2	518 3rd St. N.W.	2/23/24	.85	.98		JB
3	WOW Reg Station	2/23/24	.87	.91		JB
4	26 St. S.E. & 5th Ave. S.E.	2/23/24	.85	.93		JB
1	NE Reg Station	4/12/24	.85	.98		JB
2	518 3rd St. N.W.	4/12/24	.85	.98		JB
3	WOW Reg Station	4/12/24	.83	.95		JB
4	26 St. S.E. & 5th Ave. S.E.	4/12/24	.84	.93		JB
1	NE Reg Station	6/7/24	.84	.92		JB
2	518 3rd St. N.W.	6/7/24	.85	.93		JB
3	WOW Reg Station	6/7/24	.82	.93		JB
4	26 St. S.E. & 5th Ave. S.E.	6/7/24	.80	.91		JB
1	NE Reg Station					JB
2	518 3rd St. N.W.					
3	WOW Reg Station					
4	26 St. S.E. & 5th Ave. S.E.					

Odorization Test Point Locations
192.625(f)

Test Station #	Location:	Date	Flow-Rator Reading	% Gas In Instrument - Effluent	Odor Intensity Code	Inspector
1	NE Reg Station	1-10-23	.86	.97	light heavy	JB/JH
2	518 3rd St. N.W.		.85	.98		
3	WOW Reg Station		.81	.93		
4	26 St. S.E. & 5th Ave. S.E.		.83	.95		
1	NE Reg Station	5-15-23	.85	.91		JB/JH
2	518 3rd St. N.W.		.84	.93		
3	WOW Reg Station		.79	.91		
4	26 St. S.E. & 5th Ave. S.E.		.82	.94		
1	NE Reg Station	7-10-23	.84	.93		JB/JH
2	518 3rd St. N.W.		.85	.98		
3	WOW Reg Station		.82	.93		
4	26 St. S.E. & 5th Ave. S.E.		.81	.92		
1	NE Reg Station	9-18-23	.85	.92		JB
2	518 3rd St. N.W.		.84	.93		
3	WOW Reg Station		.82	.93		
4	26 St. S.E. & 5th Ave. S.E.		.80	.91		
1	NE Reg Station	11-13-23	.85	.98		JB/JH
2	518 3rd St. N.W.		.85	.96		
3	WOW Reg Station		.83	.94		
4	26 St. S.E. & 5th Ave. S.E.		.84	.93		

Odorization Test Point Locations
192.625(f)

Test Station #	Location	Date	Flow-Rator Reading	% Gas In Instrument - Effluent	Odor Intensity Code	Inspector
1	NE Reg Station	6-23-2021	.95	.98	LIGHT / Heavy	CA / ZP
2	518 3rd St. N.W.	8-23-2021	.93	.99	L. / H.	CA / ZP
3	WOW Reg Station	8.23-2021	.92	.97	L. / H.	CA / ZP
4	26 St. S.E. & 5th Ave. S.E.	8-23-2021	.93	.95	L. / H.	CA / ZP
1	NE Reg Station	11-18-2021	.92	.95	LIGHT / Heavy	ZP / JB
2	518 3rd St. N.W.	11-18-2021	.91	.96	L. / H.	ZP / JB
3	WOW Reg Station	11-18-2021	.94	.98	L. / H.	ZP / JB
4	26 St. S.E. & 5th Ave. S.E.	11-18-2021	.95	.99	L. / H.	ZP / JB
1	NE Reg Station	2-23-2022	.94	.98	LIGHT / Heavy	RP / JB ZP
2	518 3rd St. N.W.	2-23-2022	.95	.97	L. / H.	RP / JB ZP
3	WOW Reg Station	2-23-2022	.92	.96	L. / H.	RP / JB ZP
4	26 St. S.E. & 5th Ave. S.E.	2-23-2022	.96	.98	L. / H.	RP / JB ZP
1	NE Reg Station	6-23-2022	.93	.99	L / H	ZP / JB
2	518 3rd St. N.W.	6-23-2022	.96	.98	L / H.	ZP / JB
3	WOW Reg Station	6-23-2022	.97	.96	L / H	ZP / JB
4	26 St. S.E. & 5th Ave. S.E.	6-23-2022	.95	.98	L / H	ZP / JB
1	NE Reg Station	9-7-2022	.92	.97	L / H	ZP / JB
2	518 3rd St. N.W.	9-7-2022	.95	.97	L / H	ZP / JB
3	WOW Reg Station	9-7-2022	.90	.94	L / H	ZP / JB
4	26 St. S.E. & 5th Ave. S.E.	9-7-2022	.93	.96	L / H	ZP / JB

Odorization Test Point Locations
192.625(f)

Test Station #	Location:	Date	Flow-Rator Reading	% Gas In Instrument - Effluent	Odor Intensity Code	Inspector
1	13 5th Ave N.E.	5/24/19	.93	.96	Light Heavy	CA / KH
2	518 3rd St. N.W.	5/24/19	.93	.97	" "	CA/KH
3	500 8th St. S.W.	5/24/19	.94	.95	" "	CA/KH
4	26 St. S.E. & 5th Ave. S.E.	5/24/19	.92	.98	" "	CA/KH
1	13 5th Ave N.E.	8/13/19	.91	.98	" "	CA/RP
2	518 3rd St. N.W.	8/13/19	.92	.97	" "	CA/RP
3	500 8th St. S.W.	8/13/19	.95	.99	" "	CA/RP
4	26 St. S.E. & 5th Ave. S.E.	8/13/19	.93	.97	" "	CA/RP
1	13 5th Ave N.E.	12/12/19	.92	.97	" "	CA/ZP
2	518 3rd St. N.W.	12/12/19	.94	.98	" "	CA/ZP
3	500 8th St. S.W.	12/12/19	.93	.98	" "	CA/ZP
4	26 St. S.E. & 5th Ave. S.E.	12/12/19	.96	.99	" "	CA/ZP
1	13 5th Ave N.E.	3/23/20	.98	1.00	" "	CA/ZP
2	518 3rd St. N.W.	3/23/20	.96	.99	" "	CA/ZP
3	~~500 8th St. S.W.~~ Wash Park	3/23/20	.92	.96	" "	CA/ZP
4	26 St. S.E. & 5th Ave. S.E.	3/23/20	.94	.98	" "	CA/ZP
1	13 5th Ave N.E.	6-5-20	.90	.98	" "	CA/ZP
2	518 3rd St. N.W.	6-5-20	.93	.96	" "	CA/ZP
3	500 8th St. S.W.	6-5-20	.93	.97	" "	CA/ZP
4	26 St. S.E. & 5th Ave. S.E.	6-5-20	.95	.98	" "	CA/ZP

Odorization Test Point Locations
192.625(f)

Test Station #	Location:	Date	Flow-Rator Reading	% Gas In Instrument - Effluent	Odor Intensity Code	Inspector
1	13 5th Ave N.E.	9/3/20	.93	.98	light/heavy	CA/JB
2	518 3rd St. N.W.	9/3/20	.92	.99	" "	CA/JB
3	500 8th St. S.W.	9/3/20	.94	.97	" "	CA/JB
4	26 St. S.E. & 5th Ave. S.E.	9/3/20	.96	.99	" "	CA/JB
1	13 5th Ave N.E.	11/3/20	.94	.99	" "	CA/ZP
2	518 3rd St. N.W.	11/3/20	.93	1.00	" "	CA
3	500 8th St. S.W.	11/3/20	.93	.99	" "	CA
4	26 St. S.E. & 5th Ave. S.E.	11/3/20	.92	1.02	" "	CA
1	13 5th Ave N.E.	2/26/21	.94	.98	" "	CA/JB
2	518 3rd St. N.W.	2/26/21	.92	.98	" "	CA/JB
3	500 8th St. S.W.	2/27/21	.94	.99	" "	CA
4	26 St. S.E. & 5th Ave. S.E.	2/27/21	.92	.98	" "	CA
1	13 5th Ave N.E.	5/5/21	.91	.98	" "	CA/ZP
2	518 3rd St. N.W.	5/5/21	.86	.94	" "	CA/ZP
3	500 8th St. S.W.	5/5/21	.88	.95	" "	CA/ZP
4	26 St. S.E. & 5th Ave. S.E.	5/5/21	.92	.97	" "	CA/ZP
1	13 5th Ave N.E.	7/21/21	.92	.98	" "	RP/ZP
2	518 3rd St. N.W.	7/21/21	.88	.98	" "	RP/ZP
3	500 8th St. S.W.	7/21/21	.94	1.00	" "	RP/ZP
4	26 St. S.E. & 5th Ave. S.E.	7-21-21	.90	.97	" "	RP/ZP

NE Station - W.O.W.