CRITICAL ENERGY INFRASTRUCTURE INFORMATION - CONFIDENTIAL. This data is confidential CEII and is subject to Regulation by CFR Sec. 388.113. Recipient should be aware that disclosure of this material and its contents shall be handled in accordance with CEII procedures. Any and all duplications of this data must contain this notification. This document contains non-public transmission information and in accordance with FERC policy, should not be disclosed to Marketing Function employees.

SMART VALVES AT EAST VILLA RICA SWITCHING STATION

Teams # 21069

Need Date 06/01/2028 **Start Date** 06/01/2026

Description

Installation of Power Flow Controllers at the new East Villa Rica Switching Station on the Douglasville - Villa Rica 230kV and Summer Lake - Villa Rica 230kV lines. The Power Flow Controllers will be removed when GTCs strategic project at Cavender Drive goes in service.

Supporting Statement

REDACTED

Change From Previous Ten Year Plan

New Project

Change From Previous IRP

New Project

Estimated Cost – GPC	**REDACTED**
Estimated Cost – GTC	**REDACTED**
Estimated Cost – MEAG	**REDACTED**
Estimated Cost – DU	**REDACTED**
Estimated Cost – ITS Assigned*	**REDACTED**

** The ITS Assigned designation is for parity forecast purposes only*