AGLR SERVICE CARD	270 Cedar Grove RD, Fairburn, GA 30213	WR NO.	2736472
	LOT:1	TAX DIST.	
		GRID NO.	

PIPE SIZE 8 IPS	PIPE DPT 60	PIPE MAT COATED STEEL	MAIN IS: [redacted]
SERV TAP IS:	[redacted]		
SERV TO BW	[redacted]		
SERVICE IS	[redacted]		

TIE-IN LOCATION	SERVICE TO MAIN LOC	WR TYPE
MAIN	LONGSIDE	RES

PRESSURE MP(1 to 60 PSIG)	TAP 3/8	TEST 450 lbs 0 hrs 10 mins	WITH NITROGEN	KEYBOX

SERVICE CODE - DESC	SIZE	MATERIAL	FOOTAGE	DATE
1A-NEW-SVC	3/4	STEEL	200	12/20/2021

CORNER LOT	OFFSET	SERV INSULATED	ANODE NO.	ANODE SIZE.
NO	NO	RISER		NONE
EXCESS FLOW VALVE		EXCESS FOOTAGE	COUNTY	TYPE RISER
YES		0	FULTON	ANODELESS

CORROSION:	MAIN
TYPE OF PIPE:	COATED STEEL
COND. OF PIPE:	GOOD
MOISTURE:	NORMAL
CORROSION:	NONE
MAX PIT DEPTH:	0
COND. OF COATING:	GOOD
COATING:	EPOXY
SOIL:	CLAY
INTRN. CORRSN.:	NO

SYSTEM	P/S POTENTIAL	BEFORE / WHITE	AFTER / BLACK
ANODE	MAIN	1.87	1.86
	SERVICE		
	TEST WIRE		

CONTRACTOR	DUS
FOREMAN	[redacted]
METER NO	3902057