**From:** [redacted]
**Sent:** Tuesday, March 25, 2025 6:49 AM
**To:** [redacted]
**Subject:** Fwd: FW: shallow main at 4155 Merrigold Way

**Follow Up Flag:** Follow up
**Flag Status:** Flagged

---

**CAUTION:** This email originated from the Internet. Do not click links or open attachments unless you trust the sender and know the content is safe. If in doubt, report this email using the PhishAlarm button.

---------- Forwarded message ---------
From: [redacted]
Date: Wed, Nov 23, 2022 at 2:40 PM
Subject: FW: shallow main at 4155 Merrigold Way
To: [redacted]
Cc: [redacted]

[redacted]

Please get this main lowered to minimum depth, DUS is having a quite a few of these events lately and need to be addressed with your main crews. With the bad rapport with DR Horton this need to happen sooner rather than later.

---

**From:** [redacted]
**Sent:** Wednesday, November 23, 2022 1:46 PM
**To:** [redacted]
**Subject:** shallow main at 4155 Merrigold Way

Main is 23" from top. Sidewalk not installed yet up to end of main in cul de sac. Driveway not poured yet.

I asked SEC crew to install service so builder can move forward with inspections. DUS can disconnect, add pipe and re-test if you decide to have them dig down to proper grade.

I will wait to hear from you before contacting DUS.








[redacted]

Project Coordinator

[redacted]

[redacted]

Atlanta Gas Light

--

[redacted]

Cell - [redacted]
Main - [redacted]
**Diversified Utility Services LLC.**
5371 Cook Rd.
Morrow, GA 30260