AGLR SERVICE CARD	6450 BUFFINGTON RD, Union City, GA 30291	WR NO.	2745791
	LOT:1	TAX DIST.	
		GRID NO.	

PIPE SIZE 2 IPS	PIPE DPT 36	PIPE MAT COATED STEEL
SERV TAP IS:	[redacted]	
SERV TO BW	[redacted]	
SERVICE IS	[redacted]	
	[redacted]	

MAIN IS:	[redacted]	
	[redacted]	
TIE-IN LOCATION	SERVICE TO MAIN LOC	WR TYPE
MAIN	LONGSIDE	COM

PRESSURE HP(60 PSIG)	TAP 8	TEST 500 lbs 4 hrs 0 mins	WITH WATER	KEYBOX YES

SERVICE CODE - DESC	SIZE	MATERIAL	FOOTAGE	DATE
1A-NEW-SVC	2	STEEL	1575	09/24/2021

CORNER LOT	OFFSET	SERV INSULATED	ANODE NO.	ANODE SIZE.
NO	YES	RISER		NONE
EXCESS FLOW VALVE		EXCESS FOOTAGE	COUNTY	TYPE RISER
NO		0	FULTON	ANODELESS

CORROSION:	MAIN
TYPE OF PIPE:	COATED STEEL
COND. OF PIPE:	GOOD
MOISTURE:	NORMAL
CORROSION:	NONE
MAX PIT DEPTH:	0
COND. OF COATING:	GOOD
COATING:	EPOXY
SOIL:	CLAY
INTRN. CORRSN.:	NO

SYSTEM	P/S POTENTIAL	BEFORE / WHITE	AFTER / BLACK
ANODE	MAIN	1.6	1.6
	SERVICE		
	TEST WIRE		

CONTRACTOR	DUS
FOREMAN	[redacted]
METER NO	