Project Information						Proposed Load	Proposed Main Section 1					Proposed Main Section 2					Proposed Main Section 3					Proposed Service				Cost Estimate		Approvals			
Project Name	Address	Location Code	Project Summary	Requested By	Date Requested	Load (MCFH)	Category	Size	Type	Wall Thickness	Length (ft)	Category	Size	Type	Wall Thickness	Length (ft)	Category	Size	Type	Wall Thickness	Length (ft)	Size	Type	Wall Thickness	Length (ft)	Grand Total	Accuracy	Mgr	Director	VP	SVP
LJR Forest Products			Install 1,400 LF of 4" HP STL, 18,000 LF of 6" HP STL and 28,000 LF of 12" HP STL			75	Dist.	6	Steel		18,000	Dist.	12	Steel		28,000						4	Steel		1,400	$ 28,519,308	plus 50% or minus 30%				
TOTAL																										$ 28,519,308					

Note: Steel MAOP 300 psi, plastic MAOP 60 psi unless otherwise noted.

Disclaimer

The attached estimate is for planning purposes only and cannot be used as a firm quotation from Atlanta Gas Light or our contractors. We will not be able to provide a firm quote until the project undergoes additional engineering and cost information is solicited from our vendors thru our formal bid process. The costs provided are based on rule of thumb estimates, local knowledge, and/or past history as well as mapping technologies. The estimated installation period can be delayed due to permitting delays and undetected terrain features (boring through rock formations, water crossings, etc.) which affects costs.