COMMISSIONERS

JASON SHAW , Chairman
LAUREN "BUBBA" McDONALD , Vice-Chairman
PETER HUBBARD
DR. ALICIA M. JOHNSON
TRICIA PRIDEMORE

FILED
MAR 0 3 2026
EXECUTIVE SECRETARY
GPSC

REECE McALISTER
EXECUTIVE DIRECTOR

MICHELLE THEBERT
FACILITIES PROTECTION UNIT DIRECTOR

Georgia Public Service Commission

(404) 463-6526
(800) 282-5813

244 Washington Street, SW
Atlanta, GA 30334-5701

FAX: (404) 463-6532
psc.ga.gov

Docket No. 37024

DOCKET# 37024
DOCUMENT# 225670

AGL - Operations and Engineering
Ten Peachtree Place, NE Suite 1000
Location 1365
Atlanta, GA 30309

REF: Construction Inspection # BS25-016

☐ Certified Mail ☐ Regular Mail ☒ Email

Attention: Walt Farrell

On October 6, 2025, a representative of the Georgia Public Service Commission Pipeline/Facilities Safety Office conducted an inspection of your gas system. The enclosed inspection report numbered BS25-016 is provided for your information and file.

In conjunction with this inspection report, Staff has recommended the following enforcement(s):

Enforcement Action:

- ☐ Notice of Probable Violation
- ☐ Notice of Probable Violation with Proposed Civil Penalty
- ☐ Notice of Amendment

Enforcement Letter:

- ☐ Warning Letter
- ☐ Letter of Concern

Enforcement Notification:

- ☐ Observed Issue
- ☒ No Violation

Please review and respond to this report in accordance with the attached Instructions for Responding to Enforcement Actions, Enforcement Letters, and Notifications Issued by the Georgia Public Service Commission. Please refer to Docket No. 37024 in your response.

Please let me know if there are any questions concerning this report at (404) 985-4271 or mthebert@psc.ga.gov. Thank you for your continuing contribution toward increased pipeline safety.

Sincerely,

Michelle Thebert

Michelle L. Thebert
Director, Office of Pipeline Safety/Facilities Protection

COMMISSIONERS

JASON SHAW , Chairman
LAUREN "BUBBA" McDONALD , Vice-Chairman
PETER HUBBARD
ALICIA M. JOHNSON
TRICIA PRIDEMORE

REECE McALISTER
EXECUTIVE DIRECTOR

MICHELLE THEBERT
FACILITIES PROTECTION UNIT DIRECTOR

Georgia Public Service Commission

(404) 463-6526
(800) 282-5813

244 Washington Street, SW
Atlanta, GA 30334-5701

FAX: (404) 463-6532
psc.ga.gov

REPORT OF NATURAL GAS SAFETY

INSPECTION NO: BS25-016

OPERATOR: AGL - Conyers

INVESTIGATOR: Brant Sweat

INSPECTION DATE: October 6, 2025 REPORT MAILED DATE: February 10, 2026

Any questions concerning this report may be directed to the above address or by telephoning (404) 463-6526.

1. PURPOSE OF INSPECTION

To conduct an inspection of the Operators construction project for compliance with the minimum federal standards in 49CFR Part 192.

2. CONTINUING VIOLATIONS

Violation	Description	Inspection#	Date
192.465(a)	Each pipeline that is under cathodic protection must be tested at least once each calendar year...	JB25-003	2/3/2025

3. CLEARED VIOLATIONS

4. NEW VIOLATIONS

5. OTHER RECOMMENDATIONS/COMMENTS

SEE ATTACHED INSPECTION REPORT

ATLANTA GAS LIGHT / CONSTRUCTION INSPECTION
INSPECTION NUMBER RS25-016 / DOCKET NUMBER 37024

On October 7th Staff reported to Rockdale County, Georgia territory of Atlanta Gas Light to conduct a field inspection of the Operator's construction site. Southern Pipeline was installing a 2, 4, and 6-inch Drisocoplex distribution pipeline and 2, 4, and 6-inch Steel Gas Pipe for Atlanta Gas Light on a main extension because of Salem Rd being widened, Service installation project is located at Salem Rd going all the way to Salem Rd and I-20 Intersection.

During this inspection, the Operator was represented by:
Malcom Loyd – AGL, Quality Assurance Specialist
Damien Brock – Southern Pipeline, Gas Line Technician
Fabien Paredes – Southern Pipeline, Gas Line Technician
Kristopher Kauff – Southern Pipeline, Crew Foreman

During this inspection, the Commission was represented by Brant Sweat Lead Inspector.

NO VIOLATIONS FOUND:

During this inspection Staff reviewed Southern Pipeline construction project specifications for the 2,4 and 6-inch main extension and service installation project at Salem Rd and Interstate 20. This project consisted of installing 21,000 ft of 2, 4, and 6-inch main to widen Salem Rd all the way to Interstate 20 located in Rockdale County. Staff reviewed the materials being used, excavation for the pipe, damage prevention procedures, and qualification records along with an operator qualification field inspection on personnel performing construction tasks.

During this inspection, Staff conducted OQ Protocol 9 field verification inspections to ensure that covered task(s) were being performed in accordance with appropriate Operator-approved procedures, that the procedures were available at the job site, and that the individuals performing the observed covered task(s) were adhering to the operator-approved procedures as written.

During the field evaluations, staff observed multiple SEC Pipeline construction crew workers conduct OQ Protocol 9 field Task. Staff verified that covered task(s) were being performed in accordance with appropriate Operator-approved procedures, that the procedures were available at the job site, and that the individuals performing the observed covered task(s) were adhering to the operator-approved procedures as written.

During the field evaluations, Staff observed Damien Brock performing the Task of Socket Heat Fusion on 6-inch plastic, qualification verified current until 04/20/27. Staff also observed Fabien Paredes performing the Task of Excavation and Backfilling, Qualification current until 05/24/28. Staff also observed Kris Kauff performing the task of Purging Pipelines, qualification current until 02/23/2027. Staff noted that the individuals were cognizant of abnormal operating conditions that could be encountered with their task.

As a result of this inspection Staff noted no probable violations of the minimum federal safety standards.

Please review and respond to this report in accordance with the attached Instructions for Responding to Enforcement Letters Issued by the Georgia Public Service Commission.

OPERATOR RESPONSE FORM

Informal Conference Requested: Yes ☐ No ☐

Operator Name: ATLANTA GAS LIGHT COMPANY

Docket Number: 37024

Responses required within **30 days of electronic mail.** Provide the following information for this report:

Response to Inspection Number:_____

Type of Enforcement Action(s) cited in report:		Informal Conference Requested	
☐ Notice of Probable Violation (NOPV)	☐ New ☐Continuing	☐ Yes	☐ No
☐ Notice of Amendment (NOA)	☐ New ☐Continuing	☐ Yes	☐ No
☐ Warning Letter	☐ New ☐Continuing	☐ Yes	☐ No
☐ Letter of Concern	☐ New ☐Continuing	☐ Yes	☐ No
☐ Observed Issue	☐ New ☐Continuing	☐ Yes	☐ No
☐ Proposed Civil Penalty	$ _____ PCP $ Amount (Total for report)		

Indicate below (A-E) based on the type of Enforcement Actions in this report: (Check all that apply)
Complete a separate copy of Page 2, Operator Response to Enforcement Action, for each cited item.

A. Response for **Notice of Probable Violation** (with and without proposed civil penalty):
   1. ☐ Written statement indicating that corrective measures have achieved Compliance or
   2. ☐ Written plan of action outlining the corrective measures that will be taken to achieve compliance and when compliance is anticipated.

B. Response for **NOA**:
   1. ☐ Contested: Attach written explanation, information, or other material in answer to the allegations in the Notice of Amendment stating your reasons for objecting to the NOA, in whole or in part; or
   2. ☐ Not Contested: Explanation, information, or other material believed to warrant modification of the NOA in whole or in part; or
   3. ☐ Written request for clarification. (Attached)

C. Response for **Continuing** and/or **Existing** violations:
   Current status, updates, expected completion dates, proposed modifications, etc., of the continuing and/or existing violations, even if this information was previously provided. Referencing a previously filed response letter, as status, updates, etc. alone is not sufficient for this response. Failure to provide this information may result in formal interrogatories from the Director through data requests.

D. Response for ☐ **Letter of Concern** / ☐ **Warning Letter**
   I acknowledge receipt of the Letter of Concern/Warning Letter:_____
   SIGNATURE / TITLE

   Additional Comments: (Optional)_____

E. Response for **Observed Issue** and **No Violation**: (Optional Response)
   Staff requests that the Operator acknowledge receipt of the Observed Issue/No Violation in writing, or by submitting an email to the FPU Director

Operator Response to Enforcement Action

Enforcement Action for:_____ ☐ New Violation ☐ Continuing Violation
Enter Code / Commission Rule (Complete a separate attachment for each enforcement action)

Enforcement Action(s) cited in report:	Conference Requested:	
☐ Notice of Probable Violation (NOPV)	☐ Yes ☐ No	$ _____ Proposed Penalty for this violation
☐ Notice of Amendment (NOA)	☐ Yes ☐ No	
☐ Warning Letter	☐ Yes ☐ No	
☐ Letter of Concern	☐ Yes ☐ No	
☐ Observed Issue	☐ Yes ☐ No	
☐ Proposed Civil Penalty	☐ Yes ☐ No	

OPERATORS RESPONSE: _____

_____

_____

_____

_____

_____

_____

_____

Response Provided by: _____ Date:_____
Name / Title

Internal use only:

Lead Inspector: _____ Date Response Reviewed:_____

Actions Acceptable: ☐ Yes ☐No Re-inspection Needed:☐ Yes ☐ No Clear Violation:☐ Yes ☐ No

_____

Supervisor Review by:_____ Date Reviewed:_____

Additional Enforcement Recommended: ☐ Yes ☐ No

_____

Director Review

Approved: ☐ Yes ☐No Schedule Special Follow-up Inspection: ☐ Yes ☐ No

Cleared Violation: ☐ Yes ☐ No

Comments:_____

_____

Filings:
For all written responses or any other official correspondence, the Operator shall file the response at the following address:

Ms. Sallie Tanner, Executive Secretary
Georgia Public Service Commission
244 Washington Street, SW
Atlanta, Georgia 30334

The Operator must file **five (5)** copies of any response and/or official correspondence, as well as a CD with an electronic version of the response in Microsoft Word and/or a PDF, if applicable.

Informal Conference:
Any Operator who chooses to request an informal conference shall request such a conference through emailing the Director (michellet@psc.state.ga.us), calling the Director (404-463-2765), or selecting the "Request Conference" choice.

Civil Penalty Payments:
Certified check for the full amount of the recommended civil penalty or consent agreement amount made payable to the Georgia Public Service Commission. The Operator's name, applicable Docket No., and Inspection Report No. must be included on the certified check. Mail payment to:

Ms. Michelle Thebert, Director, Facilities Protection Unit
Georgia Public Service Commission
244 Washington Street
Atlanta, Georgia 30334

Hearing Requests:
The Operator has the right to request a hearing before the full Commission to contest the alleged probable violations, recommended civil penalties, and all other proposed actions of enforcement. A request for a hearing must be submitted in writing and in accordance with Commission Rule 515-2-1-.04. The Operator must include a statement of the issues that you intend to raise at the hearing. The issues may relate to the allegations, new information, proposed compliance order, proposed civil penalty, or any other recommendation for enforcement action. Please refer to Commission Rule 515-9-3-.11 and O.C.G.A. § 46-2-91 for assessment considerations upon which civil penalties are based. An operator's failure to specify an issue may result in a waiver of the right to raise that issue at hearing. The request must also indicate whether or not the Operator will be represented by counsel at the hearing.

Open Records and Trade Secret Filings:
The Operator is advised that any material provided to the Commission, and all materials prepared by the Commission, including the Notice of Probable Violations and any Orders issued in this case, may be considered public information and subject to disclosure under the Georgia Open Records Act (O.C.G.A. § 50-18-70 et seq.). If you believe that any portion of your response material is security sensitive, privileged, confidential or may cause your company competitive disadvantages and would qualify for protection under the Commission's "Trade Secret Rule" (Commission Rule 515-3-1-.11), you must, along with the complete original document clearly marked "TRADE SECRET" on each page, provide a second copy of the document with the portions you believe qualify for trade secret treatment redacted, and an explanation of why you believe the redacted information qualifies for such trade secret treatment. Should the Commission receive a request for disclosure of any "TRADE SECRET" material, you will be notified, if after review, the materials and your provided justification are deemed not to meet any exemptions provided in the Georgia Open Records Act. You may appeal the Commission's decision to release material at that time. Your appeal will stay the release of those materials until a final decision is made.

BEFORE THE GEORGIA PUBLIC SERVICE COMMISSION
STATE OF GEORGIA

IN THE MATTER OF:	)	
	)	
Atlanta Gas Light Company	)	**DOCKET NO. 37024**
	)	
	)	
	)	

CERTIFICATE OF SERVICE

I, hereby certify that I have this day served a copy of the within and foregoing document on the following persons via email and/or United States Mail as follows:

*Sallie Tanner, Executive Secretary
Georgia Public Service Commission
244 Washington Street, SW
Atlanta, GA 30334

* Walt Farrell, President and CEO
Southern Company Gas
Ten Peachtree Place, NE,
Atlanta, GA 30309
wffarell@southernco.com

*Michelle Thebert, Facilities Protection Unit Director
Georgia Public Service Commission
244 Washington Street, SW
Atlanta, GA 30334

Respectfully Submitted this 5th day of March February 2026:

Cathy Nesbitt

Cathy Nesbitt, Administrative Assistant
Georgia Public Service Commission
Facilities Protection Unit
244 Washington Street, SW
Atlanta, GA 30334