OPERATOR RESPONSE FORM

Operator Name: City of Claxton

Informal Conference Requested: Yes ☐ No ☐X

Docket Number: 37035

Responses required within **30 days of electronic mail.** Provide the following information for this report:

Response to Inspection Number: JS25-032

Type of Enforcement Action(s) cited in report:		Informal Conference Requested	
☐ Notice of Probable Violation (NOPV)	☐ New ☐Continuing	☐ Yes	☐ No
☐ Notice of Amendment (NOA)	☐ New ☐Continuing	☐ Yes	☐ No
☐ Warning Letter	☐ New ☐Continuing	☐ Yes	☐ No
☐ Letter of Concern	☐ New ☐Continuing	☐ Yes	☐ No
☐ Observed Issue	☐ New ☐Continuing	☐ Yes	☐ No
☐ Proposed Civil Penalty	$ _____ PCP $ Amount (Total for report)		

Indicate below (A-E) based on the type of Enforcement Actions in this report: (Check all that apply)
Complete a separate copy of Page 2, Operator Response to Enforcement Action, for each cited item.

A. Response for **Notice of Probable Violation** (with and without proposed civil penalty):
   1. ☐ Written statement indicating that corrective measures have achieved Compliance or
   2. ☐ Written plan of action outlining the corrective measures that will be taken to achieve compliance and when compliance is anticipated.

B. Response for **NOA**:
   1. ☐ Contested: Attach written explanation, information, or other material in answer to the allegations in the Notice of Amendment stating your reasons for objecting to the NOA, in whole or in part; or
   2. ☐ Not Contested: Explanation, information, or other material believed to warrant modification of the NOA in whole or in part; or
   3. ☐ Written request for clarification. (Attached)

C. Response for **Continuing** and/or **Existing** violations:
   Current status, updates, expected completion dates, proposed modifications, etc., of the continuing and/or existing violations, even if this information was previously provided. Referencing a previously filed response letter, as status, updates, etc. alone is not sufficient for this response. Failure to provide this information may result in formal interrogatories from the Director through data requests.

D. Response for ☐ **Letter of Concern** / ☐ **Warning Letter**
   I acknowledge receipt of the Letter of Concern/Warning Letter: _____
   SIGNATURE / TITLE

   Additional Comments: (Optional) _____

E. Response for **Observed Issue** and **No Violation**: (Optional Response)
   Staff requests that the Operator acknowledge receipt of the Observed Issue/No Violation in writing, or by submitting an email to the FPU Director

OPERATOR RESPONSE FORM

Operator Name: City of Claxton

Informal Conference Requested: Yes ☐ No ☐X

Docket Number: 37035

Enforcement Action for: Consent Agreement ☐ New Violation ☒ Continuing Violation

Enter Code / Commission Rule (Complete a separate attachment for each enforcement action)

Enforcement Action(s) cited in report:	Conference Requested:	
☐ Notice of Probable Violation (NOPV)	☐ Yes ☐ No	$ Proposed Penalty for this violation
☐ Notice of Amendment (NOA)	☐ Yes ☐ No	
☐ Warning Letter	☐ Yes ☐ No	
☐ Letter of Concern	☐ Yes ☐ No	
☐ Observed Issue	☐ Yes ☐ No	
☐ Proposed Civil Penalty	☐ Yes ☐ No	

OPERATORS RESPONSE: The City of Claxton negotiated appropriate mitigation measures and formally submitted a written proposal to the Facilities Protection Unit Director

Response Provided by: Danny Hughes Gas Superintendent (Name / Title) Date: 6/10/2026

Internal use only:

Lead Inspector: _____ Date Response Reviewed: _____

Actions Acceptable: ☐ Yes ☐No Re-inspection Needed: ☐ Yes ☐ No Clear Violation: ☐ Yes ☐ No

Supervisor Review by: _____ Date Reviewed: _____

Additional Enforcement Recommended: ☐ Yes ☐ No

Director Review

Approved: ☐ Yes ☐No Schedule Special Follow-up Inspection: ☐ Yes ☐ No

Cleared Violation: ☐ Yes ☐ No

Comments: _____

OPERATOR RESPONSE FORM

Informal Conference Requested: Yes ☐ No ☐X

Operator Name: City of Claxton

Docket Number: 37035

Enforcement Action for: §192.1007(a) ☐ New Violation ☒ Continuing Violation

Enter Code / Commission Rule (Complete a separate attachment for each enforcement action)

Enforcement Action(s) cited in report:	Conference Requested:	
☐ Notice of Probable Violation (NOPV)	☐ Yes ☐ No	$ Proposed Penalty for this violation
☐ Notice of Amendment (NOA)	☐ Yes ☐ No	
☐ Warning Letter	☐ Yes ☐ No	
☐ Letter of Concern	☐ Yes ☐ No	
☐ Observed Issue	☐ Yes ☐ No	
☐ Proposed Civil Penalty	☐ Yes ☐ No	

OPERATORS RESPONSE: Work order forms and procedures are being revised to ensure required material data is captured at the time of installation. Identified work orders are being reviewed and supplemented where documentation is available. All required component data will be reported and retained in accordance with 192.1007(a)5 using Gas Scan software; materials not scannable will be recorded manually. Field personnel have been re-trained on documentation requirements.

Response Provided by: Danny Hughes Gas Superintendent Date: 6/10/2026

Name / Title

Internal use only:

Lead Inspector: _____ Date Response Reviewed: _____

Actions Acceptable: ☐ Yes ☐No Re-inspection Needed: ☐ Yes ☐ No Clear Violation: ☐ Yes ☐ No

Supervisor Review by: _____ Date Reviewed: _____

Additional Enforcement Recommended: ☐ Yes ☐ No

Director Review

Approved: ☐ Yes ☐No Schedule Special Follow-up Inspection: ☐ Yes ☐ No

Cleared Violation: ☐ Yes ☐ No

Comments: _____

OPERATOR RESPONSE FORM

Operator Name: City of Claxton

Informal Conference Requested: Yes ☐ No ☐X

Docket Number: 37035

Enforcement Action for: §192.1007(d) ☐ New Violation ☒ Continuing Violation

Enter Code / Commission Rule (Complete a separate attachment for each enforcement action)

Enforcement Action(s) cited in report:	Conference Requested:
☐ Notice of Probable Violation (NOPV)	☐ Yes ☐ No
☐ Notice of Amendment (NOA)	☐ Yes ☐ No
☐ Warning Letter	☐ Yes ☐ No
☐ Letter of Concern	☐ Yes ☐ No
☐ Observed Issue	☐ Yes ☐ No
☐ Proposed Civil Penalty	☐ Yes ☐ No

$ _____
Proposed Penalty for this violation

OPERATORS RESPONSE: The City of Claxton has reviewed all excavation damages for the 2024 reporting period. Those excavation damages have been verified and submitted to the GUFPA database as needed, and submission records will be retained going forward.

Response Provided by: Danny Hughes Gas Superintendent
Name / Title

Date: 6/10/2026

Internal use only:_____

Lead Inspector: _____ Date Response Reviewed:_____

Actions Acceptable: ☐ Yes ☐No Re-inspection Needed:☐ Yes ☐ No Clear Violation:☐ Yes ☐ No

Supervisor Review by:_____ Date Reviewed:_____

Additional Enforcement Recommended: ☐ Yes ☐ No

Director Review

Approved: ☐ Yes ☐No Schedule Special Follow-up Inspection: ☐ Yes ☐ No

Cleared Violation: ☐ Yes ☐ No

Comments:_____

Filings:

For all written responses or any other official correspondence, the Operator shall file the response at the following address:

Ms. Sallie Tanner, Executive Secretary
Georgia Public Service Commission
244 Washington Street, SW
Atlanta, Georgia 30334

The Operator must file **five (5)** copies of any response and/or official correspondence, as well as a CD with an electronic version of the response in Microsoft Word and/or a PDF, if applicable.

Informal Conference:

Any Operator who chooses to request an informal conference shall request such a conference through emailing the Director (michellet@psc.state.ga.us), calling the Director (404-463-2765), or selecting the "Request Conference" choice.

Civil Penalty Payments:

Certified check for the full amount of the recommended civil penalty or consent agreement amount made payable to the Georgia Public Service Commission. The Operator's name, applicable Docket No., and Inspection Report No. must be included on the certified check. Mail payment to:

Ms. Michelle Thebert, Director, Facilities Protection Unit
Georgia Public Service Commission
244 Washington Street
Atlanta, Georgia 30334

Hearing Requests:

The Operator has the right to request a hearing before the full Commission to contest the alleged probable violations, recommended civil penalties, and all other proposed actions of enforcement. A request for a hearing must be submitted in writing and in accordance with Commission Rule 515-2-1-.04. The Operator must include a statement of the issues that you intend to raise at the hearing. The issues may relate to the allegations, new information, proposed compliance order, proposed civil penalty, or any other recommendation for enforcement action. Please refer to Commission Rule 515-9-3-.11 and O.C.G.A. § 46-2-91 for assessment considerations upon which civil penalties are based. An operator's failure to specify an issue may result in a waiver of the right to raise that issue at hearing. The request must also indicate whether or not the Operator will be represented by counsel at the hearing.

Open Records and Trade Secret Filings:

The Operator is advised that any material provided to the Commission, and all materials prepared by the Commission, including the Notice of Probable Violations and any Orders issued in this case, may be considered public information and subject to disclosure under the Georgia Open Records Act (O.C.G.A. § 50-18-70 et seq.). If you believe that any portion of your response material is security sensitive, privileged, confidential or may cause your company competitive disadvantages and would qualify for protection under the Commission's "Trade Secret Rule" (Commission Rule 515-3-1-.11), you must, along with the complete original document clearly marked "TRADE SECRET" on each page, provide a second copy of the document with the portions you believe qualify for trade secret treatment redacted, and an explanation of why you believe the redacted information qualifies for such trade secret treatment. Should the Commission receive a request for disclosure of any "TRADE SECRET" material, you will be notified, if after review, the materials and your provided justification are deemed not to meet any exemptions provided in the Georgia Open Records Act. You may appeal the Commission's decision to release material at that time. Your appeal will stay the release of those materials until a final decision is made.

City of Claxton's RESPONSE FORM

Informal Conference Requested: Yes ☐ No X

Operator Name: City of Claxton Gas Department

Docket Number: 37035

Responses required within **30 days of electronic mail.** Provide the following information for this report:

Response to Inspection Number: JS25-033

Type of Enforcement Action(s) cited in report:		Informal Conference Requested	
☐ Notice of Probable Violation (NOPV)	☐ New ☒Continuing	☐ Yes	☐ No
☐ Notice of Amendment (NOA)	☐ New ☐Continuing	☐ Yes	☐ No
☐ Warning Letter	☐ New ☐Continuing	☐ Yes	☐ No
☐ Letter of Concern	☐ New ☐Continuing	☐ Yes	☐ No
☐ Observed Issue	☐ New ☐Continuing	☐ Yes	☐ No
☐ Proposed Civil Penalty	$ _____ PCP $ Amount (Total for report)		

Indicate below (A-E) based on the type of Enforcement Actions in this report: (Check all that apply)
Complete a separate copy of Page 2, Operator Response to Enforcement Action, for each cited item.

A. Response for **Notice of Probable Violation** (with and without proposed civil penalty):
   1. ☐ Written statement indicating that corrective measures have achieved Compliance or
   2. ☐ Written plan of action outlining the corrective measures that will be taken to achieve compliance and when compliance is anticipated.

B. Response for **NOA**:
   1. ☐ Contested: Attach written explanation, information, or other material in answer to the allegations in the Notice of Amendment stating your reasons for objecting to the NOA, in whole or in part; or
   2. ☐ Not Contested: Explanation, information, or other material believed to warrant modification of the NOA in whole or in part; or
   3. ☐ Written request for clarification. (Attached)

C. Response for **Continuing** and/or **Existing** violations:
   Current status, updates, expected completion dates, proposed modifications, etc., of the continuing and/or existing violations, even if this information was previously provided. Referencing a previously filed response letter, as status, updates, etc. alone is not sufficient for this response. Failure to provide this information may result in formal interrogatories from the Director through data requests.

D. Response for ☐ **Letter of Concern** / ☐ **Warning Letter**
   I acknowledge receipt of the Letter of Concern/Warning Letter: _____
   SIGNATURE / TITLE

   Additional Comments: (Optional) _____

E. Response for **Observed Issue** and **No Violation**: (Optional Response)
   Staff requests that the Operator acknowledge receipt of the Observed Issue/No Violation in writing, or by submitting an email to the FPU Director

City of Claxton's RESPONSE FORM

Operator Name: City of Claxton Gas Department

Informal Conference Requested: Yes ☐ No X

Docket Number: 37035

Enforcement Action for: 192.1007(d) ☐ New Violation ☒ Continuing Violation

Enter Code / Commission Rule (Complete a separate attachment for each enforcement action)

Enforcement Action(s) cited in report:	Conference Requested:	
☐ Notice of Probable Violation (NOPV)	☐ Yes ☐ No	$ Proposed Penalty for this violation
☐ Notice of Amendment (NOA)	☐ Yes ☐ No	
☐ Warning Letter	☐ Yes ☐ No	
☐ Letter of Concern	☐ Yes ☐ No	
☐ Observed Issue	☐ Yes ☐ No	
☐ Proposed Civil Penalty	☐ Yes ☐ No	

OPERATORS RESPONSE: The City of Claxton replaced or retired 20 services in 2022, 25 in 2023, and 18 in 2024. Leak surveys were conducted along this pipeline segment in both 2023 and 2024, and no leaks were identified. Claxton is currently reassessing its Distribution Integrity Management Program (DIMP) plan to determine whether additional actions are necessary.

Response Provided by: Danny Huges Gas Superintendent Date: 6/10/2026

Name / Title

Internal use only:

Lead Inspector: _____ Date Response Reviewed: _____

Actions Acceptable: ☐ Yes ☐No Re-inspection Needed: ☐ Yes ☐ No Clear Violation: ☐ Yes ☐ No

Supervisor Review by: _____ Date Reviewed: _____

Additional Enforcement Recommended: ☐ Yes ☐ No

Director Review

Approved: ☐ Yes ☐No Schedule Special Follow-up Inspection: ☐ Yes ☐ No

Cleared Violation: ☐ Yes ☐ No

Comments: _____

City of Claxton's RESPONSE FORM

Informal Conference Requested: Yes ☐ No X

Operator Name: City of Claxton Gas Department

Docket Number: 37035

Enforcement Action for: §192.1011 ☐ New Violation ☒ Continuing Violation

Enter Code / Commission Rule (Complete a separate attachment for each enforcement action)

Enforcement Action(s) cited in report:	Conference Requested:	
☐ Notice of Probable Violation (NOPV)	☐ Yes ☐ No	$ Proposed Penalty for this violation
☐ Notice of Amendment (NOA)	☐ Yes ☐ No	
☐ Warning Letter	☐ Yes ☐ No	
☐ Letter of Concern	☐ Yes ☐ No	
☐ Observed Issue	☐ Yes ☐ No	
☐ Proposed Civil Penalty	☐ Yes ☐ No	

OPERATORS RESPONSE: The City of Claxton has confirmed that its list of patrol locations is now complete, and the newly assigned Gas Department personnel are ensuring that all required patrol activities are being carried out.

Response Provided by: Danny Hughes Gas Superintendent Date: 6/10/2026.

Name / Title

Internal use only:

Lead Inspector: _____ Date Response Reviewed: _____

Actions Acceptable: ☐ Yes ☐No Re-inspection Needed: ☐ Yes ☐ No Clear Violation: ☐ Yes ☐ No

Supervisor Review by: _____ Date Reviewed: _____

Additional Enforcement Recommended: ☐ Yes ☐ No

Director Review

Approved: ☐ Yes ☐No Schedule Special Follow-up Inspection: ☐ Yes ☐ No

Cleared Violation: ☐ Yes ☐ No

Comments: _____

City of Claxton's RESPONSE FORM

Informal Conference Requested: Yes ☐ No X

Operator Name: City of Claxton Gas Department

Docket Number: 37035

Enforcement Action for: §192.473(a) ☐ New Violation ☒ Continuing Violation

Enter Code / Commission Rule (Complete a separate attachment for each enforcement action)

Enforcement Action(s) cited in report:	Conference Requested:	
☐ Notice of Probable Violation (NOPV)	☐ Yes ☒ No	$ _____ Proposed Penalty for this violation
☐ Notice of Amendment (NOA)	☐ Yes ☐ No	
☐ Warning Letter	☐ Yes ☐ No	
☐ Letter of Concern	☐ Yes ☐ No	
☐ Observed Issue	☐ Yes ☐ No	
☐ Proposed Civil Penalty	☐ Yes ☐ No	

OPERATORS RESPONSE: The City of Claxton and Southern Natural Pipeline are scheduled to address this issue in August 2024.

Response Provided by: Danny Hughes Gas Superintendent (Name / Title) Date: 6/10/2026.

Internal use only:

Lead Inspector: _____ Date Response Reviewed: _____

Actions Acceptable: ☐ Yes ☐No Re-inspection Needed: ☐ Yes ☐ No Clear Violation: ☐ Yes ☐ No

Supervisor Review by: _____ Date Reviewed: _____

Additional Enforcement Recommended: ☐ Yes ☐ No

Director Review

Approved: ☐ Yes ☐No Schedule Special Follow-up Inspection: ☐ Yes ☐ No

Cleared Violation: ☐ Yes ☐ No

Comments:

_____

_____

_____

City of Claxton's RESPONSE FORM

Informal Conference Requested: Yes ☐ No X

Operator Name: City of Claxton Gas Department

Docket Number: 37035

Enforcement Action for: Consent Agreement ☐ New Violation ☐ Continuing Violation

Enter Code / Commission Rule (Complete a separate attachment for each enforcement action)

Enforcement Action(s) cited in report:	Conference Requested:
☐ Notice of Probable Violation (NOPV)	☐ Yes ☐ No
☐ Notice of Amendment (NOA)	☐ Yes ☐ No
☐ Warning Letter	☐ Yes ☐ No
☐ Letter of Concern	☐ Yes ☐ No
☐ Observed Issue	☐ Yes ☐ No
☐ Proposed Civil Penalty	☐ Yes ☐ No

$ _____
Proposed Penalty for this violation

OPERATORS RESPONSE: City of Claxton is negotiating with the Pipeline Safety Director on a consent agreement.

Response Provided by: Danny Hughes Gas Superintendent Date: 6/10/2026

Name / Title

Internal use only:

Lead Inspector: _____ Date Response Reviewed: _____

Actions Acceptable: ☐ Yes ☐No Re-inspection Needed:☐ Yes ☐ No Clear Violation:☐ Yes ☐ No

Supervisor Review by:_____ Date Reviewed:_____

Additional Enforcement Recommended: ☐ Yes ☐ No

Director Review

Approved: ☐ Yes ☐No Schedule Special Follow-up Inspection: ☐ Yes ☐ No

Cleared Violation: ☐ Yes ☐ No

Comments:_____

City of Claxton's RESPONSE FORM

Informal Conference Requested: Yes ☐ No X

Operator Name: City of Claxton Gas Department

Docket Number: 37035

Enforcement Action for: 192.1007(a) ☒ New Violation ☐ Continuing Violation

Enter Code / Commission Rule (Complete a separate attachment for each enforcement action)

Enforcement Action(s) cited in report:	Conference Requested:
☒ Notice of Probable Violation (NOPV)	☐ Yes ☐ No
☐ Notice of Amendment (NOA)	☐ Yes ☐ No
☐ Warning Letter	☐ Yes ☐ No
☐ Letter of Concern	☐ Yes ☐ No
☐ Observed Issue	☐ Yes ☐ No
☐ Proposed Civil Penalty	☐ Yes ☐ No

$ _____
Proposed Penalty for this violation

OPERATORS RESPONSE: Work order forms and procedures are being revised to ensure required material data is captured at the time of installation. Identified work orders are being reviewed and supplemented where documentation is available. All required component data will be recorded and retained in accordance with §192.1007(a)(5) using Gas Scan software; materials not scannable will be recorded manually Field personnel have been re-instructed on documentation requirements.

Response Provided by: Danny Hughes Gas Superintendent Date: 6/10/2026
Name / Title

Internal use only:

Lead Inspector: _____ Date Response Reviewed: _____

Actions Acceptable: ☐ Yes ☐No Re-inspection Needed: ☐ Yes ☐ No Clear Violation: ☐ Yes ☐ No

Supervisor Review by: _____ Date Reviewed: _____

Additional Enforcement Recommended: ☐ Yes ☐ No

Director Review

Approved: ☐ Yes ☐No Schedule Special Follow-up Inspection: ☐ Yes ☐ No

Cleared Violation: ☐ Yes ☐ No

Comments:

_____

_____

_____

_____

City of Claxton's RESPONSE FORM

Informal Conference Requested: Yes ☐ No X

Operator Name: City of Claxton Gas Department

Docket Number: 37035

Enforcement Action for: §192.1007(d) ☒ New Violation ☐ Continuing Violation

Enter Code / Commission Rule (Complete a separate attachment for each enforcement action)

Enforcement Action(s) cited in report:	Conference Requested:	
☒ Notice of Probable Violation (NOPV)	☐ Yes ☐ No	$ _____ Proposed Penalty for this violation
☐ Notice of Amendment (NOA)	☐ Yes ☐ No	
☐ Warning Letter	☐ Yes ☐ No	
☐ Letter of Concern	☐ Yes ☐ No	
☐ Observed Issue	☐ Yes ☐ No	
☐ Proposed Civil Penalty	☐ Yes ☐ No	

OPERATORS' RESPONSE: The City of Claxton has reviewed all excavation damages for the 2024 reporting period. Those excavation damages have been verified and submitted to the GUFPA database as needed, and submission records will be retained going forward.

Response Provided by: Danny Hughes Gas Superintendent Date: 6/10/2026

Name / Title

Internal use only:

Lead Inspector: _____ Date Response Reviewed: _____

Actions Acceptable: ☐ Yes ☐No Re-inspection Needed: ☐ Yes ☐ No Clear Violation: ☐ Yes ☐ No

Supervisor Review by: _____ Date Reviewed: _____

Additional Enforcement Recommended: ☐ Yes ☐ No

Director Review

Approved: ☐ Yes ☐No Schedule Special Follow-up Inspection: ☐ Yes ☐ No

Cleared Violation: ☐ Yes ☐ No

Comments:

_____

_____

_____

_____

City of Claxton's RESPONSE FORM

Operator Name: City of Claxton Gas Department

Informal Conference Requested: Yes ☐ No X

Docket Number: 37035

Responses required within **30 days of electronic mail.** Provide the following information for this report:

Response to Inspection Number: JS25-041

Type of Enforcement Action(s) cited in report:		Informal Conference Requested	
☐ Notice of Probable Violation (NOPV)	☐ New ☒ Continuing	☐ Yes	☐ No
☐ Notice of Amendment (NOA)	☐ New ☐ Continuing	☐ Yes	☐ No
☐ Warning Letter	☐ New ☐ Continuing	☐ Yes	☐ No
☐ Letter of Concern	☐ New ☐ Continuing	☐ Yes	☐ No
☐ Observed Issue	☐ New ☐ Continuing	☐ Yes	☐ No
☐ Proposed Civil Penalty	$ _____ PCP $ Amount (Total for report)		

Indicate below (A-E) based on the type of Enforcement Actions in this report: (Check all that apply)
Complete a separate copy of Page 2, Operator Response to Enforcement Action, for each cited item.

A. Response for **Notice of Probable Violation** (with and without proposed civil penalty):
   1. ☐ Written statement indicating that corrective measures have achieved Compliance or
   2. ☐ Written plan of action outlining the corrective measures that will be taken to achieve compliance and when compliance is anticipated.

B. Response for **NOA**:
   1. ☐ Contested: Attach written explanation, information, or other material in answer to the allegations in the Notice of Amendment stating your reasons for objecting to the NOA, in whole or in part; or
   2. ☐ Not Contested: Explanation, information, or other material believed to warrant modification of the NOA in whole or in part; or
   3. ☐ Written request for clarification. (Attached)

C. Response for **Continuing** and/or **Existing** violations:
   Current status, updates, expected completion dates, proposed modifications, etc., of the continuing and/or existing violations, even if this information was previously provided. Referencing a previously filed response letter, as status, updates, etc. alone is not sufficient for this response. Failure to provide this information may result in formal interrogatories from the Director through data requests.

D. Response for ☐ **Letter of Concern** / ☐ **Warning Letter**
   I acknowledge receipt of the Letter of Concern/Warning Letter: _____
   SIGNATURE / TITLE

   Additional Comments: (Optional) _____

E. Response for **Observed Issue** and **No Violation**: (Optional Response)
   Staff requests that the Operator acknowledge receipt of the Observed Issue/No Violation in writing, or by submitting an email to the FPU Director

City of Claxton's RESPONSE FORM

Operator Name: City of Claxton Gas Department

Informal Conference Requested: Yes ☐ No X

Docket Number: 37035

Enforcement Action for: §192.1007(a) ☐ New Violation ☒ Continuing Violation

Enter Code / Commission Rule (Complete a separate attachment for each enforcement action)

Enforcement Action(s) cited in report:	Conference Requested:	
☐ Notice of Probable Violation (NOPV)	☒ Yes ☐ No	$ _____ Proposed Penalty for this violation
☐ Notice of Amendment (NOA)	☐ Yes ☐ No	
☐ Warning Letter	☐ Yes ☐ No	
☐ Letter of Concern	☐ Yes ☐ No	
☐ Observed Issue	☐ Yes ☐ No	
☐ Proposed Civil Penalty	☐ Yes ☐ No	

OPERATORS RESPONSE: Work order forms and procedures are being revised to ensure required material data is captured at the time of installation. Identified work orders are being reviewed and supplemented where documentation is available. All required component data will be recorded and retained in accordance with §192.1007(a)(5) using Gas Scan software; materials not scannable will be recorded manually. Field personnel have been re-instructed on documentation requirements.

Response Provided by: Danny Hughes Gas Superintendent Date: 6/10/2026.

Name / Title

Internal use only:

Lead Inspector: _____ Date Response Reviewed: _____

Actions Acceptable: ☐ Yes ☐No Re-inspection Needed: ☐ Yes ☐ No Clear Violation: ☐ Yes ☐ No

Supervisor Review by: _____ Date Reviewed: _____

Additional Enforcement Recommended: ☐ Yes ☐ No

Director Review

Approved: ☐ Yes ☐No Schedule Special Follow-up Inspection: ☐ Yes ☐ No

Cleared Violation: ☐ Yes ☐ No

Comments: _____

Enforcement Action for: 192.1007(d) ☐ New Violation ☒ Continuing Violation

Enter Code / Commission Rule (Complete a separate attachment for each enforcement action)

Enforcement Action(s) cited in report:	Conference Requested:	
☐ Notice of Probable Violation (NOPV)	☐ Yes ☒ No	$ Proposed Penalty for this violation
☐ Notice of Amendment (NOA)	☐ Yes ☐ No	
☐ Warning Letter	☐ Yes ☐ No	
☐ Letter of Concern	☐ Yes ☐ No	
☐ Observed Issue	☐ Yes ☐ No	
☐ Proposed Civil Penalty	☐ Yes ☐ No	

OPERATORS RESPONSE: The City of Claxton has reviewed all excavation damages for the 2024 reporting period. Those excavation damages have been verified and submitted to the GUFPA database as needed, and submission records will be retained going forward.

Response Provided by: Danny Hughes Gas Superintendent Date: 6/10/2026.
Name / Title

Internal use only:

Lead Inspector: _____ Date Response Reviewed: _____

Actions Acceptable: ☐ Yes ☐No Re-inspection Needed:☐ Yes ☐ No Clear Violation:☐ Yes ☐ No

Supervisor Review by: _____ Date Reviewed: _____

Additional Enforcement Recommended: ☐ Yes ☐ No

Director Review

Approved: ☐ Yes ☐No Schedule Special Follow-up Inspection: ☐ Yes ☐ No

Cleared Violation: ☐ Yes ☐ No

Comments:

Filings:

For all written responses or any other official correspondence, the Operator shall file the response at the following address:

Ms. Sallie Tanner, Executive Secretary
Georgia Public Service Commission
244 Washington Street, SW
Atlanta, Georgia 30334

The Operator must file **five (5)** copies of any response and/or official correspondence, as well as a CD with an electronic version of the response in Microsoft Word and/or a PDF, if applicable.

Informal Conference:

Any Operator who chooses to request an informal conference shall request such a conference through emailing the Director (michellet@psc.state.ga.us), calling the Director (404-463-2765), or selecting the "Request Conference" choice.

Civil Penalty Payments:

Certified check for the full amount of the recommended civil penalty or consent agreement amount made payable to the Georgia Public Service Commission. The Operator's name, applicable Docket No., and Inspection Report No. must be included on the certified check. Mail payment to:

Ms. Michelle Thebert, Director, Facilities Protection Unit
Georgia Public Service Commission
244 Washington Street
Atlanta, Georgia 30334

Hearing Requests:

The Operator has the right to request a hearing before the full Commission to contest the alleged probable violations, recommended civil penalties, and all other proposed actions of enforcement. A request for a hearing must be submitted in writing and in accordance with Commission Rule 515-2-1-.04. The Operator must include a statement of the issues that you intend to raise at the hearing. The issues may relate to the allegations, new information, proposed compliance order, proposed civil penalty, or any other recommendation for enforcement action. Please refer to Commission Rule 515-9-3-.11 and O.C.G.A. § 46-2-91 for assessment considerations upon which civil penalties are based. An operator's failure to specify an issue may result in a waiver of the right to raise that issue at hearing. The request must also indicate whether or not the Operator will be represented by counsel at the hearing.

Open Records and Trade Secret Filings:

The Operator is advised that any material provided to the Commission, and all materials prepared by the Commission, including the Notice of Probable Violations and any Orders issued in this case, may be considered public information and subject to disclosure under the Georgia Open Records Act (O.C.G.A. § 50-18-70 et seq.). If you believe that any portion of your response material is security sensitive, privileged, confidential or may cause your company competitive disadvantages and would qualify for protection under the Commission's "Trade Secret Rule" (Commission Rule 515-3-1-.11), you must, along with the complete original document clearly marked "TRADE SECRET" on each page, provide a second copy of the document with the portions you believe qualify for trade secret treatment redacted, and an explanation of why you believe the redacted information qualifies for such trade secret treatment. Should the Commission receive a request for disclosure of any "TRADE SECRET"

material, you will be notified, if after review, the materials and your provided justification are deemed not to meet any exemptions provided in the Georgia Open Records Act. You may appeal the Commission's decision to release material at that time. Your appeal will stay the release of those materials until a final decision is made.