MFR-7 Project Technical Analysis - Bartow

Project Information						Proposed Load	Proposed Main Section 1					Proposed Main Section 2					Proposed Main Section 3					Proposed Main Section 4					Cost Estimate		Approvals			
Project Name	Address	Location Code	Project Summary	Requested By	Date Requested	Load (MCFH)	Category	Size	Type	Wall Thickness	Length (ft)	Category	Size	Type	Wall Thickness	Length (ft)	Category	Size	Type	Wall Thickness	Length (ft)	Category	Size	Type	Wall Thickness	Length (ft)	Grand Total	Accuracy	Mgr	Director	VP	SVP
Cumming-Dawson Co Poultry Farms USF	Cumming	3320	Install 62,000' of 8" HP STL Pipe and approximately 86,850' of 6" and 4" Plastic Pipe	New Business	4/1/2026	100	Distribution	8"	Steel	0.219"	62,000	Distribution	6"	Pls	0.576" (SDR 11)	57,350	Distribution	4"	Pls	0.391" (SDR 11.5)	29,500						64,667,675	+50% -30%				
TOTAL																											$ 64,667,675					

Note: Plastic MAOP - 60 psi, steel MAOP - 300 psi unless otherwise noted.

Disclaimer

The attached estimate is for planning purposes only and cannot be used as a firm quotation from Atlanta Gas Light or our contractors. We will not be able to provide a firm quote until the project undergoes additional engineering and cost information is solicited from our vendors thru our formal bid process. The costs provided are based on rule of thumb estimates, local knowledge, and/or past history as well as mapping technologies. Keep in mind the estimated installation period can be delayed due to permitting delays and undetected terrain features (boring through rock formations, water crossings, etc.).